


VENTILATION AUDIT REPORT

SCHOOL:	Campsie Public School (1488)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Canterbury
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

1488 - Campsie Public School
Site Plan (10140)







































1:731

Printed: 13-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Special Programs Room - (47.54 SQM)	● Student Space (22)	
B00A - R0002 - Home Base - (47.14 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0009 - Special Programs Room - (19.65 SQM)	● Student Space (9)	
B00A - R0010 - Home Base - (48.23 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0011 - Home Base - (47.44 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0012 - Home Base - (47.43 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0017 - Movement - (12.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (12.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Special Programs Room - (28.78 SQM)	● Student Space (13)	
B00A - R0032 - Practical Activities - 1hb - (11.47 SQM)	● Student Space (5)	
B00A - R0034 - Home Base - (47.57 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0035 - Practical Activities - 1hb - (15.55 SQM)	● Student Space (7)	
B00A - R0037 - Practical Activities - 1hb - (15.94 SQM)	● Student Space (7)	
B00A - R0040 - Practical Activities - 1hb - (12.98 SQM)	● Student Space (6)	
B00A - R0041 - Movement - (7.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Movement - (74.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Withdrawal Space - 1hb - (11.29 SQM)	● Student Space (5)	
B00A - R0046 - Withdrawal Space - 1hb - (10.12 SQM)	● Student Space (4)	
B00A - R0047 - Withdrawal Space - 1hb - (9.82 SQM)	● Student Space (4)	
B00A - R0050 - Movement - (19.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0053 - Practical Activities - 1hb - (15.15 SQM)	● Student Space (7)	
B00A - R0054 - Practical Activities - 1hb - (15.48 SQM)	● Student Space (7)	
B00A - R0058 - Breakout Area - (32.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0059 - Special Programs Room - (45 SQM)	● Student Space (20)	
B00A - R0060 - Movement - (72.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (49.65 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1002 - Home Base - (48.77 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1006 - Withdrawal Space - 1hb - (19.69 SQM)	● Student Space (9)	
B00A - R1007 - Home Base - (50.17 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1008 - Home Base - (49.42 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1009 - Home Base - (49.27 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1011 - Home Base - M - (50.03 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1020 - Staff Room Annexe - (6.62 SQM)	● Office (1)	
B00A - R1022 - Movement - (26.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R1023 - Special Programs Room - (30.21 SQM)	● Student Space (14)	
B00A - R1024 - Movement - (18.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Practical Activities - 1hb - (11.83 SQM)	● Student Space (5)	
B00A - R1034 - Movement - (9.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R1035 - Movement - (52.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R1036 - Practical Activities - 1hb - (15.86 SQM)	● Student Space (7)	
B00A - R1038 - Practical Activities - 1hb - (16.08 SQM)	● Student Space (7)	
B00A - R1041 - Practical Activities - 1hb - (13.06 SQM)	● Student Space (6)	
B00A - R1042 - Special Programs Room - (8.86 SQM)	● Student Space (4)	
B00A - R1043 - Practical Activities - 1hb - (17.47 SQM)	● Student Space (8)	
B00A - R1044 - Practical Activities - 1hb - (17.11 SQM)	● Student Space (7)	
B00A - R1047 - Special Programs Room - (45.42 SQM)	● Student Space (21)	
B00B - M0002 - Movement - (5.01 SQM)	Not Applicable	Circulation or storage space.
B00B - M0005 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (48.56 SQM) - Teaching Space: 1	● Student Space (22)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0006 - Home Base - (48.55 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R0013 - Entry Vestibule - (15.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Clerical Office/Workroom - (47.81 SQM)	 Office (11)	
B00B - R0015 - Sick Bay - (8.95 SQM)	 Student Space (4)	
B00B - R0018 - Interview - (9.5 SQM)	 Office (2)	
B00B - R0019 - Interview - (21.97 SQM)	 Office (5)	
B00B - R0020 - Principal - (22.84 SQM)	 Office (5)	
B00B - R0021 - Staff Room - (102.63 SQM)	 Office (25)	
B00B - R0025 - Home Base - (47.53 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R0026 - Home Base - (47.6 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R0028 - Movement - (11.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Deputy Principal - (16.46 SQM)	 Office (4)	
B00B - R0036 - Clerical Office - (24.57 SQM)	 Office (6)	
B00B - R0038 - Movement - (78.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0039 - Movement - (18.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0044 - Movement - (8.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0047 - Movement - (47.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0048 - Movement - (11.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0053 - Special Programs Room - (20.81 SQM)	 Student Space (9)	
B00B - R0054 - Practical Activities - 1hb - (31.13 SQM)	 Student Space (14)	
B00B - R0056 - Withdrawal Space - 1hb - (5.57 SQM)	 Student Space (2)	
B00B - R0058 - Practical Activities - 1hb - (14.73 SQM)	 Student Space (6)	
B00B - R0059 - Special Programs Room - (9.36 SQM)	 Student Space (4)	
B00B - R0060 - Practical Activities - 1hb - (12.92 SQM)	 Student Space (5)	
B00B - R0061 - Special Programs Room - (39.57 SQM)	 Student Space (18)	
B00B - R0063 - Practical Activities - 1hb - (9.3 SQM)	 Student Space (4)	
B00B - R0064 - Withdrawal Space - 1hb - (13.61 SQM)	 Student Space (6)	
B00B - R0065 - Practical Activities - 1hb - (11.08 SQM)	 Student Space (5)	
B00B - R0067 - Movement - (23.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0068 - Home Base - (48.29 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R0069 - Home Base - (48.52 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R1004 - Home Base - (48.62 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R1006 - Home Base - (48.14 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R1009 - Home Base - (47.94 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R1017 - Home Base - (49.27 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R1019 - Home Base - (50.51 SQM) - Teaching Space: 1	 Student Space (23)	
B00B - R1022 - Movement - (34.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R1024 - Home Base - (42.68 SQM) - Teaching Space: 1	 Student Space (19)	
B00B - R1025 - Practical Activities - 1hb - (8.98 SQM)	 Student Space (4)	
B00B - R1028 - Movement - (54.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R1029 - Practical Activities - 1hb - (12.35 SQM)	 Student Space (5)	
B00B - R1030 - Movement - (29.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R1031 - Withdrawal Space - 1hb - (12.66 SQM)	 Student Space (5)	
B00B - R1032 - Practical Activities - E - (12.17 SQM)	 Student Space (5)	
B00B - R1033 - Home Base - (50.79 SQM) - Teaching Space: 1	 Student Space (23)	
B00B - R1035 - Withdrawal Space - 1hb - (5.95 SQM)	 Student Space (2)	
B00B - R1037 - Practical Activities - 1hb - (32.34 SQM)	 Student Space (15)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1038 - Home Base - (49.8 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1039 - Practical Activities - 1hb - (13.19 SQM)	Student Space (6)	
B00B - R1040 - Home Base - (38.78 SQM) - Teaching Space: 1	Student Space (17)	
B00B - R1041 - Special Programs Room - (20.68 SQM)	Student Space (9)	
B00B - R1043 - Practical Activities - 1hb - (13.94 SQM)	Student Space (6)	
B00B - R1044 - Movement - (19.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R1046 - Home Base - (45.62 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1048 - Withdrawal Space - 1hb - (7.82 SQM)	Student Space (3)	
B00B - R1050 - Practical Activities - 1hb - (32.79 SQM)	Student Space (15)	
B00B - R1051 - Home Base - (51.55 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1053 - Movement - (64.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R1055 - Practical Activities - 1hb - (11.85 SQM)	Student Space (5)	
B00B - R1056 - Withdrawal Space - 1hb - (14.02 SQM)	Student Space (6)	
B00B - R1057 - Practical Activities - 1hb - (11.97 SQM)	Student Space (5)	
B00C - R0003 - Communal Space - (215.24 SQM)	Student Space (99)	
B00C - R0014 - Canteen - (49.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Raised Platform - (62.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (106.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Special Programs Room - (49.92 SQM)	Student Space (23)	
B00C - R1003 - Reading Area - (285.14 SQM)	Student Space (132)	
B00E - R0004 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Practical Activities - (17.84 SQM)	Student Space (8)	
B00G - R0002 - Home Base - (61.87 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0004 - Withdrawal Space - 2hb - (11.7 SQM)	Student Space (5)	
B00G - R0005 - Practical Activities - 2hb - (18.99 SQM)	Student Space (8)	
B00G - R0006 - Home Base - (61.66 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R1001 - Practical Activities - 1hb - (18.99 SQM)	Student Space (8)	
B00G - R1002 - Home Base - (61.66 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R1004 - Withdrawal Space - 2hb - (11.7 SQM)	Student Space (5)	
B00G - R1005 - Practical Activities - (18.99 SQM)	Student Space (8)	
B00G - R1006 - Home Base - (61.66 SQM) - Teaching Space: 1	Student Space (28)	
OS 600 11511 - OS 600 11511 - Learning Unit - Small - (57 SQM)	Student Space (26)	