

VENTILATION AUDIT REPORT

SCHOOL:	Canley Heights Public School (3983)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Fairfield
LOCAL GOVERNMENT AREA:	Fairfield

3983 - Canley Heights Public School
Site Plan (10921)



1:947

Printed: 10-Apr-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Home Base - (65.12 SQM) - Teaching Space: 1	● Student Space (30)	
B001 - R0005 - Movement - (7.51 SQM)	Not Applicable	Circulation or storage space.
B001 - R0010 - Home Base - (66.98 SQM) - Teaching Space: 1	● Student Space (31)	
B001 - R0012 - Movement - (5.59 SQM)	Not Applicable	Circulation or storage space.
B002 - R0001 - Home Base - (66.67 SQM) - Teaching Space: 1	● Student Space (30)	
B002 - R0004 - Movement - (7.86 SQM)	Not Applicable	Circulation or storage space.
B002 - R0009 - Home Base - (66.67 SQM) - Teaching Space: 1	● Student Space (30)	
B003 - R0005 - Home Base - (65.2 SQM) - Teaching Space: 1	● Student Space (30)	
B003 - R0007 - Home Base - (65.23 SQM) - Teaching Space: 1	● Student Space (30)	
B004 - R0001 - Home Base - (51.05 SQM) - Teaching Space: 1	● Student Space (23)	
B004 - R0002 - Practical Activities - 1hb - (16.39 SQM)	● Student Space (7)	
B004 - R0005 - Movement - (12.15 SQM)	Not Applicable	Circulation or storage space.
B004 - R0008 - Interview - (16.11 SQM)	● Office (4)	
B005 - R0002 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B005 - R0007 - Home Base - (56.17 SQM) - Teaching Space: 1	● Student Space (26)	
B005 - R0008 - Home Base - (56.9 SQM) - Teaching Space: 1	● Student Space (26)	
B006 - R0003 - Movement - (11.47 SQM)	Not Applicable	Circulation or storage space.
B006 - R0005 - Special Programs Room - (54.19 SQM)	● Student Space (25)	
B006 - R0010 - Reading Area - (109.25 SQM)	● Student Space (50)	
B006 - R0011 - Reading Area - (36.64 SQM)	● Student Space (16)	
B00A - R0001 - Home Base - (58.01 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0005 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Home Base - (56.42 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0011 - Home Base - (56.85 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0016 - Movement - (12.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Staff Room Annexe - (15.13 SQM)	● Office (3)	
B00C - R0001 - Home Base - (79.03 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R0005 - Practical Activities - 1hb - (9.57 SQM)	● Student Space (4)	
B00C - R0006 - Movement - (10.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Home Base - (77.05 SQM) - Teaching Space: 1	● Student Space (35)	
B00C - R0010 - Home Base - (56.17 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0013 - Staff Room Annexe - (18.31 SQM)	● Office (4)	
B00C - R0015 - Movement - (10.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (57.53 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0004 - Movement - (6.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (56.47 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0010 - Home Base - (56.07 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0002 - Staff Room Annexe - (19.27 SQM)	● Office (4)	
B00E - R0004 - Movement - (10.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Home Base - (56.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0010 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Home Base - (56.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0001 - Practical Activities - 1hb - (19.18 SQM)	● Student Space (8)	
B00F - R0002 - Home Base - (61.22 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0004 - Withdrawal Space - 2hb - (11.75 SQM)	● Student Space (5)	
B00F - R0005 - Practical Activities - 1hb - (19.25 SQM)	● Student Space (8)	
B00F - R0006 - Home Base - (61.31 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0008 - Practical Activities - 1hb - (18.61 SQM)	● Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0009 - Home Base - (61.15 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0011 - Withdrawal Space - 2hb - (11.75 SQM)	● Student Space (5)	
B00F - R0012 - Practical Activities - 1hb - (19.14 SQM)	● Student Space (8)	
B00F - R0013 - Home Base - (61.35 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0001 - Practical Activities - 1hb - (18.59 SQM)	● Student Space (8)	
B00G - R0002 - Home Base - (61.27 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0004 - Withdrawal Space - 2hb - (11.75 SQM)	● Student Space (5)	
B00G - R0005 - Practical Activities - 1hb - (19.14 SQM)	● Student Space (8)	
B00G - R0006 - Home Base - (61.27 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0001 - Communal Space - (196.02 SQM)	● Student Space (90)	
B00H - R0002 - Raised Platform - (60.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Movement - (10.07 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Movement - (16.46 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (8.69 SQM)	Not Applicable	Circulation or storage space.
B00P - R0004 - Withdrawal Space - 1hb - (19.86 SQM)	● Student Space (9)	
B00P - R0005 - Practical Activities - Pre - (18.77 SQM)	● Student Space (8)	
B00P - R0006 - Home Base - Pre - (53.83 SQM) - Teaching Space: 1	● Student Space (24)	
B00P - R0012 - Movement - (19.73 SQM)	Not Applicable	Circulation or storage space.
B010 - R0002 - Canteen - (34.95 SQM)	Not Applicable	Circulation or storage space.
B018 - R0002 - Entry Vestibule - (10.32 SQM)	Not Applicable	Circulation or storage space.
B018 - R0003 - Clerical Office - (14.22 SQM)	● Office (3)	
B018 - R0004 - Sick Bay - (9.37 SQM)	● Student Space (4)	
B018 - R0005 - Deputy Principal - (12.93 SQM)	● Office (3)	
B018 - R0011 - Movement - (15.12 SQM)	Not Applicable	Circulation or storage space.
B018 - R0012 - Clerical Office/Workroom - (20.04 SQM)	● Office (5)	
B018 - R0015 - Principal - (17.2 SQM)	● Office (4)	
B018 - R0016 - Staff Room - (48.31 SQM)	● Office (12)	
B019 - R0002 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B019 - R0004 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B019 - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B019 - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B019 - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
OS 603 10953 - OS 603 10953 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 750 17817 - OS 750 17817 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	