

VENTILATION AUDIT REPORT

SCHOOL:	Canley Vale High School (8393)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Fairfield
LOCAL GOVERNMENT AREA:	Fairfield

8393 - Canley Vale High School
Site Plan (13404)



1:1,069

Printed: 27-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Ancillary Staff - (19.99 SQM)	Office (4)	
B00A - R0003 - Preparation - Science - (23.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Laboratory L.S. - (91.2 SQM)	Student Space (42)	
B00A - R0007 - Staff Study - (25.92 SQM)	Office (6)	
B00A - R0009 - Administration - Clerical - (13.32 SQM)	Office (3)	
B00A - R0010 - Administration - Clerical - (45.92 SQM)	Office (11)	
B00A - R0011 - Public Reception - (39.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Principal Office - (19.79 SQM)	Office (4)	
B00A - R0015 - Clinic - (7.2 SQM)	Office (1)	
B00A - R0018 - Movement - (8.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Staff Study - (32.87 SQM)	Office (8)	
B00A - R0022 - General Assistants - (24.61 SQM)	Office (6)	
B00A - R0030 - Public Reception - (20.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Public Reception - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Interview/Meeting - (38.48 SQM)	Office (9)	
B00A - R0033 - Interview/Meeting - (13.13 SQM)	Office (3)	
B00A - R0034 - Clinic - (10.25 SQM)	Office (2)	
B00A - R0035 - Movement - (24.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Clinic - (12.25 SQM)	Office (3)	
B00A - R0040 - Interview/Meeting - (23.77 SQM)	Office (5)	
B00A - R0041 - Student Reception - (32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Principal Office - (26.07 SQM)	Office (6)	
B00A - R0045 - Movement - (7.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Administration - Clerical - (136.02 SQM)	Office (34)	
B00A - R0047 - Deputy Principal Office - (22.63 SQM)	Office (5)	
B00A - R0048 - Deputy Principal Office - (22.95 SQM)	Office (5)	
B00A - R0049 - Deputy Principal Office - (22.19 SQM)	Office (5)	
B00A - R0050 - Student Canteen - (71.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (59.64 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1002 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1003 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1004 - General Learning Space - (55.7 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1008 - Computer Learning Space - (53.68 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1009 - Computer Learning Space - (66.21 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1013 - Student Waiting - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Deputy Principal Office - (13.76 SQM)	Office (3)	
B00A - R1015 - General Learning Space - (50.74 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1018 - General Learning Space - (53.82 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1026 - Student Waiting - (5.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R1027 - Deputy Principal Office - (13.84 SQM)	Office (3)	
B00A - R1028 - General Learning Space - (39.82 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1029 - General Learning Space - (33.02 SQM) - Teaching Space: 1	Student Space (15)	
B00B - R0002 - Computer Learning Space - (53.75 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0009 - Staff Study - (29.91 SQM)	Office (7)	
B00B - R0010 - Wood Technology L.S. - (80.88 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0015 - Food Technology L.S. - (72.3 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0023 - Art Learning Space - (63.97 SQM) - Teaching Space: 1	Student Space (29)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0030 - Preparation - Materials - (17.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Food Technology L.S. - (78.91 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0034 - Food/Research Space - (31.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Metal Technology L.S. - (100.41 SQM) - Teaching Space: 1	● Student Space (46)	
B00B - R0041 - Tea Room - (6.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0042 - Staff Study - (30.72 SQM)	○ Office (7)	
B00B - R1004 - Textiles Technology L.S. - (50.82 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1011 - Welding Area - (15.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R1012 - Textiles Technology L.S. - (67.24 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R1017 - Art Learning Space - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1018 - Staff Study - (25.53 SQM)	○ Office (6)	
B00B - R1019 - Art Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1022 - Art Learning Space - (59.4 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1027 - Wood Technology L.S. - (104.58 SQM) - Teaching Space: 1	● Student Space (48)	
B00B - R1030 - Metal Technology L.S. - (104.52 SQM) - Teaching Space: 1	● Student Space (48)	
B00C - R0003 - Audio Visual Workroom - (30.29 SQM)	● Student Space (14)	
B00C - R0006 - Movement - (7.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Movement - (6.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Main Entry - (19.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Main Area - (372.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (21.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Movement - (21.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - Senior Study - (13.2 SQM)	○ Office (3)	
B00C - R1009 - Senior Study - (13.32 SQM)	○ Office (3)	
B00C - R1010 - Senior Study - (13.32 SQM)	○ Office (3)	
B00C - R1014 - Senior Study - (152.05 SQM)	○ Office (38)	
B00D - R0001 - Laboratory L.S. - (99.64 SQM) - Teaching Space: 1	● Student Space (46)	
B00D - R0003 - General Learning Space - (65.35 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0004 - Laboratory L.S. - (86.44 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R0006 - Preparation - Science - (18.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0010 - Staff Study - (13.55 SQM)	○ Office (3)	
B00D - R0011 - Interview/Office - Type 1 - (13.07 SQM)	○ Office (3)	
B00D - R0014 - Laboratory L.S. - (85.26 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0020 - Preparation - Science - (39.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - (59.41 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1004 - General Learning Space - (65.41 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1005 - General Learning Space - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1006 - General Learning Space - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1007 - General Learning Space - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1008 - Computer Learning Space - (59.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1009 - Staff Study - (21.63 SQM)	○ Office (5)	
B00D - R1010 - General Learning Space - (53.97 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1013 - General Learning Space - (59.4 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1014 - Staff Study - (39.42 SQM)	○ Office (9)	
B00D - R1015 - Staff Study - (39.43 SQM)	○ Office (9)	
B00E - R0002 - Computer Learning Space - (65.96 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0005 - Staff Study - (26.95 SQM)	○ Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0008 - General Learning Space - (32.32 SQM) - Teaching Space: 1	● Student Space (14)	
B00E - R0012 - Student Waiting - (12.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Interview/Office - Type 1 - (12.61 SQM)	● Office (3)	
B00E - R0014 - General Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0015 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0016 - General Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0024 - Laboratory L.S. - (92.85 SQM) - Teaching Space: 1	● Student Space (43)	
B00E - R0025 - Preparation - Science - (28.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0027 - Laboratory L.S. - (92.65 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0028 - Laboratory L.S. - (92.8 SQM) - Teaching Space: 1	● Student Space (43)	
B00E - R0037 - Preparation - Science - (39.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0040 - Staff Study - (50.11 SQM)	● Office (12)	
B00E - R0045 - Commonroom - (67.06 SQM)	● Office (16)	
B00E - R0046 - Staff Kitchen - (6.77 SQM)	● Office (1)	
B00E - R0047 - Seminar - (40.5 SQM)	● Office (10)	
B00E - R0048 - General Learning Space - (65.78 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0049 - Commonroom - (22.18 SQM)	● Office (5)	
B00E - R0051 - General Learning Space - (104.11 SQM) - Teaching Space: 1	● Student Space (48)	
B00E - R1003 - Study Space - (12.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Senior Study - (13.44 SQM)	● Office (3)	
B00E - R1009 - General Learning Space - (59.08 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1010 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1011 - General Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1012 - General Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1013 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1016 - General Assistants - (52.36 SQM)	● Office (13)	
B00E - R1018 - General Learning Space - (59.15 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1020 - General Learning Space - (53.97 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R1021 - Practice/Seminar - (25.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R1022 - Staff Study - (28.16 SQM)	● Office (7)	
B00E - R1024 - Music Learning Space - (59.08 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1026 - Music Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1029 - Staff Study - (52.8 SQM)	● Office (13)	
B00E - R1031 - Staff Study - (26 SQM)	● Office (6)	
B00E - R1036 - General Learning Space - (58.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1042 - Practice/Seminar - (31.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R1044 - Leading Teacher - (6.74 SQM)	● Office (1)	
B00E - R1045 - Performance Workspace - (79.16 SQM) - Teaching Space: 1	● Student Space (36)	
B00E - R1046 - General Learning Space - (53.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1047 - Study Space - (26.58 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Student Canteen - (52.61 SQM)	Not Applicable	Circulation or storage space.
B00G - M0001 - Movement - (132.22 SQM)	Not Applicable	Circulation or storage space.
B00G - M0002 - Fitness Laboratory - (28.4 SQM)	● Student Space (13)	
B00G - R0002 - Staff Kitchen - (12.52 SQM)	● Office (3)	
B00G - R0014 - Multi-Purpose Space - (504.95 SQM)	● Student Space (234)	
B00G - R0035 - Stage - (82.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0043 - Stage - (98.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R0049 - Entry - (23.94 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0050 - Gymnasium - (658.04 SQM)	● Student Space (305)	
B00J - R0001 - Movement - (54.38 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - Lecture Space - (207.44 SQM) - Teaching Space: 2	● Student Space (96)	
B00K - R0001 - General Learning Space - (150.61 SQM) - Teaching Space: 1	● Student Space (69)	
B00L - R0001 - General Learning Space - (62.48 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R0002 - Workshop - (106.99 SQM)	● Student Space (49)	
B00L - R0003 - General Learning Space - (63.53 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R0004 - General Learning Space - (63.71 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R0006 - Shared Learning Space - (194.45 SQM)	● Student Space (90)	
B00L - R0007 - Workroom - (53.21 SQM)	● Office (13)	
B00L - R0009 - Design L.S. - (58.99 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0010 - Workshop - (100.01 SQM)	● Student Space (46)	
B00L - R0011 - General Learning Space - (59.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0015 - Movement - (33.63 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Movement - (22.17 SQM)	Not Applicable	Circulation or storage space.
B00L - R0028 - Movement - (26.27 SQM)	Not Applicable	Circulation or storage space.
B00L - R0029 - Tiered Learning Area - (8.2 SQM)	● Student Space (3)	
B00L - R0030 - Movement Studio - (83.59 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Science Laboratory - (101.01 SQM)	● Student Space (46)	
B00L - R1002 - General Learning Space - (60.51 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R1003 - General Learning Space - (62.58 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R1004 - General Learning Space - (60.9 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R1005 - Seminar - (35.8 SQM)	● Office (8)	
B00L - R1007 - Collaboration Space - (89.01 SQM)	● Student Space (41)	
B00L - R1008 - Preparation - (37.21 SQM)	Not Applicable	Circulation or storage space.
B00L - R1010 - Science Laboratory - (99.12 SQM)	● Student Space (45)	
B00L - R1011 - General Learning Space - (61.13 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R1012 - General Learning Space - (61.03 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R1016 - Movement - (34.24 SQM)	Not Applicable	Circulation or storage space.
B00L - R1024 - Movement - (6.64 SQM)	Not Applicable	Circulation or storage space.
B00L - R1028 - Movement - (154.95 SQM)	Not Applicable	Circulation or storage space.
B00L - R1029 - Movement - (14.69 SQM)	Not Applicable	Circulation or storage space.
OS 600 10916 - OS 600 10916 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 13279 - OS 600 13279 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 13408 - OS 600 13408 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 13447 - OS 600 13447 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 13997 - OS 600 13997 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 14741 - OS 600 14741 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 16234 - OS 600 16234 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 18071 - OS 600 18071 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 10486 - OS 601 10486 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12161 - OS 601 12161 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13476 - OS 601 13476 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15493 - OS 601 15493 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	