

VENTILATION AUDIT REPORT

SCHOOL:	Canobolas Public School (1495)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Orange
LOCAL GOVERNMENT AREA:	Orange

1495 - Canobolas Public School
Site Plan (11136)





















1:690

Printed: 14-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Reading Area - (37.07 SQM)	 Student Space (17)	
B00A - R0006 - Reading Area - (35.16 SQM)	 Student Space (16)	
B00C - R0002 - Clerical Office/Workroom - (29.17 SQM)	 Office (7)	
B00C - R0007 - Interview - (10.73 SQM)	 Office (2)	
B00C - R0008 - Principal - (10.63 SQM)	 Office (2)	
B00C - R0009 - Staff Room - (10.69 SQM)	 Office (2)	
B00C - R0010 - Staff Kitchen - (10.5 SQM)	 Office (2)	
B00C - R0014 - Sick Bay - (7.47 SQM)	 Student Space (3)	
B00E - R0002 - Practical Activities - 1hb - (19.37 SQM)	 Student Space (8)	
B00E - R0004 - Home Base - (58.8 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	 Student Space (4)	
B00E - R0006 - Home Base - (58.71 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0008 - Practical Activities - 1hb - (19.37 SQM)	 Student Space (8)	
B00F - R0002 - Reading Area - (92.78 SQM)	 Student Space (43)	
B00H - R0001 - Home Base - (60.83 SQM) - Teaching Space: 1	 Student Space (28)	
OS 531 16086 - OS 531 16086 - Library - (76 SQM)	 Student Space (35)	
OS 603 11458 - OS 603 11458 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 12672 - OS 603 12672 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	