


VENTILATION AUDIT REPORT

SCHOOL:	Canobolas Rural Technology High School (8444)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Orange
LOCAL GOVERNMENT AREA:	Orange

8444 - Canobolas Rural Technology High School
Site Plan (10923)



1:1,786

Printed: 11-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Computer Learning Space - (58.84 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0005 - General Learning Space - (52.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0016 - Interview/Office - Type 1 - (13.03 SQM)	○ Office (3)	
B00A - R0017 - Duplicating Workroom - (18.84 SQM)	○ Office (4)	
B00A - R0020 - Duplicating Workroom - (31.62 SQM)	○ Office (7)	
B00A - R0021 - Interview/Office - Type 1 - (12.68 SQM)	○ Office (3)	
B00A - R0025 - Public Entry - (47.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Principal Office - (18.83 SQM)	○ Office (4)	
B00A - R0034 - Clinic - Girls - (13.81 SQM)	○ Office (3)	
B00A - R0035 - Movement - (8.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Clinic - Boys - (5.88 SQM)	○ Office (1)	
B00A - R0037 - Staff Study - (11.59 SQM)	○ Office (2)	
B00A - R0038 - Administration - Clerical - (48.76 SQM)	○ Office (12)	
B00A - R0039 - Administration - Clerical - (9.66 SQM)	○ Office (2)	
B00A - R0040 - Staff Study - (24 SQM)	○ Office (6)	
B00A - R0041 - Movement - (156.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Seminar - (31.54 SQM)	○ Office (7)	
B00A - R0047 - Food Technology L.S. - (85.97 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R0048 - Preparation - Materials - (16.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0050 - Food/Research Space - (12.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - Food Technology L.S. - (86.24 SQM) - Teaching Space: 1	● Student Space (40)	
B00A - R1004 - General Learning Space - (52.95 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1014 - General Learning Space - (52.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1015 - Seminar - (15.49 SQM)	○ Office (3)	
B00A - R1016 - Seminar - (15.49 SQM)	○ Office (3)	
B00A - R1027 - Commonroom - (159.68 SQM)	○ Office (39)	
B00A - R1028 - Movement - (114.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R1030 - Movement - (15.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R1035 - Main Area - (315.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Music Learning Space - (52.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0012 - Materials Technology L.S. - (84.73 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R0015 - Materials Technology L.S. - (92.04 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R0016 - General Learning Space - (58.44 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0023 - Staff Study - (31.41 SQM)	○ Office (7)	
B00B - R0024 - Darkroom Space - (25.94 SQM)	○ Office (6)	
B00B - R0028 - Movement - (174.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R0032 - Materials Workshop - Type 2 - (166.49 SQM)	● Student Space (77)	
B00B - R0035 - Welding Area - (7.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Wood Technology Bay - (79.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0042 - Wood Technology L.S. - (78.48 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0049 - Wood Technology Bay - (54.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R0050 - Practical Activities - (58.48 SQM)	● Student Space (27)	
B00B - R1001 - Art Learning Space - (71.58 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R1004 - Music Learning Space - (52.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1007 - Materials Technology L.S. - (85.31 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R1010 - Materials Technology L.S. - (79.26 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R1012 - Computer Learning Space - (51.15 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1015 - Art Learning Space - (52.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1018 - Staff Study - (31.78 SQM)	○ Office (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1022 - Art Learning Space - (52.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1023 - Art Learning Space - (52.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1026 - Movement - (176.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R1029 - General Learning Space - (52.88 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0003 - Movement - (10.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Student Canteen - (57.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (25.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (10.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (315.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (13.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Movement - (10.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - General Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0009 - General Learning Space - (58.37 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0017 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0026 - Movement - (174.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Staff Study - (25.93 SQM)	● Office (6)	
B00D - R0029 - Seminar - Type 3 - (11.09 SQM)	● Office (2)	
B00D - R0030 - General Learning Space - S/P - (58.89 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0031 - Practical Activity Area - (29.88 SQM)	● Student Space (13)	
B00D - R0035 - General Learning Space - S/P - (55.81 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0037 - Seminar - Type 3 - (11.39 SQM)	● Office (2)	
B00D - R0038 - Movement - (12.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0042 - Movement Studio - (114.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R0043 - General Learning Space - (65.91 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1001 - General Learning Space - (58.44 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1004 - Computer Learning Space - (52.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1006 - Staff Study - (13.33 SQM)	● Office (3)	
B00D - R1008 - General Learning Space - (53.33 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1009 - General Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1011 - Staff Study - (25.56 SQM)	● Office (6)	
B00D - R1013 - General Learning Space - (58.08 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1016 - General Learning Space - (52.95 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1018 - General Learning Space - (58.07 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1019 - General Learning Space - (52.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1020 - Study Space - (25.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R1021 - Interview/Office - Type 1 - (12.61 SQM)	● Office (3)	
B00D - R1022 - Interview/Office - Type 1 - (12.97 SQM)	● Office (3)	
B00D - R1023 - Staff Study - (25.93 SQM)	● Office (6)	
B00D - R1026 - Movement - (169.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R1029 - General Learning Space - (44.31 SQM) - Teaching Space: 1	● Student Space (20)	
B00D - R1030 - Kitchen - Type 1 - (13.72 SQM)	● Student Space (6)	
B00E - R0001 - Laboratory L.S. - (86.41 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R0007 - General Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0008 - Laboratory L.S. - (86.19 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0009 - Preparation - (22.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Laboratory L.S. - (92.41 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0013 - General Assistants - (32.87 SQM)	● Office (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0018 - General Learning Space - (51.49 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0020 - Laboratory L.S. - (92.55 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0027 - Movement - (156.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0033 - Preparation - Science - (35.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0034 - Movement - (15.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Staff Study - (58.8 SQM)	○ Office (14)	
B00E - R1005 - Computer Learning Space - (51.35 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1007 - Interview/Office - Type 1 - (12.97 SQM)	○ Office (3)	
B00E - R1008 - General Learning Space - (59.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1009 - Study Space - (26.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R1010 - General Learning Space - (52.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1011 - General Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1012 - General Learning Space - (59.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1016 - General Learning Space - (51.13 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1020 - General Learning Space - (58.44 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1023 - General Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1024 - Movement - (5.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R1028 - Movement - (168.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R1031 - Staff Study - (39 SQM)	○ Office (9)	
B00F - R0006 - Movement - (43.59 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (15.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (5.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Stage - (71.25 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Staff Kitchen - (15.13 SQM)	○ Office (3)	
B00F - R0017 - Staff Study - (12.36 SQM)	○ Office (3)	
B00F - R0019 - Multi-Purpose Space - (508.91 SQM)	● Student Space (236)	
B00H - R0001 - General Learning Space - (37.39 SQM) - Teaching Space: 1	● Student Space (17)	
B00H - R0004 - Commonroom - (8.19 SQM)	○ Office (2)	
B00H - R0009 - Staff Study - (9.2 SQM)	○ Office (2)	
B00I - R0001 - Movement - (40.72 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Seminar - Type 1 - (43.85 SQM)	○ Office (10)	
B00I - R0004 - Interview/Office - Type 1 - (10.62 SQM)	○ Office (2)	
B00I - R0006 - Movement - (8.66 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Gymnasium - (241.66 SQM)	● Student Space (112)	