

VENTILATION AUDIT REPORT

SCHOOL:	Canterbury Boys High School (8107)
AMU REGION:	Sydney
STATE ELECTORATE:	Canterbury
LOCAL GOVERNMENT AREA:	Inner West

8107 - Canterbury Boys High School
Site Plan (10268)



1:1,046

Printed: 11-Jul-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (51.64 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0004 - General Learning Space - (37.77 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R0005 - General Learning Space - (54.57 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0006 - General Learning Space - (54.55 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0007 - General Learning Space - (49.5 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0008 - General Learning Space - (49.29 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0010 - Duplicating Workroom - (33.58 SQM)	Office (8)	
B00A - R0013 - Administration - Clerical - (37.65 SQM)	Office (9)	
B00A - R0023 - Leading Teacher - (14.38 SQM)	Office (3)	
B00A - R0024 - Clinic - Boys - (12.11 SQM)	Office (3)	
B00A - R0025 - Deputy Principal Office - (22.27 SQM)	Office (5)	
B00A - R0027 - Principal Office - (24.54 SQM)	Office (6)	
B00A - R0028 - Interview/Office - Type 1 - (14.16 SQM)	Office (3)	
B00A - R0030 - Staff Study - (35.56 SQM)	Office (8)	
B00A - R0031 - Staff Study - (30.69 SQM)	Office (7)	
B00A - R0032 - Interview/Office - Type 1 - (17.07 SQM)	Office (4)	
B00A - R0033 - Interview/Office - Type 1 - (14.27 SQM)	Office (3)	
B00A - R0036 - Interview/Office - Type 1 - (8.4 SQM)	Office (2)	
B00A - R0038 - Movement - (14.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Movement - (58.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Movement - (16.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Staff Kitchen - (6.52 SQM)	Office (1)	
B00A - R0047 - Commonroom - (90.66 SQM)	Office (22)	
B00A - R0049 - Movement - (60.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - Movement - (12.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Staff Study - (22.57 SQM)	Office (5)	
B00A - R0056 - Student Reception - (13.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0059 - Public Entry - (24.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0060 - Public Reception - (14.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - Movement - (20.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0064 - Ancillary Staff - (8.17 SQM)	Office (2)	
B00A - R0065 - Movement - (150.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0066 - Movement - (8.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0069 - General Learning Space - (52.6 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0072 - Movement - (12.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0073 - Student Waiting - (17.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (53.25 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1002 - Computer Learning Space - (59.6 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1003 - Senior Study - (16.76 SQM)	Office (4)	
B00A - R1004 - Senior Study - (16.72 SQM)	Office (4)	
B00A - R1005 - Computer Learning Space - (55.66 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1007 - Computer Learning Space - (56.12 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1008 - Interview/Office - Type 1 - (16.46 SQM)	Office (4)	
B00A - R1011 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Main Area - (342.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Seminar - (10.36 SQM)	Office (2)	
B00A - R1014 - Seminar - (10.39 SQM)	Office (2)	
B00A - R1016 - Audio Visual Workroom - (39.2 SQM)	Student Space (18)	
B00A - R1017 - Seminar - (25.15 SQM)	Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1020 - General Learning Space - (38.81 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1024 - General Learning Space - (36 SQM) - Teaching Space: 1	Student Space (16)	
B00A - R1025 - General Learning Space - (52.83 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1028 - General Learning Space - (46.93 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1032 - Staff Study - (45.44 SQM)	Office (11)	
B00A - R1036 - Movement - (106.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R1039 - General Learning Space - (56.02 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1040 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R1042 - Workroom - (28.98 SQM)	Office (7)	
B00A - R1043 - Staff Kitchen - (5.72 SQM)	Office (1)	
B00A - R1046 - Movement - (95.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R1047 - Movement - (5.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R9001 - Darkroom Space - (19.15 SQM)	Office (4)	
B00A - R9002 - Darkroom Space - (14.11 SQM)	Office (3)	
B00A - R9009 - General Assistants - (10.06 SQM)	Office (2)	
B00A - R9012 - General Assistants - (16.07 SQM)	Office (4)	
B00A - R9013 - Workshop - (54.16 SQM)	Student Space (25)	
B00A - R9019 - Movement - (82.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R9021 - Movement - (38.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Tiered Learning Area - (66.58 SQM)	Student Space (30)	
B00B - R0003 - General Learning Space - (39.26 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R0007 - General Learning Space - (48.76 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0008 - Movement - (12.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (67.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (79.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Interview/Office - Type 1 - (9.49 SQM)	Office (2)	
B00B - R1003 - General Learning Space - (49.18 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1005 - Staff Study - (24.4 SQM)	Office (6)	
B00B - R1006 - General Learning Space - (39.1 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R1009 - General Learning Space - (49.17 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1010 - Interview/Office - Type 1 - (12.59 SQM)	Office (3)	
B00C - R0001 - Gymnasium - (349.36 SQM)	Student Space (162)	
B00C - R0003 - Movement - (8.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Staff Study - (5.79 SQM)	Office (1)	
B00D - R0004 - Student Canteen - (61.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Commonroom - (25.84 SQM)	Office (6)	
B00D - R0009 - Interview/Office - Type 1 - (25.46 SQM)	Office (6)	
B00D - R0012 - Laboratory L.S. - (93.06 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R0013 - Preparation - (28.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Preparation - (9.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Food Technology L.S. - (93.17 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R0016 - Movement - (15.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Materials Technology L.S. - (79.18 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0028 - Movement - (7.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R0034 - Staff Kitchen - (12.15 SQM)	Office (3)	
B00D - R0035 - Staff Study - (26.02 SQM)	Office (6)	
B00D - R0036 - Materials Technology L.S. - (97.76 SQM) - Teaching Space: 1	Student Space (45)	
B00D - R0038 - Interview/Meeting - (12.96 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1001 - Staff Study - (53.88 SQM)	Office (13)	
B00D - R1002 - Art Learning Space - (133.22 SQM) - Teaching Space: 1	Student Space (61)	
B00D - R1009 - Laboratory L.S. - (92.28 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R1010 - Preparation - (28.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R1011 - Preparation - (9.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R1012 - Laboratory L.S. - (92.8 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R1013 - Movement - (14.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R1017 - Staff Study - (26.16 SQM)	Office (6)	
B00D - R1019 - Art Learning Space - (52.02 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1021 - Art Learning Space - (52.77 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1023 - Art Learning Space - (60.1 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R2003 - General Learning Space - (53.95 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R2004 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R2007 - Computer Learning Space - (52.71 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R2008 - Staff Study - (25.95 SQM)	Office (6)	
B00D - R2013 - Laboratory L.S. - (92.88 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R2014 - Preparation - (10.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R2015 - Preparation - (28.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R2016 - Movement - (5.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R2017 - Laboratory L.S. - (93.19 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R2021 - Design L.S. - (52.78 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R2024 - Design L.S. - (52.7 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R2029 - Staff Study - (14.78 SQM)	Office (3)	
B00D - R2032 - Music Learning Space - (121.89 SQM) - Teaching Space: 1	Student Space (56)	
B00D - R9009 - Staff Study - (11.93 SQM)	Office (2)	
B00D - R9016 - Materials Technology L.S. - (99.39 SQM)	Student Space (46)	
B00D - R9021 - Special Learning Space - (53.49 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R9023 - Independent Learning Space - (12.04 SQM) - Teaching Space: 1	Student Space (5)	
B00D - R9025 - Special Learning Space - (53.57 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R9026 - Special Learning Space - (52.27 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R9030 - Staff Kitchen - (6.05 SQM)	Office (1)	
B00D - R9031 - Staff Study - (43.81 SQM)	Office (10)	