

VENTILATION AUDIT REPORT

SCHOOL:	Canterbury Vale School (5759)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Lakemba
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

5759 - Canterbury Vale School
Site Plan (11662)
















1:1,386

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (58.43 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R0006 - Home Base - (58.43 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R0007 - Movement - (34.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Staff Room - (23.05 SQM)	 Office (5)	
B00B - R0002 - Staff Room Annexe - (13.78 SQM)	 Office (3)	
B00B - R0003 - Movement - (20.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Sick Bay - (6.64 SQM)	 Student Space (3)	
B00B - R0007 - Clerical Office - (17.44 SQM)	 Office (4)	
B00B - R0008 - Entry Vestibule - (11.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Interview - (12.82 SQM)	 Office (3)	
B00B - R0010 - Principal - (12.82 SQM)	 Office (3)	
B00B - R0013 - Movement - (34.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Home Base - (56.89 SQM) - Teaching Space: 1	 Student Space (26)	
B00C - R0005 - Home Base - (60.42 SQM) - Teaching Space: 1	 Student Space (28)	
B00C - R0007 - Movement - (35.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Communal Space - (60.51 SQM)	 Student Space (28)	
B00F - R0001 - Wood Technology Bay - (28.55 SQM)	Not Applicable	Circulation or storage space.
OS 501 12025 - OS 501 12025 - Admin Staff/Principal/Deputy/Dup/Clinic - (209 SQM)	 Office (52)	
OS 751 11900 - OS 751 11900 - Learning Unit - ESL - (76 SQM)	 Student Space (35)	