

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Cardiff High School (8903)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Charlestown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

8903 - Cardiff High School  
Site Plan (10272)



1:1,893

Printed: 04-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Music Learning Space - (53.33 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0005 - Music Learning Space - (64.57 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0006 - General Learning Space - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0007 - General Learning Space - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0008 - General Learning Space - (53.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0009 - Movement - (31.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - General Learning Space - (53.4 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0011 - General Learning Space - (53.4 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0012 - Staff Study - (13.97 SQM)	● Office (3)	
B00A - R0013 - Staff Study - (52.97 SQM)	● Office (13)	
B00A - R0015 - Staff Study - (26.28 SQM)	● Office (6)	
B00A - R0019 - Darkroom Space - (12.49 SQM)	● Office (3)	
B00A - R0020 - Art Learning Space - (72.73 SQM) - Teaching Space: 1	● Student Space (33)	
B00A - R0024 - Art Learning Space - (63.3 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0025 - Art Learning Space - (53.48 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0026 - Staff Study - (26.3 SQM)	● Office (6)	
B00A - R0027 - Movement - (63.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (145.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Movement - (66.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - General Learning Space - (53.41 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1005 - General Learning Space - (53.41 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1006 - General Learning Space - (67.27 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1007 - General Learning Space - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1008 - General Learning Space - (53.77 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1009 - General Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1010 - General Learning Space - (53.03 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1011 - Staff Study - (14.26 SQM)	● Office (3)	
B00A - R1012 - General Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1013 - Staff Study - (35.22 SQM)	● Office (8)	
B00A - R1018 - Computer Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1019 - Computer Learning Space - (52.35 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1021 - Staff Study - (47.76 SQM)	● Office (11)	
B00A - R1023 - Movement - (198.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R1026 - Computer Room - (86.12 SQM)	● Student Space (39)	
B00A - R1027 - Staff Kitchen - (6.2 SQM)	● Office (1)	
B00A - R1030 - Movement - (206.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R9001 - Movement - (20.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R9005 - Movement - (46.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R9006 - General Learning Space - (52.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R9007 - General Learning Space - (52.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R9008 - Staff Study - (13.16 SQM)	● Office (3)	
B00A - R9009 - General Learning Space - (51.66 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R9011 - Staff Study - (26.01 SQM)	● Office (6)	
B00A - R9016 - Seminar/Technology Space - (12.08 SQM)	● Office (3)	
B00A - R9017 - Food Technology L.S. - (92.08 SQM) - Teaching Space: 1	● Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R9019 - Food Technology L.S. - (66.11 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R9023 - Materials Technology L.S. - (64.83 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R9024 - Movement - (205.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R9032 - Movement - (207.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Ancillary Staff - (21.76 SQM)	● Office (5)	
B00B - R0002 - Principal Office - (18.76 SQM)	● Office (4)	
B00B - R0021 - Public Reception - (24.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Student Reception - (24.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Deputy Principal Office - (12.56 SQM)	● Office (3)	
B00B - R0026 - Student Waiting - (12.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Deputy Principal Office - (13.02 SQM)	● Office (3)	
B00B - R0028 - Interview/Meeting - (35.12 SQM)	● Office (8)	
B00B - R0029 - Interview/Meeting - (11.7 SQM)	● Office (2)	
B00B - R0030 - Staff Study - (13.95 SQM)	● Office (3)	
B00B - R0032 - Movement - (57.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Clinic - (13.7 SQM)	● Office (3)	
B00B - R0035 - Staff Kitchen - (8.19 SQM)	● Office (2)	
B00B - R0036 - Staff Lounge - (11.86 SQM)	● Office (2)	
B00B - R0037 - Administration - Clerical - (67.9 SQM)	● Office (16)	
B00B - R0038 - Principal Office - (19.92 SQM)	● Office (4)	
B00B - R0039 - Interview/Meeting - (12.61 SQM)	● Office (3)	
B00C - R0009 - Student Canteen - (48.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Practical Activities - (172.88 SQM)	● Student Space (80)	
B00D - R0001 - Seminar - (21.09 SQM)	● Office (5)	
B00D - R0002 - Seminar - (13.11 SQM)	● Office (3)	
B00D - R0008 - Entry - (16.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Workroom - (40.47 SQM)	● Office (10)	
B00D - R0011 - Audio Visual Workroom - (35.3 SQM)	● Student Space (16)	
B00D - R0015 - Main Area - (412.63 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (10.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (8.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (95.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Laboratory L.S. - (86.02 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0007 - Preparation - (39.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Laboratory L.S. - (86.01 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0011 - Senior Study - (52.97 SQM)	● Office (13)	
B00E - R0013 - Movement - (25.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Staff Study - (32.95 SQM)	● Office (8)	
B00E - R0018 - Staff Kitchen - (5.6 SQM)	● Office (1)	
B00E - R0020 - Study Space - (11.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (9.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Movement - (12.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Movement - (89.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R1005 - Laboratory L.S. - (88.16 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R1006 - Preparation - (38.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R1007 - Laboratory L.S. - (85.87 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R1011 - Movement - (16.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R1012 - Staff Study - (12.01 SQM)	● Office (3)	
B00E - R1013 - Movement - (7.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R1015 - Staff Study - (34.5 SQM)	● Office (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1018 - Staff Lounge - (107.23 SQM)	Office (26)	
B00F - R0001 - General Learning Space - (65.72 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0002 - Movement - (52.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Staff Study - (25.86 SQM)	Office (6)	
B00F - R0009 - Design L.S. - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0010 - Welding Area - (9.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Seminar/Technology Space - (10.55 SQM)	Office (2)	
B00F - R0012 - Materials Technology L.S. - (72.07 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0014 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Design L.S. - (59.23 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R1004 - Movement - (7.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R1005 - Movement - (48.4 SQM)	Not Applicable	Circulation or storage space.
B00F - R1006 - Materials Technology L.S. - (79.04 SQM) - Teaching Space: 1	Student Space (36)	
B00F - R1009 - Materials Technology L.S. - (83.41 SQM) - Teaching Space: 1	Student Space (38)	
B00G - R0001 - Performance Workspace - (73.75 SQM) - Teaching Space: 1	Student Space (34)	
B00G - R0003 - Movement - (5.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Movement - (6.85 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Staff Kitchen - (20.48 SQM)	Office (5)	
B00G - R1003 - Multi-Purpose Space - (388.76 SQM)	Student Space (180)	
B00G - R1004 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00G - R1005 - Stage - (99.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R1006 - Movement - (8.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R1007 - Movement - (46.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R1012 - Movement - (32.68 SQM)	Not Applicable	Circulation or storage space.
B00G - R1014 - Movement - (77.95 SQM)	Not Applicable	Circulation or storage space.
B00G - R9003 - General Assistants - (13.01 SQM)	Office (3)	
OS 522 14805 - OS 522 14805 - Staff Study - (38 SQM)	Office (9)	
OS 600 15268 - OS 600 15268 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 14789 - OS 601 14789 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 15320 - OS 601 15320 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 19728 - OS 601 19728 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 19733 - OS 601 19733 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 621 10728 - OS 621 10728 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	
OS 621 19538 - OS 621 19538 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	