

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Carenne School (5610)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Bathurst</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Bathurst</b>

5610 - Carenne School  
Site Plan (12219)












1:1,502

Printed: 08-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal - (18.52 SQM)	Office (4)	
B00A - R0002 - Entry Vestibule - (10.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office - (9.78 SQM)	Office (2)	
B00A - R0005 - Interview - (11.27 SQM)	Office (2)	
B00A - R0011 - Movement - (28.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Staff Room - (38.55 SQM)	Office (9)	
B00A - R0015 - Deputy Principal - (12.4 SQM)	Office (3)	
B00A - R0016 - Interview - (12.36 SQM)	Office (3)	
B00A - R0017 - Duplicating Workroom - (12.36 SQM)	Office (3)	
B00A - R0019 - Movement - (7.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (54.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Communal Space - (80.29 SQM)	Student Space (37)	
B00A - R0026 - Movement - (29.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Canteen - (11.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (129.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Practical Activities - 1hb - (18.31 SQM)	Student Space (8)	
B00A - R0041 - Home Base - (50.05 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0043 - Home Base - (50.91 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0044 - Practical Activities - 1hb - (18.09 SQM)	Student Space (8)	
B00A - R0045 - Movement - (7.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0050 - Movement - (9.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0060 - Reading Area - (90.15 SQM)	Student Space (41)	
B00A - R0061 - Practical Activities - S - 1hb - (31.72 SQM)	Student Space (14)	
B00A - R0062 - Home Base - P - (50.61 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0001 - Movement - (101.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Staff Room Annexe - (10.36 SQM)	Office (2)	
B00B - R0005 - General Learning Space - (38.25 SQM) - Teaching Space: 1	Student Space (17)	
B00B - R0006 - Practical Activities - 1hb - (15.07 SQM)	Student Space (6)	
B00B - R0007 - Withdrawal Space - 1hb - (22.1 SQM)	Student Space (10)	
B00B - R0015 - General Learning Space - (46.45 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0016 - Practical Activities - 1hb - (19.59 SQM)	Student Space (9)	
B00B - R0017 - Home Base - (46.02 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0001 - Home Base - M - (57.87 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0002 - Withdrawal - M - (8.91 SQM)	Student Space (4)	
B00E - R0004 - Practical Activities - M - 2hb - (37.9 SQM)	Student Space (17)	
B00E - R0008 - Home Base - M - (57.66 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0009 - Withdrawal - M - (8.97 SQM)	Student Space (4)	
B00E - R0011 - Home Base - M - (57.67 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0012 - Withdrawal - M - (8.95 SQM)	Student Space (4)	
B00E - R0014 - Practical Activities - M - 2hb - (38.02 SQM)	Student Space (17)	
B00E - R0018 - Home Base - M - (57.89 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0019 - Withdrawal - M - (9.1 SQM)	Student Space (4)	
B00E - R0020 - Withdrawal - M - (5.81 SQM)	Student Space (2)	
BOA1 - R0001 - Staff Kitchen - (39.65 SQM)	Office (9)	
BOA1 - R0005 - Entry Vestibule - (20.26 SQM)	Not Applicable	Circulation or storage space.
BOA1 - R0006 - Clerical Office - (28.88 SQM)	Office (7)	
BOA1 - R0007 - Home Base - (49.79 SQM) - Teaching Space: 1	Student Space (23)	
BOA1 - R0009 - Withdrawal Space - 2hb - (11.87 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOA1 - R0010 - Home Base - (49.79 SQM) - Teaching Space: 1	 Student Space (23)	
BOA1 - R0014 - Movement - (13.88 SQM)	Not Applicable	Circulation or storage space.
BOA1 - R0015 - Sick Bay - (5.46 SQM)	 Student Space (2)	
BOA1 - R0016 - Deputy Principal - (8.29 SQM)	 Office (2)	
BOA1 - R0018 - Principal - (11.29 SQM)	 Office (2)	
BOA1 - R0020 - Movement - (75.93 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0002 - Outdoor Learning Area - (8.82 SQM)	Not Applicable	Circulation or storage space.
NS 120 13782 - NS 120 13782 - Learning Unit Primary Single - PWD - (76 SQM)	 Student Space (35)	
OS 531 13777 - OS 531 13777 - Library - (76 SQM)	 Student Space (35)	
OS 601 13778 - OS 601 13778 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13779 - OS 601 13779 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 12135 - OS 602 12135 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	