

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Caringbah High School (8240)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Cronulla</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

8240 - Caringbah High School  
Site Plan (12222)



1:1,488

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Laboratory L.S. - (108.83 SQM) - Teaching Space: 1	Student Space (50)	
B00A - R0012 - Seminar - (23.42 SQM)	Office (5)	
B00A - R1013 - Interview/Meeting - (19.14 SQM)	Office (4)	
B00A - R1014 - Interview/Meeting - (17.18 SQM)	Office (4)	
B00A - R1015 - Staff Lounge - (109.22 SQM)	Office (27)	
B00B - R0001 - Laboratory L.S. - (93.89 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0006 - Laboratory L.S. - (92.37 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0008 - Preparation - (28.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - General Learning Space - (53.88 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1013 - Staff Study - (201.03 SQM)	Office (50)	
B00C - R0001 - General Assistants - (10.22 SQM)	Office (2)	
B00C - R0006 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0009 - Laboratory L.S. - (92.34 SQM) - Teaching Space: 1	Student Space (42)	
B00C - R0017 - Preparation - (25.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (5.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Staff Study - (32.38 SQM)	Office (8)	
B00C - R1014 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1015 - Staff Study - (160.82 SQM)	Office (40)	
B00C - R1017 - Movement - (5.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R1019 - Staff Study - (16.54 SQM)	Office (4)	
B00D - R0020 - General Learning Space - (52.34 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0023 - Laboratory L.S. - (103.89 SQM) - Teaching Space: 1	Student Space (48)	
B00D - R0024 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1016 - Art Learning Space - (66.01 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1019 - Art Learning Space - (79.39 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R1021 - Dark Room - (24.34 SQM)	Office (6)	
B00D - R1023 - Art Learning Space - (59.88 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0010 - Deputy Principal Office - (25.33 SQM)	Office (6)	
B00E - R0011 - Staff Study - (25.85 SQM)	Office (6)	
B00E - R0012 - General Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0013 - General Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0014 - General Learning Space - (54.03 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0017 - General Learning Space - (53 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0018 - General Learning Space - (52.34 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1002 - General Learning Space - (53.89 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R1003 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1004 - General Learning Space - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1008 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1009 - Staff Study - (25.92 SQM)	Office (6)	
B00E - R1010 - General Learning Space - (53.96 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R0002 - Movement - (53.96 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - General Learning Space - (53.8 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0014 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0015 - General Learning Space - (52.71 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0016 - General Learning Space - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1006 - Movement - (53.3 SQM)	Not Applicable	Circulation or storage space.
B00F - R1012 - General Learning Space - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1013 - General Learning Space - (52.34 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1014 - General Learning Space - (52.34 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1015 - Computer Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0019 - Computer Learning Space - (60.34 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0020 - Performance Workshop - (103.52 SQM)	Student Space (48)	
B00G - R0021 - General Learning Space - (60.27 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0022 - Practice/Seminar - (22.09 SQM)	Not Applicable	Circulation or storage space.
B00G - R0029 - Student Canteen - (62.08 SQM)	Not Applicable	Circulation or storage space.
B00G - R0036 - Movement - (103.38 SQM)	Not Applicable	Circulation or storage space.
B00G - R1013 - Movement - (7.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R1016 - Seminar - Type 1 - (24.92 SQM)	Office (6)	
B00G - R1017 - General Learning Space - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R1018 - General Learning Space - (51.92 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R1021 - Movement - (7.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R1023 - Movement - (69.68 SQM)	Not Applicable	Circulation or storage space.
B00G - R1025 - Computer Learning Space - (60.34 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R1026 - Fitness Laboratory - (99.18 SQM)	Student Space (46)	
B00G - R1027 - General Learning Space - (60.27 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0002 - Senior Study - (69.52 SQM)	Office (17)	
B00M - R0003 - Seminar - (12.67 SQM)	Office (3)	
B00M - R0007 - Entry - (52.72 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Main Area - (431.3 SQM)	Not Applicable	Circulation or storage space.
B00M - R0010 - Workroom - (45.47 SQM)	Office (11)	
B00M - R0011 - Audio Visual Workroom - (30.35 SQM)	Student Space (14)	
B00M - R0013 - Seminar - (12.65 SQM)	Office (3)	
B00M - R0014 - Seminar - (12.73 SQM)	Office (3)	
B00M - R0015 - Seminar - (12.73 SQM)	Office (3)	
B00N - R0001 - Clinic - Boys - (13.5 SQM)	Office (3)	
B00N - R0002 - Movement - (6.52 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Principal Office - (19.76 SQM)	Office (4)	
B00N - R0010 - Clinic - Girls - (12.91 SQM)	Office (3)	
B00N - R0011 - Deputy Principal Office - (13.93 SQM)	Office (3)	
B00N - R0012 - Student Reception - (47.13 SQM)	Not Applicable	Circulation or storage space.
B00N - R0013 - Movement - (15.85 SQM)	Not Applicable	Circulation or storage space.
B00N - R0014 - Administration - Clerical - (98.02 SQM)	Office (24)	
B00N - R0016 - Staff Kitchen - (5.02 SQM)	Office (1)	
B00N - R0019 - Interview/Meeting - (13.15 SQM)	Office (3)	
B00N - R0020 - Interview/Meeting - (13.15 SQM)	Office (3)	
B00N - R0021 - Deputy Principal Office - (13.5 SQM)	Office (3)	
B00N - R0026 - Interview/Meeting - (11.97 SQM)	Office (2)	
B00N - R0029 - Public Reception - (22.34 SQM)	Not Applicable	Circulation or storage space.
B00N - R0030 - Visitors Office - (13.12 SQM)	Office (3)	
B00N - R0031 - Movement - (20.4 SQM)	Not Applicable	Circulation or storage space.
B00N - R1001 - General Learning Space - (62.62 SQM) - Teaching Space: 1	Student Space (29)	
B00N - R1003 - Shared Study Space - (114.33 SQM)	Office (28)	
B00N - R1004 - General Learning Space - (58.37 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R1006 - General Learning Space - (62.53 SQM) - Teaching Space: 1	Student Space (29)	
B00N - R1007 - General Learning Space - (62.53 SQM) - Teaching Space: 1	Student Space (29)	
B00N - R1008 - General Learning Space - (62.25 SQM) - Teaching Space: 1	Student Space (28)	
B00S - R0002 - Movement - (51.2 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00S - R0003 - Stage - (97.05 SQM)	Not Applicable	Circulation or storage space.
B00S - R0004 - Movement - (14.93 SQM)	Not Applicable	Circulation or storage space.
B00S - R0006 - Gymnasium - (618.97 SQM)	● Student Space (287)	
B00T - R0001 - Movement - (99.97 SQM)	Not Applicable	Circulation or storage space.
B00T - R0003 - Materials Workshop - Type 2 - (83.39 SQM)	● Student Space (38)	
B00T - R0004 - General Learning Space - Type 9 - (60.69 SQM) - Teaching Space: 1	● Student Space (28)	
B00T - R0005 - Movement - (29.37 SQM)	Not Applicable	Circulation or storage space.
B00T - R0006 - Computer Learning Space - (61.39 SQM) - Teaching Space: 1	● Student Space (28)	
B00T - R0007 - General Learning Space - Type 8 - (62.3 SQM) - Teaching Space: 1	● Student Space (28)	
B00T - R0012 - Materials Workshop - Type 2 - (119.72 SQM)	● Student Space (55)	
B00T - R0014 - Materials Workshop - Type 2 - (120.9 SQM)	● Student Space (56)	
B00T - R0017 - Outdoor Workshop - (84.78 SQM)	Not Applicable	Circulation or storage space.
B00T - R0019 - Welding/Hot Metals Area - (13.4 SQM)	Not Applicable	Circulation or storage space.
B00T - R1001 - Movement - (107.91 SQM)	Not Applicable	Circulation or storage space.
B00T - R1002 - Computer Learning Space - (64.44 SQM) - Teaching Space: 1	● Student Space (29)	
B00T - R1003 - General Learning Space - Type 7 - (63.69 SQM) - Teaching Space: 1	● Student Space (29)	
B00T - R1004 - Seminar - Type 2 - (27.66 SQM)	○ Office (6)	
B00T - R1005 - Movement - (21.85 SQM)	Not Applicable	Circulation or storage space.
B00T - R1006 - General Learning Space - Type 7 - (64.25 SQM) - Teaching Space: 1	● Student Space (29)	
B00T - R1007 - General Learning Space - Type 7 - (63.71 SQM) - Teaching Space: 1	● Student Space (29)	
B00T - R1009 - Kitchen - Type 1 - (117.87 SQM)	● Student Space (54)	
B00T - R1010 - Preparation - Materials - (20.74 SQM)	Not Applicable	Circulation or storage space.
B00T - R1013 - Kitchen - Type 1 - (117.94 SQM)	● Student Space (54)	
B00U - R0001 - Movement Studio - (128.14 SQM)	Not Applicable	Circulation or storage space.
B00U - R0002 - General Learning Space - Type 1 - (60.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00U - R0007 - Stage - (32.86 SQM)	Not Applicable	Circulation or storage space.
B00U - R0010 - Movement - (7.28 SQM)	Not Applicable	Circulation or storage space.
B00U - R0011 - Seminar - Type 1 - (27.25 SQM)	○ Office (6)	