

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Caringbah North Public School (3972)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Cronulla</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>









3972 - Caringbah North Public School  
Site Plan (12223)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0004 - Movement - (34.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0006 - Home Base - (53.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0011 - Home Base - (53.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0016 - Home Base - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0018 - Principal - (18.72 SQM)	● Office (4)	
B00A - R0024 - Clerical Office/Workroom - (21.73 SQM)	● Office (5)	
B00A - R0026 - Movement - (43.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Duplicating Workroom - (11.39 SQM)	● Office (2)	
B00A - R0028 - Duplicating Workroom - (7.85 SQM)	● Office (1)	
B00A - R0030 - Staff Room - (53.31 SQM)	● Office (13)	
B00A - R0031 - Home Base - (53.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0036 - Home Base - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0037 - Home Base - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0040 - Movement - (9.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Staff Room Annexe - (18.23 SQM)	● Office (4)	
B00A - R0046 - Movement - (6.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0047 - Home Base - (65.93 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0050 - Movement - (7.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0053 - Home Base - (66.08 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0054 - Home Base - (66 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0057 - Movement - (8.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - Withdrawal Space - 1hb - (21.79 SQM)	● Student Space (10)	
B00A - R0063 - Movement - (7.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0064 - Movement - (105.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (66.68 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0007 - Movement - (9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Reading Area - (161.13 SQM)	● Student Space (74)	
B00C - R0002 - Home Base - (67.25 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0006 - Home Base - (66.81 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R0010 - Home Base - (53.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0013 - Home Base - (53.38 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0016 - Special Programs Room - (18.62 SQM)	● Student Space (8)	
B00C - R0019 - Staff Room Annexe - (18.19 SQM)	● Office (4)	
B00C - R0023 - Duplicating Workroom - (14.69 SQM)	● Office (3)	
B00C - R0024 - Home Base - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0025 - Home Base - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0032 - Movement - (80.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0033 - Movement - (22.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0034 - Movement - (36.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (5.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Special Programs Room - (55.11 SQM)	● Student Space (25)	
B00D - R0014 - Home Base - (57.19 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0015 - Home Base - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0002 - Movement - (5.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Canteen - (30.49 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Communal Space - (90.62 SQM)	● Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0009 - Communal Space - (203.05 SQM)	 Student Space (94)	
B00J - R0010 - Raised Platform - (63.04 SQM)	Not Applicable	Circulation or storage space.
B00J - R0022 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00J - R0023 - Movement - (12.66 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Home Base - (82.84 SQM) - Teaching Space: 1	 Student Space (38)	
B00L - R0002 - Home Base X2 - (119.26 SQM) - Teaching Space: 2	 Student Space (55)	
B00L - R0006 - Staff Room - (15.27 SQM)	 Office (3)	
B00L - R0007 - Practical Activities - (52.31 SQM)	 Student Space (24)	
B00L - R0008 - Practical Activities - (38.31 SQM)	 Student Space (17)	
OS 602 11881 - OS 602 11881 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14788 - OS 602 14788 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	