

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Carlingford High School (8447)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Epping</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Parramatta</b>

8447 - Carlingford High School  
Site Plan (10500)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0018 - Deputy Principal Office - (20.76 SQM)	Office (5)	
B00A - R0020 - General Learning Space - (58.37 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0023 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0027 - Laboratory L.S. - (88.23 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0029 - Preparation - Science - (29.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Laboratory L.S. - (83.15 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R0040 - Ancillary Staff - (13.97 SQM)	Office (3)	
B00A - R0041 - Interview/Meeting - (10.81 SQM)	Office (2)	
B00A - R0042 - Clinic - (6.47 SQM)	Office (1)	
B00A - R0043 - Principal Office - (21.7 SQM)	Office (5)	
B00A - R0044 - Public Reception - (46.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Interview/Meeting - (12.5 SQM)	Office (3)	
B00A - R0046 - Administration - Clerical - (55.4 SQM)	Office (13)	
B00A - R0047 - Administration - Clerical - (10.17 SQM)	Office (2)	
B00A - R0048 - Deputy Principal Office - (21.31 SQM)	Office (5)	
B00A - R1003 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1005 - Interview/Office - Type 1 - (12.96 SQM)	Office (3)	
B00A - R1006 - General Learning Space - (58.21 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1008 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - Design L.S. - (66.05 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1013 - Computer Learning Space - (71.6 SQM) - Teaching Space: 1	Student Space (33)	
B00A - R1017 - General Learning Space - (52.43 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1030 - Administration - Clerical - (12.43 SQM)	Office (3)	
B00A - R1031 - Interview/Office - Type 1 - (13.36 SQM)	Office (3)	
B00A - R1032 - Commonroom - (74.97 SQM)	Office (18)	
B00A - R1033 - Staff Kitchen - (10.11 SQM)	Office (2)	
B00A - R1034 - Staff Study - (23.21 SQM)	Office (5)	
B00A - R1036 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1037 - General Learning Space - (52.44 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0005 - General Learning Space - (51.7 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0006 - Staff Study - (57.97 SQM)	Office (14)	
B00B - R0007 - Food Technology L.S. - (66.07 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0010 - Food Technology L.S. - (77.39 SQM) - Teaching Space: 1	Student Space (35)	
B00B - R0020 - Materials Technology L.S. - (85.54 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0021 - Welding Area - (25.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Materials Technology L.S. - (83.32 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R0024 - Design/Technology L.S. - (67.69 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0034 - Laboratory L.S. - (64.36 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0038 - Preparation - (25.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1009 - Art Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1011 - Art Learning Space - (71.79 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1015 - General Learning Space - (52.44 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1018 - Materials Technology L.S. - (86.44 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R1019 - Workshop - (34.29 SQM)	Student Space (15)	
B00B - R1021 - Materials Technology L.S. - (79.2 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R1025 - Design L.S. - (58.36 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1040 - Art Learning Space - (60.6 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R1042 - Staff Study - (23.06 SQM)	● Office (5)	
B00B - R1043 - Staff Study - (44.9 SQM)	● Office (11)	
B00C - R0007 - Student Canteen - (56.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (10.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Movement - (19.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Movement - (12.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Movement - (12.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0008 - Laboratory L.S. - (92.59 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0015 - General Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0017 - Leading Teacher - (12.89 SQM)	● Office (3)	
B00D - R0018 - General Learning Space - (58.51 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0019 - Laboratory L.S. - (89.74 SQM) - Teaching Space: 1	● Student Space (41)	
B00D - R0022 - Laboratory L.S. - (82.52 SQM) - Teaching Space: 1	● Student Space (38)	
B00D - R0027 - Preparation - Science - (9.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0035 - Staff Study - (50.81 SQM)	● Office (12)	
B00D - R0039 - Preparation - Science - (39.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - General Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1005 - General Learning Space - (57.93 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1006 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1011 - Computer Room - (12.52 SQM)	● Student Space (5)	
B00D - R1012 - Computer Learning Space - (58.36 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1015 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1017 - Interview/Office - Type 1 - (12.93 SQM)	● Office (3)	
B00D - R1018 - General Learning Space - (57.62 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1019 - General Learning Space - (51.41 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1020 - General Learning Space - (51.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1022 - Staff Study - (39.27 SQM)	● Office (9)	
B00D - R1023 - General Learning Space - (58.51 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1030 - Staff Study - (73.98 SQM)	● Office (18)	
B00E - R0007 - General Learning Space - (50.71 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0008 - General Learning Space - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0020 - Music Learning Space - (51.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0023 - Leading Teacher - (12.36 SQM)	● Office (3)	
B00E - R0024 - Staff Lounge - (17.24 SQM)	● Office (4)	
B00E - R0031 - Staff Study - (35.45 SQM)	● Office (8)	
B00E - R0036 - Practice/Seminar - (15.14 SQM)	Not Applicable	Circulation or storage space.
B00E - R0037 - Practice/Seminar - (15.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0042 - Music Learning Space - (78.45 SQM) - Teaching Space: 1	● Student Space (36)	
B00E - R0043 - Music Learning Space - (61.95 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0045 - Performance Workspace - (95.38 SQM) - Teaching Space: 1	● Student Space (44)	
B00E - R0046 - Staff Study - (32.67 SQM)	● Office (8)	
B00E - R0048 - Staff Study - (12.65 SQM)	● Office (3)	
B00E - R0050 - Staff Study - (25.07 SQM)	● Office (6)	
B00E - R1004 - General Learning Space - (50.5 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1008 - Laboratory L.S. - (88.09 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R1011 - Preparation - Science - (22.03 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1013 - Laboratory L.S. - (81.05 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R1017 - General Learning Space - (50.71 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1019 - Interview/Office - Type 1 - (12.55 SQM)	● Office (3)	
B00E - R1020 - General Learning Space - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1021 - General Learning Space - (51.43 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1022 - General Learning Space - (51.57 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1023 - Study Space - (25.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R1024 - General Learning Space - (57.17 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0003 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Multi-Purpose Space - (475.63 SQM)	● Student Space (220)	
B00F - R0018 - Staff Kitchen - (12.39 SQM)	● Office (3)	
B00F - R0025 - Movement - (24.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0029 - Stage - (82.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Movement - (137.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Senior Study - (13.51 SQM)	● Office (3)	
B00G - R0002 - Seminar - (13.51 SQM)	● Office (3)	
B00G - R0004 - Computer Learning Space - (60.99 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0005 - Main Area - (419.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Computer Learning Space - (65.13 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R0012 - Main Entry - (30.95 SQM)	Not Applicable	Circulation or storage space.
B00G - R9003 - General Assistants - (30.89 SQM)	● Office (7)	
OS 600 11856 - OS 600 11856 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 15835 - OS 600 15835 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 18363 - OS 600 18363 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 18368 - OS 600 18368 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19760 - OS 600 19760 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19764 - OS 600 19764 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19777 - OS 600 19777 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19779 - OS 600 19779 - Learning Unit - Small - (57 SQM)	● Student Space (26)	