

VENTILATION AUDIT REPORT

SCHOOL:	Casino High School (8154)
AMU REGION:	North Coast
STATE ELECTORATE:	Clarence
LOCAL GOVERNMENT AREA:	Richmond Valley

8154 - Casino High School
Site Plan (10925)



1:1,822















Printed: 24-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0005 - Movement - (17.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (325.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (11.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - General Assistants - (16.69 SQM)	Office (4)	
B00B - R0023 - Movement - (8.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (9.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Student Canteen - (16.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Student Canteen - (41.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Movement - (15.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Student Canteen - (16.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Student Canteen - (49.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0043 - Gymnasium - (76.6 SQM)	Student Space (35)	
B00B - R0048 - Movement - (8.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Interview/Office - Type 1 - (18.74 SQM)	Office (4)	
B00D - R0003 - Leading Teacher - (12.53 SQM)	Office (3)	
B00D - R0005 - Staff Kitchen - (6.14 SQM)	Office (1)	
B00D - R0023 - Public Entry - (14.13 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Movement - (39.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Interview/Office - Type 1 - (10.4 SQM)	Office (2)	
B00D - R0027 - Administration - Clerical - (73.5 SQM)	Office (18)	
B00D - R0028 - Clinic - Boys - (10.83 SQM)	Office (2)	
B00D - R0029 - Movement - (30.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0031 - Clinic - Girls - (10.91 SQM)	Office (2)	
B00D - R0032 - Leading Teacher - (14.85 SQM)	Office (3)	
B00D - R0035 - Interview/Office - Type 1 - (7.71 SQM)	Office (1)	
B00D - R0036 - Deputy Principal Office - (13.18 SQM)	Office (3)	
B00D - R0043 - Principal Office - (20.96 SQM)	Office (5)	
B00H - R0001 - Staff Study - (25.76 SQM)	Office (6)	
B00H - R0002 - General Learning Space - (66.27 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0003 - Staff Study - (26.12 SQM)	Office (6)	
B00H - R0004 - Staff Study - (26.05 SQM)	Office (6)	
B00H - R0005 - Computer Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0009 - Staff Study - (18.9 SQM)	Office (4)	
B00L - R0001 - Audio Visual Workroom - (24.81 SQM)	Student Space (11)	
B00L - R0003 - Workroom - (42.57 SQM)	Office (10)	
B00L - R0005 - Movement - (10.7 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Seminar - (11.54 SQM)	Office (2)	
B00L - R0007 - Seminar - (11.54 SQM)	Office (2)	
B00L - R0010 - Seminar - (11.78 SQM)	Office (2)	
B00L - R0011 - Seminar - (12.53 SQM)	Office (3)	
B00L - R0012 - Seminar - (11.67 SQM)	Office (2)	
B00L - R0013 - Main Area - (433.89 SQM)	Not Applicable	Circulation or storage space.
B00L - R0014 - Entry - (9.74 SQM)	Not Applicable	Circulation or storage space.
B00M - R0008 - Music Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R0011 - Materials Learning Space - Type 1 - (66.22 SQM) - Teaching Space: 1	Student Space (30)	
B00M - R0013 - Music Learning Space - (82.75 SQM) - Teaching Space: 1	Student Space (38)	
B00M - R0016 - Stage - (22.02 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0005 - General Learning Space - S/P - (58.31 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Q - R0006 - Withdrawal Space - 1hb - (11.87 SQM)	Student Space (5)	
B00Q - R0007 - General Learning Space - S/P - (58.29 SQM) - Teaching Space: 1	Student Space (27)	
B00Q - R0008 - Practical Activities - S - 1hb - (30.99 SQM)	Student Space (14)	
B0A1 - R0001 - Performance Workspace - (105.09 SQM) - Teaching Space: 1	Student Space (48)	
B0A1 - R0003 - Staff Study - (26.2 SQM)	Office (6)	
B0A1 - R0005 - Staff Study - (39.04 SQM)	Office (9)	
B0A1 - R0006 - Art Learning Space - (93.21 SQM) - Teaching Space: 1	Student Space (43)	
B0A1 - R0009 - Laboratory L.S. - (93.2 SQM) - Teaching Space: 1	Student Space (43)	
B0A1 - R0016 - Preparation - (13.8 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R1001 - General Learning Space - (52.84 SQM) - Teaching Space: 1	Student Space (24)	
B0A1 - R1002 - General Learning Space - (52.98 SQM) - Teaching Space: 1	Student Space (24)	
B0A1 - R1003 - General Learning Space - (52.85 SQM) - Teaching Space: 1	Student Space (24)	
B0A1 - R1004 - General Learning Space - (52.77 SQM) - Teaching Space: 1	Student Space (24)	
B0A1 - R1007 - Staff Study - (25.76 SQM)	Office (6)	
B0A1 - R1010 - Workshop - (39.33 SQM)	Student Space (18)	
B0A1 - R1011 - Art Learning Space - (52.84 SQM) - Teaching Space: 1	Student Space (24)	
B0A1 - R1023 - Dark Room - (22.16 SQM)	Office (5)	
B0A2 - R0001 - Laboratory L.S. - (86.59 SQM) - Teaching Space: 1	Student Space (40)	
B0A2 - R0002 - Preparation - (28.16 SQM)	Not Applicable	Circulation or storage space.
B0A2 - R0004 - Laboratory L.S. - (86.75 SQM) - Teaching Space: 1	Student Space (40)	
B0A2 - R0005 - General Learning Space - (52.85 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R0007 - General Learning Space - (66.27 SQM) - Teaching Space: 1	Student Space (30)	
B0A2 - R0008 - General Learning Space - (52.77 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1001 - Senior Study - (39.34 SQM)	Office (9)	
B0A2 - R1002 - General Learning Space - (39.42 SQM) - Teaching Space: 1	Student Space (18)	
B0A2 - R1005 - Staff Study - (25.77 SQM)	Office (6)	
B0A2 - R1007 - General Learning Space - (52.55 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1008 - General Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1009 - General Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1010 - General Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1011 - General Learning Space - (52.7 SQM) - Teaching Space: 1	Student Space (24)	
B0A2 - R1012 - Staff Study - (22.15 SQM)	Office (5)	
B0A2 - R1013 - General Learning Space - (66.36 SQM) - Teaching Space: 1	Student Space (30)	
B0A2 - R1016 - Computer Learning Space - (66.35 SQM) - Teaching Space: 1	Student Space (30)	
B0A3 - R0001 - Laboratory L.S. - (86.75 SQM) - Teaching Space: 1	Student Space (40)	
B0A3 - R0004 - Laboratory L.S. - (87.04 SQM) - Teaching Space: 1	Student Space (40)	
B0A3 - R0013 - Preparation - Science - (38.09 SQM)	Not Applicable	Circulation or storage space.
B0A3 - R1001 - Staff Study - (18.95 SQM)	Office (4)	
B0A3 - R1002 - General Learning Space - (53.06 SQM) - Teaching Space: 1	Student Space (24)	
B0A3 - R1004 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B0A3 - R1005 - General Learning Space - (53.07 SQM) - Teaching Space: 1	Student Space (24)	
B0A3 - R1006 - General Learning Space - (51.67 SQM) - Teaching Space: 1	Student Space (23)	
B0C1 - R0009 - Materials Technology L.S. - (79.26 SQM) - Teaching Space: 1	Student Space (36)	
B0C1 - R0011 - Staff Study - (22.18 SQM)	Office (5)	
B0C1 - R0012 - Materials Technology L.S. - (79.64 SQM) - Teaching Space: 1	Student Space (36)	
B0C1 - R0014 - Design L.S. - (52.18 SQM) - Teaching Space: 1	Student Space (24)	
B0C1 - R0019 - Metal Technology Bay - (142.96 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
BOC2 - R0008 - Food Technology L.S. - (66.42 SQM) - Teaching Space: 1	 Student Space (30)	
BOC2 - R0017 - Kitchen - Type 1 - (125.34 SQM)	 Student Space (58)	
BOC2 - R0018 - Preparation - Materials - (18.27 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1001 - Materials Technology L.S. - (66.2 SQM) - Teaching Space: 1	 Student Space (30)	
BOC2 - R1005 - Materials Technology L.S. - (66.27 SQM) - Teaching Space: 1	 Student Space (30)	
BOC2 - R1010 - Staff Study - (25.69 SQM)	 Office (6)	
BOJK - R0001 - Administration - Clerical - (13.7 SQM)	 Office (3)	
BOJK - R0002 - Deputy Principal Office - (19.49 SQM)	 Office (4)	
BOJK - R0003 - Leading Teacher - (13.17 SQM)	 Office (3)	
BOJK - R0009 - Movement - (14.48 SQM)	Not Applicable	Circulation or storage space.
BOJK - R0012 - Staff Kitchen - (6.46 SQM)	 Office (1)	
BOJK - R0013 - Commonroom - (121.61 SQM)	 Office (30)	
BMPU - R0001 - Multi-Purpose Space - (457.77 SQM)	 Student Space (212)	
BMPU - R0002 - Stage - (104.38 SQM)	Not Applicable	Circulation or storage space.
BMPU - R0004 - Public Entry - (69.32 SQM)	Not Applicable	Circulation or storage space.
NS 111 13173 - NS 111 13173 - Learning Unit - Double Secondary/Secure - (114 SQM)	 Student Space (52)	
OS 600 16833 - OS 600 16833 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 626 11503 - OS 626 11503 - Double Learning Unit - H/Cap - (171 SQM)	 Student Space (79)	
OS 801 13120 - OS 801 13120 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.