


VENTILATION AUDIT REPORT

SCHOOL:	Casino Public School (1526)
AMU REGION:	North Coast
STATE ELECTORATE:	Clarence
LOCAL GOVERNMENT AREA:	Richmond Valley

1526 - Casino Public School
Site Plan (12066)



1:1,131






Printed: 28-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (47.46 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0008 - Clerical Office - (48.43 SQM)	● Office (12)	
B00A - R0013 - Movement - (24.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (18.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (27.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Movement - (71.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Interview/Office - Type 3 - (13.4 SQM)	● Office (3)	
B00A - R0031 - Interview - (25.81 SQM)	● Office (6)	
B00A - R0032 - Staff Room - (32.5 SQM)	● Office (8)	
B00A - R0033 - Staff Kitchen - (30.75 SQM)	● Office (7)	
B00A - R0034 - Interview/Office - Type 3 - (13.71 SQM)	● Office (3)	
B00A - R0036 - Sick Bay - (9.77 SQM)	● Student Space (4)	
B00A - R0038 - Deputy Principal - Type 1 - (15.88 SQM)	● Office (3)	
B00A - R0041 - Principal - (16.5 SQM)	● Office (4)	
B00A - R0043 - Duplicating Workroom - (29.9 SQM)	● Office (7)	
B00A - R0045 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (49.02 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1002 - Staff Room Annexe - (15.3 SQM)	● Office (3)	
B00A - R1004 - Movement - (105.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - Withdrawal Space - 1hb - (38.45 SQM)	● Student Space (17)	
B00A - R1006 - Home Base - (48.64 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1007 - Home Base - (96.98 SQM) - Teaching Space: 1	● Student Space (44)	
B00A - R1010 - Staff Room Annexe - (14.89 SQM)	● Office (3)	
B00A - R1012 - Home Base - (49.11 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1013 - Practical Activities - 1hb - (21.03 SQM)	● Student Space (9)	
B00A - R1016 - Withdrawal - M - (16.13 SQM)	● Student Space (7)	
B00A - R1019 - Movement - (10.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Home Base - (53.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0004 - Home Base - (55.77 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0008 - Seminar/Study - (51.17 SQM)	● Office (12)	
B00B - R0020 - Movement - (21.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Movement - (80.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0036 - Home Base - (59.88 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0037 - Staff Room Annexe - (19.85 SQM)	● Office (4)	
B00B - R0038 - Home Base - (45.29 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0039 - Home Base - (59.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0040 - Home Base - (45.12 SQM) - Teaching Space: 1	● Student Space (20)	
B00C - R0001 - Interview - (13.22 SQM)	● Office (3)	
B00C - R0006 - Movement - (14.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Staff Room Annexe - (15.17 SQM)	● Office (3)	
B00C - R0024 - Movement - (18.84 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (8.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0027 - Home Base - (63.17 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0028 - Home Base - (75.07 SQM) - Teaching Space: 1	● Student Space (34)	
B00C - R0029 - Home Base - (66.5 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R0030 - Home Base - (73.82 SQM) - Teaching Space: 1	● Student Space (34)	
B00M - R0003 - Movement - (50.16 SQM)	Not Applicable	Circulation or storage space.
B00M - R0007 - Practical Activities - Pre - (37.18 SQM)	● Student Space (17)	
B00M - R0008 - Clerical Office/Workroom - (14.1 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0011 - Movement - (7.56 SQM)	Not Applicable	Circulation or storage space.
B00M - R0013 - Home Base - (55.98 SQM) - Teaching Space: 1	● Student Space (25)	
B00M - R0014 - Staff Kitchen - (13.51 SQM)	● Office (3)	
B00O - R0002 - Practical Activities - 1hb - (19.45 SQM)	● Student Space (9)	
B00O - R0004 - Home Base - (59.36 SQM) - Teaching Space: 1	● Student Space (27)	
B00O - R0005 - Withdrawal Space - 2hb - (11.38 SQM)	● Student Space (5)	
B00O - R0006 - Home Base - (59.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00O - R0008 - Practical Activities - 1hb - (19.46 SQM)	● Student Space (9)	
B00P - R0001 - Communal Space - (203.27 SQM)	● Student Space (94)	
B00P - R0004 - Staff Kitchen - (7.43 SQM)	● Office (1)	
B00P - R0015 - Raised Platform - (54.34 SQM)	Not Applicable	Circulation or storage space.
B00P - R0016 - Movement - (12.71 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0001 - Canteen - (41.73 SQM)	Not Applicable	Circulation or storage space.
B00R - R0001 - Home Base - (60.66 SQM) - Teaching Space: 1	● Student Space (28)	
B00R - R0002 - Home Base - (60.51 SQM) - Teaching Space: 1	● Student Space (28)	
B00R - R0003 - Home Base - (60.66 SQM) - Teaching Space: 1	● Student Space (28)	
B00R - R0004 - Home Base - (60.66 SQM) - Teaching Space: 1	● Student Space (28)	
B00R - R0005 - Home Base - (60.66 SQM) - Teaching Space: 1	● Student Space (28)	
B00R - R0006 - Home Base - (60.66 SQM) - Teaching Space: 1	● Student Space (28)	
B00R - R0011 - Special Programs Room - (11.64 SQM)	● Student Space (5)	
B00R - R0012 - Special Programs Room - (11.63 SQM)	● Student Space (5)	
B00R - R0016 - Special Programs Room - (11.64 SQM)	● Student Space (5)	
B00R - R0018 - Practical Activities - (19.09 SQM)	● Student Space (8)	
B00R - R0019 - Practical Activities - (19.09 SQM)	● Student Space (8)	
B00R - R0020 - Practical Activities - (19.09 SQM)	● Student Space (8)	
B00R - R0021 - Practical Activities - (18.41 SQM)	● Student Space (8)	
B00R - R0022 - Practical Activities - (18.45 SQM)	● Student Space (8)	
B00R - R0023 - Practical Activities - (19.09 SQM)	● Student Space (8)	
B00S - R0001 - Reading Area - (257.28 SQM)	● Student Space (119)	
B00S - R0002 - Seminar/Study - (57.02 SQM)	● Office (14)	
B00T - R0001 - Home Base - (81.08 SQM) - Teaching Space: 1	● Student Space (37)	
B00T - R0002 - Home Base - (81.25 SQM) - Teaching Space: 1	● Student Space (37)	
B00T - R0003 - Home Base - (81.16 SQM) - Teaching Space: 1	● Student Space (37)	
B00T - R0004 - Home Base - (81.32 SQM) - Teaching Space: 1	● Student Space (37)	
B00T - R0005 - Withdrawal - M - (9.64 SQM)	● Student Space (4)	
B00T - R0006 - Breakout Area - (18.27 SQM)	Not Applicable	Circulation or storage space.
B00T - R0008 - Movement - (20.33 SQM)	Not Applicable	Circulation or storage space.
B00T - R0013 - Breakout Area - (17.92 SQM)	Not Applicable	Circulation or storage space.
B00T - R0014 - Withdrawal - M - (9.54 SQM)	● Student Space (4)	
B00T - R0019 - Withdrawal - M - (9.51 SQM)	● Student Space (4)	
B00T - R0020 - Breakout Area - (18.28 SQM)	Not Applicable	Circulation or storage space.
B00T - R0022 - Breakout Area - (18.56 SQM)	Not Applicable	Circulation or storage space.
B00T - R0029 - Withdrawal - M - (9.6 SQM)	● Student Space (4)	
B00U - R0002 - Movement - (17.68 SQM)	Not Applicable	Circulation or storage space.
B00U - R0003 - Home Base - (52.47 SQM) - Teaching Space: 1	● Student Space (24)	
B00U - R0004 - Home Base - (52.54 SQM) - Teaching Space: 1	● Student Space (24)	
B00U - R0006 - Withdrawal Space - 1hb - (6.7 SQM)	● Student Space (3)	
B00V - R0002 - Home Base - (92.96 SQM) - Teaching Space: 1	● Student Space (43)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00V - R0003 - Staff Room - (20.4 SQM)	 Office (5)	
OS 602 12687 - OS 602 12687 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13267 - OS 602 13267 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13863 - OS 602 13863 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16174 - OS 602 16174 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	