

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Casula High School (8476)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Holsworthy</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Liverpool</b>

8476 - Casula High School  
Site Plan (10261)



1:1,658














Printed: 30-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0006 - Tiered Learning Area - (10.84 SQM)	● Student Space (5)	
B00L - R0009 - Seminar/Study - (192.02 SQM)	● Office (48)	
B00L - R0012 - Main Entry - (13.69 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Movement - (30.7 SQM)	Not Applicable	Circulation or storage space.
B00L - R1002 - Senior Seminar - (99.57 SQM)	● Office (24)	
B00L - R1004 - Main Area - (111.72 SQM)	Not Applicable	Circulation or storage space.
B00L - R1005 - Seminar - (15.1 SQM)	● Office (3)	
B00L - R1006 - Seminar - (15.37 SQM)	● Office (3)	
B00L - R1007 - Senior Study - (15.49 SQM)	● Office (3)	
B00L - R1008 - Senior Study - (15.29 SQM)	● Office (3)	
B00L - R1009 - Senior Study - (15.02 SQM)	● Office (3)	
B00S - R0007 - Laboratory L.S. - (93.89 SQM) - Teaching Space: 1	● Student Space (43)	
B00S - R0010 - Laboratory L.S. - (93.8 SQM) - Teaching Space: 1	● Student Space (43)	
B00S - R0012 - Staff Study - (93.98 SQM)	● Office (23)	
B00S - R0015 - Computer Learning Space - (94.26 SQM) - Teaching Space: 1	● Student Space (43)	
B00S - R0020 - Preparation - Science - (50.55 SQM)	Not Applicable	Circulation or storage space.
B00S - R1008 - Laboratory L.S. - (92.87 SQM) - Teaching Space: 1	● Student Space (43)	
B00S - R1009 - Preparation - Science - (49.63 SQM)	Not Applicable	Circulation or storage space.
B00S - R1012 - Laboratory L.S. - (92.78 SQM) - Teaching Space: 1	● Student Space (43)	
B00S - R1013 - Laboratory L.S. - (92.68 SQM) - Teaching Space: 1	● Student Space (42)	
B00S - R1014 - Preparation - Science - (45.69 SQM)	Not Applicable	Circulation or storage space.
B00S - R1016 - Laboratory L.S. - (92.77 SQM) - Teaching Space: 1	● Student Space (43)	
B0AM - R0002 - Administration - Clerical - (29.06 SQM)	● Office (7)	
B0AM - R0003 - Principal Office - (22.1 SQM)	● Office (5)	
B0AM - R0010 - Commonroom - (115.82 SQM)	● Office (28)	
B0AM - R0011 - Staff Kitchen - (10.73 SQM)	● Office (2)	
B0AM - R0015 - Leading Teacher - (12.25 SQM)	● Office (3)	
B0AM - R0019 - Multi Media Workshop - (96.29 SQM)	Not Applicable	Circulation or storage space.
B0AM - R0021 - Administration - Executive - (13.47 SQM)	● Office (3)	
B0AM - R0025 - Movement - (55.08 SQM)	Not Applicable	Circulation or storage space.
B0AM - R0028 - Clinic - (25.89 SQM)	● Office (6)	
B0AM - R0030 - Deputy Principal Office - (22.32 SQM)	● Office (5)	
B0AM - R0036 - Pupil Entry - (47.4 SQM)	Not Applicable	Circulation or storage space.
B0AM - R0037 - Interview/Office - Type 2 - (25.44 SQM)	● Office (6)	
B0AM - R0038 - Administration - Clerical - (12.77 SQM)	● Office (3)	
B0AM - R0039 - Public Reception - (16.2 SQM)	Not Applicable	Circulation or storage space.
B0AM - R1002 - Staff Study - (52.58 SQM)	● Office (13)	
B0AM - R1003 - General Learning Space - (52.17 SQM) - Teaching Space: 1	● Student Space (24)	
B0AM - R1004 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B0AM - R1006 - General Learning Space - (53.38 SQM) - Teaching Space: 1	● Student Space (24)	
B0AM - R1007 - General Learning Space - (64.4 SQM) - Teaching Space: 1	● Student Space (29)	
B0AM - R1008 - General Learning Space - (64.3 SQM) - Teaching Space: 1	● Student Space (29)	
B0AM - R1009 - General Learning Space - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B0AM - R1010 - Movement - (20.98 SQM)	Not Applicable	Circulation or storage space.
B0AM - R1016 - Tea Room - (12.54 SQM)	Not Applicable	Circulation or storage space.
B0AM - R1017 - General Assistants - (16.58 SQM)	● Office (4)	
B0AM - R1019 - Seminar - Type 1 - (16.64 SQM)	● Office (4)	
B0AM - R1021 - Movement - (74.64 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0003 - Art Learning Space - (67.59 SQM) - Teaching Space: 1	● Student Space (31)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOC1 - R0004 - Dark Room - (11.27 SQM)	Office (2)	
BOC1 - R0006 - Workshop - (33.55 SQM)	Student Space (15)	
BOC1 - R0008 - Art Learning Space - (44.02 SQM) - Teaching Space: 1	Student Space (20)	
BOC1 - R0009 - Art Learning Space - (58.17 SQM) - Teaching Space: 1	Student Space (26)	
BOC1 - R1002 - Staff Study - (13.42 SQM)	Office (3)	
BOC1 - R1003 - Staff Study - (19.66 SQM)	Office (4)	
BOC1 - R1004 - Textiles Technology L.S. - (69.81 SQM) - Teaching Space: 1	Student Space (32)	
BOC1 - R1007 - Textiles Technology L.S. - (69.45 SQM) - Teaching Space: 1	Student Space (32)	
BOC2 - R0001 - Art Learning Space - (65.5 SQM) - Teaching Space: 1	Student Space (30)	
BOC2 - R0003 - Wood Technology L.S. - (111 SQM) - Teaching Space: 1	Student Space (51)	
BOC2 - R0004 - Wood Technology L.S. - (113.01 SQM) - Teaching Space: 1	Student Space (52)	
BOC2 - R1005 - Kitchen - Type 2 - (95.52 SQM)	Student Space (44)	
BOC2 - R1009 - Food Technology L.S. - (94.25 SQM) - Teaching Space: 1	Student Space (43)	
BOC2 - R1010 - Preparation - Materials - (32.52 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1013 - General Learning Space - (48.41 SQM) - Teaching Space: 1	Student Space (22)	
BOC3 - R0001 - Metal Technology L.S. - (63.72 SQM) - Teaching Space: 1	Student Space (29)	
BOC3 - R0002 - Metal Technology Bay - (38.42 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0005 - Metal Technology L.S. - (89.85 SQM) - Teaching Space: 1	Student Space (41)	
BOC3 - R1001 - Design/Technology L.S. - (67.13 SQM) - Teaching Space: 1	Student Space (31)	
BOC3 - R1002 - Movement - (6.78 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1003 - Computer Learning Space - (90.27 SQM) - Teaching Space: 1	Student Space (41)	
BOC3 - R1004 - Staff Study - (56.12 SQM)	Office (14)	
BOEL - R0001 - General Learning Space - (53.97 SQM) - Teaching Space: 1	Student Space (25)	
BOEL - R0002 - General Learning Space - (51.28 SQM) - Teaching Space: 1	Student Space (23)	
BOEL - R0003 - General Learning Space - (67.04 SQM) - Teaching Space: 1	Student Space (31)	
BOEL - R0004 - Special Learning Space - (51.77 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R0005 - Staff Study - (45.92 SQM)	Office (11)	
BOEL - R0009 - Leading Teacher - (25.5 SQM)	Office (6)	
BOEL - R0010 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R0011 - Movement Studio - (53.89 SQM)	Not Applicable	Circulation or storage space.
BOEL - R0015 - Computer Learning Space - (53.82 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1001 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1002 - General Learning Space - (51.46 SQM) - Teaching Space: 1	Student Space (23)	
BOEL - R1003 - General Learning Space - (65.5 SQM) - Teaching Space: 1	Student Space (30)	
BOEL - R1004 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1010 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1011 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1012 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1013 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1015 - Staff Study - (68.87 SQM)	Office (17)	
BOHC - R0003 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
BOHC - R0004 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
BOHC - R0010 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
BOHC - R0011 - General Learning Space - (66.54 SQM) - Teaching Space: 1	Student Space (30)	
BOHC - R0012 - General Learning Space - (67.24 SQM) - Teaching Space: 1	Student Space (31)	
BOHC - R0016 - Staff Study - (65.9 SQM)	Office (16)	
BOHC - R1003 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOHC - R1004 - General Learning Space - (73.14 SQM) - Teaching Space: 1	 Student Space (33)	
BOHC - R1010 - General Learning Space - (53.02 SQM) - Teaching Space: 1	 Student Space (24)	
BOHC - R1011 - General Learning Space - (66.06 SQM) - Teaching Space: 1	 Student Space (30)	
BOHC - R1012 - General Learning Space - (65.76 SQM) - Teaching Space: 1	 Student Space (30)	
BOSC - R0001 - Multi-Purpose Space - (457.18 SQM)	 Student Space (212)	
BOSC - R0002 - Movement - (12.04 SQM)	Not Applicable	Circulation or storage space.
BOSC - R0023 - Student Canteen - (61 SQM)	Not Applicable	Circulation or storage space.
BOSC - R0029 - Performance Workshop - (101.2 SQM)	 Student Space (46)	
BOSC - R0030 - Movement - (7.82 SQM)	Not Applicable	Circulation or storage space.
BOSC - R0033 - Movement - (7.82 SQM)	Not Applicable	Circulation or storage space.
BOSC - R1001 - Music Learning Space - (78.7 SQM) - Teaching Space: 1	 Student Space (36)	
BOSC - R1002 - Music Learning Space - (82.6 SQM) - Teaching Space: 1	 Student Space (38)	
BOSC - R1010 - Fitness Laboratory - (42.57 SQM)	 Student Space (19)	
BOSC - R1020 - Movement - (25.21 SQM)	Not Applicable	Circulation or storage space.
OS 601 12653 - OS 601 12653 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12886 - OS 601 12886 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13714 - OS 601 13714 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14782 - OS 601 14782 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	