

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Cattai Public School (1535)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Hawkesbury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Hawkesbury</b>

1535 - Cattai Public School  
Site Plan (12232)













1:518

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (8.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Withdrawal Space - 1hb - (15.87 SQM)	 Student Space (7)	
B00A - R0006 - Practical Activity Area - (21.82 SQM)	 Student Space (10)	
B00B - R0001 - Movement - (28.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Practical Activities - 1hb - (15.95 SQM)	 Student Space (7)	
B00B - R0004 - Home Base - (62.13 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R0006 - Movement - (13.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Withdrawal Space - 1hb - (11.89 SQM)	 Student Space (5)	
B00B - R0008 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Home Base - (62.2 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R0011 - Practical Activities - 1hb - (15.97 SQM)	 Student Space (7)	
B00D - R0005 - Home Base - (57.51 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0001 - Reading Area - (91.91 SQM)	 Student Space (42)	
OS 503 16165 - OS 503 16165 - Admin Lib Staff/Principal/Clerk/Store - (152 SQM)	 Office (38)	