

VENTILATION AUDIT REPORT

SCHOOL:	Caves Beach Public School (4367)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Swansea
LOCAL GOVERNMENT AREA:	Lake Macquarie








4367 - Caves Beach Public School
Site Plan (10926)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (32.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Practical Activities - 1hb - (15.41 SQM)	● Student Space (7)	
B00A - R0003 - Home Base - (56.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0004 - Home Base - (56.39 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0005 - Practical Activities - 1hb - (15.49 SQM)	● Student Space (7)	
B00B - R0001 - Movement - (45.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Communal Space - (58.34 SQM)	● Student Space (27)	
B00B - R0003 - Movement - (25.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Canteen - (20.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (59.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Reading Area - (171.41 SQM)	● Student Space (79)	
B00C - R1001 - Movement - (59.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Practical Activities - 1hb - (15.83 SQM)	● Student Space (7)	
B00C - R1003 - Home Base - (55.61 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1004 - Home Base - (55.6 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1005 - Practical Activities - 1hb - (15.84 SQM)	● Student Space (7)	
B00C - R1006 - Home Base - (55.92 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1007 - Practical Activities - 1hb - (15.84 SQM)	● Student Space (7)	
B00D - R0001 - Movement - (5.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (57.19 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0005 - Practical Activities - 1hb - (20.59 SQM)	● Student Space (9)	
B00D - R0007 - Home Base - (57.02 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0008 - Movement - (31.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Movement - (9.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (11.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Practical Activities - 1hb - (14.31 SQM)	● Student Space (6)	
B00E - R0004 - Home Base - (89.8 SQM) - Teaching Space: 1	● Student Space (41)	
B00E - R0005 - Movement - (41.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Home Base - (56.86 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0008 - Movement - (9.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Home Base - (57.26 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0003 - Movement - (7.72 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Movement - (32.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Home Base - (57.41 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0001 - Movement - (12.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (13.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (79.72 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Interview - (8 SQM)	● Office (2)	
B00H - R0009 - Staff Room Annexe - (22.24 SQM)	● Office (5)	
B00H - R0010 - Movement - (11.08 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Entry Vestibule - (15.26 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Staff Room - (40.99 SQM)	● Office (10)	
B00H - R0021 - Special Programs Room - (41.09 SQM)	● Student Space (19)	
B00I - R0002 - Home Base - (57.02 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0003 - Movement - (7.74 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Movement - (48.49 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Home Base - (57.02 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0008 - Movement - (6.67 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0011 - Home Base - (57.35 SQM) - Teaching Space: 1	 Student Space (26)	
B00J - R0001 - Movement - (15.69 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Movement - (10.29 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Movement - (19.39 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Movement - (14.56 SQM)	Not Applicable	Circulation or storage space.
B00K - R0012 - Raised Platform - (68.12 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Movement - (7.64 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Communal Space - (132.01 SQM)	 Student Space (61)	
B00L - R0001 - Special Programs Room - (32.12 SQM)	 Student Space (14)	
OS 508 14553 - OS 508 14553 - Administration - (114 SQM)	 Office (28)	
OS 602 14298 - OS 602 14298 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14883 - OS 602 14883 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 19668 - OS 606 19668 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	