

VENTILATION AUDIT REPORT

SCHOOL:	Cecil Hills Public School (4635)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Mulgoa
LOCAL GOVERNMENT AREA:	Liverpool

4635 - Cecil Hills Public School
Site Plan (03088)



1:1,036





















Printed: 20-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (40.68 SQM)	Office (10)	
B00A - R0002 - Staff Kitchen - (6.53 SQM)	Office (1)	
B00A - R0003 - Staff Room Annexe - (19.03 SQM)	Office (4)	
B00A - R0004 - Movement - (42.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Deputy Principal - (12.78 SQM)	Office (3)	
B00A - R0006 - Deputy Principal - (12.78 SQM)	Office (3)	
B00A - R0007 - Principal - (16.94 SQM)	Office (4)	
B00A - R0008 - Interview - (13.01 SQM)	Office (3)	
B00A - R0009 - Entry Vestibule - (18.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Clerical Office - (49.7 SQM)	Office (12)	
B00A - R0011 - Sick Bay - (8.7 SQM)	Student Space (4)	
B00A - R0019 - Movement - (124.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Practical Activities - 1hb - (19.08 SQM)	Student Space (8)	
B00A - R1006 - Home Base - (60.84 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1007 - Withdrawal Space - 2hb - (11.79 SQM)	Student Space (5)	
B00A - R1008 - Home Base - (60.84 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1010 - Practical Activities - 1hb - (18.74 SQM)	Student Space (8)	
B00A - R1012 - Practical Activities - 1hb - (18.71 SQM)	Student Space (8)	
B00A - R1014 - Home Base - (60.81 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1015 - Withdrawal Space - 2hb - (11.79 SQM)	Student Space (5)	
B00A - R1016 - Home Base - (61.24 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1018 - Practical Activities - 1hb - (19.07 SQM)	Student Space (8)	
B00A - R1019 - Movement - (182.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (60.72 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0004 - Practical Activities - 1hb - (18.57 SQM)	Student Space (8)	
B00B - R0005 - Withdrawal Space - 2hb - (11.78 SQM)	Student Space (5)	
B00B - R0006 - Practical Activities - 2hb - (19.23 SQM)	Student Space (8)	
B00B - R0008 - Home Base - (60.72 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0009 - Movement - (43.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Practical Activities - 1hb - (19.21 SQM)	Student Space (8)	
B00C - R0005 - Home Base - (60.43 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0006 - Withdrawal Space - 2hb - (11.78 SQM)	Student Space (5)	
B00C - R0007 - Home Base - (60.42 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0009 - Practical Activities - 1hb - (19.24 SQM)	Student Space (8)	
B00C - R0013 - Special Programs Room - (21.27 SQM)	Student Space (9)	
B00C - R0014 - Special Programs Room - (16.12 SQM)	Student Space (7)	
B00C - R0015 - Reading Area - (166.89 SQM)	Student Space (77)	
B00C - R0023 - Movement - (163.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (60.64 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0003 - Practical Activities - 1hb - (19.23 SQM)	Student Space (8)	
B00D - R0004 - Withdrawal Space - 2hb - (11.82 SQM)	Student Space (5)	
B00D - R0005 - Home Base - (60.77 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0007 - Practical Activities - 1hb - (18.89 SQM)	Student Space (8)	
B00D - R0009 - Practical Activities - 1hb - (18.78 SQM)	Student Space (8)	
B00D - R0011 - Home Base - (60.48 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0012 - Withdrawal Space - 2hb - (11.79 SQM)	Student Space (5)	
B00D - R0013 - Home Base - (60.65 SQM) - Teaching Space: 1	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0015 - Practical Activities - 1hb - (19.23 SQM)	● Student Space (8)	
B00D - R0019 - Movement - (173.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Communal Space - (241.41 SQM)	● Student Space (112)	
B00E - R0025 - Raised Platform - (62.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - Movement - (20.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Practical Activities - 1hb - (19.2 SQM)	● Student Space (8)	
B00F - R0003 - Home Base - (60.72 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0004 - Withdrawal Space - 2hb - (11.74 SQM)	● Student Space (5)	
B00F - R0005 - Practical Activities - 1hb - (19.2 SQM)	● Student Space (8)	
B00F - R0007 - Home Base - (59.89 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0010 - Canteen - (28.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Movement - (111.26 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (38.27 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00G - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00G - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00H - R0002 - Practical Activities - (19.05 SQM)	● Student Space (8)	
B00H - R0004 - Home Base - (60.58 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0005 - Withdrawal Space - 2hb - (11.67 SQM)	● Student Space (5)	
B00H - R0006 - Home Base - (60.77 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0008 - Practical Activities - (18.34 SQM)	● Student Space (8)	
B00H - R0009 - Withdrawal Space - 1hb - (7.7 SQM)	● Student Space (3)	
B00H - R0011 - Home Base - (59.61 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0012 - Practical Activities - (19.02 SQM)	● Student Space (8)	
B00H - R1002 - Practical Activities - (19.33 SQM)	● Student Space (8)	
B00H - R1004 - Home Base - (60.36 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R1005 - Withdrawal Space - 2hb - (11.82 SQM)	● Student Space (5)	
B00H - R1006 - Home Base - (61.31 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R1008 - Practical Activities - (19.25 SQM)	● Student Space (8)	
B00H - R1009 - Withdrawal Space - 1hb - (7.66 SQM)	● Student Space (3)	
B00H - R1011 - Home Base - (59.05 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R1012 - Practical Activities - (19.61 SQM)	● Student Space (9)	
B00I - R0001 - Home Base - (61.39 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0002 - Practical Activities - 4hb - (82.4 SQM)	● Student Space (38)	
B00I - R0003 - Practical Activities - (49.2 SQM)	● Student Space (22)	
B00I - R0004 - Seminar/Study - (26.84 SQM)	● Office (6)	
B00I - R0005 - Home Base - (65.56 SQM) - Teaching Space: 1	● Student Space (30)	
B00I - R0006 - Withdrawal Space - 2hb - (11.87 SQM)	● Student Space (5)	
B00I - R0007 - Home Base - (77.46 SQM) - Teaching Space: 1	● Student Space (35)	
B00I - R0017 - Practical Activities - 3hb - (49.16 SQM)	● Student Space (22)	
B00I - R0018 - Home Base - (43.51 SQM) - Teaching Space: 1	● Student Space (20)	
B00I - R0019 - Home Base - (45.08 SQM) - Teaching Space: 1	● Student Space (20)	
B00I - R0020 - Home Base - (24.99 SQM) - Teaching Space: 1	● Student Space (11)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0023 - Seminar/Study - (27.1 SQM)	 Office (6)	
B00I - R0026 - Home Base - (49.04 SQM) - Teaching Space: 1	 Student Space (22)	
B00I - R0027 - Withdrawal Space - 2hb - (10.91 SQM)	 Student Space (5)	
B00I - R0037 - Movement - (48.8 SQM)	Not Applicable	Circulation or storage space.
B00I - R0038 - Outdoor Learning Area - (94.05 SQM)	Not Applicable	Circulation or storage space.
B00I - R0041 - Home Base - (56.28 SQM) - Teaching Space: 1	 Student Space (26)	
B00I - R0042 - Withdrawal Space - 2hb - (10.55 SQM)	 Student Space (4)	
B00I - R0043 - Withdrawal Space - 2hb - (11.05 SQM)	 Student Space (5)	
B00I - R0045 - Presentation Area - (39.96 SQM)	Not Applicable	Circulation or storage space.
B00I - R0048 - Movement - (25.39 SQM)	Not Applicable	Circulation or storage space.
B00I - R1001 - Home Base - (59.48 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R1002 - Practical Activities - 3hb - (87.46 SQM)	 Student Space (40)	
B00I - R1003 - Practical Activities - (44.29 SQM)	 Student Space (20)	
B00I - R1004 - Seminar/Study - (22.75 SQM)	 Office (5)	
B00I - R1005 - Home Base - (67.58 SQM) - Teaching Space: 1	 Student Space (31)	
B00I - R1006 - Withdrawal Space - 2hb - (9.84 SQM)	 Student Space (4)	
B00I - R1007 - Home Base - (45.57 SQM) - Teaching Space: 1	 Student Space (21)	
B00I - R1009 - Home Base - (71.62 SQM) - Teaching Space: 1	 Student Space (33)	
B00I - R1013 - Movement - (56.3 SQM)	Not Applicable	Circulation or storage space.
B00I - R1021 - Practical Activities - 4hb - (80.47 SQM)	 Student Space (37)	
B00I - R1022 - Movement - (49.2 SQM)	Not Applicable	Circulation or storage space.
B00I - R1023 - Home Base - (61.01 SQM) - Teaching Space: 1	 Student Space (28)	
B00I - R1024 - Withdrawal Space - 2hb - (11.11 SQM)	 Student Space (5)	
B00I - R1025 - Home Base - (67.28 SQM) - Teaching Space: 1	 Student Space (31)	
B00I - R1026 - Seminar/Study - (25.74 SQM)	 Office (6)	
B00I - R1028 - Outdoor Learning Area - (25.02 SQM)	Not Applicable	Circulation or storage space.
B00I - R1032 - Outdoor Learning Area - (27.12 SQM)	Not Applicable	Circulation or storage space.
B00I - R1036 - Presentation Area - (46.04 SQM)	Not Applicable	Circulation or storage space.
B00I - R1038 - Home Base - (50.04 SQM) - Teaching Space: 1	 Student Space (23)	
B00I - R1039 - Outdoor Learning Area - (86.99 SQM)	Not Applicable	Circulation or storage space.
B00I - R1041 - Presentation Area - (44.05 SQM)	Not Applicable	Circulation or storage space.