


VENTILATION AUDIT REPORT

SCHOOL:	Central Sydney Intensive English High School (8288)
AMU REGION:	Sydney
STATE ELECTORATE:	Heffron
LOCAL GOVERNMENT AREA:	Sydney

8288 - Central Sydney Intensive English High School
Site Plan (10935)




















1:427

Printed: 05-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B0AA - R0101 - Entry - (16.53 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0103 - Public Reception - (37.89 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0104 - Administration - Clerical - (58.97 SQM)	Office (14)	
B0AA - R0105 - Movement - (39.6 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0106 - Visitors Office - (10.15 SQM)	Office (2)	
B0AA - R0107 - Tea Room - (5.88 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0110 - Interview/Meeting - (11.8 SQM)	Office (2)	
B0AA - R0111 - Interview/Meeting - (12.18 SQM)	Office (3)	
B0AA - R0112 - Interview/Meeting - (12.18 SQM)	Office (3)	
B0AA - R0113 - Deputy Principal Office - (12.1 SQM)	Office (3)	
B0AA - R0114 - Principal Office - (18.5 SQM)	Office (4)	
B0AA - R0118 - Clinic - (11.85 SQM)	Office (2)	
B0AA - R0119 - Student Reception - (61.3 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0121 - Interview/Office - Type 1 - (15.08 SQM)	Office (3)	
B0AA - R0122 - Movement - (36.41 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0123 - Movement - (23.77 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0130 - Interview/Meeting - (48.7 SQM)	Office (12)	
B0AA - R0131 - General Learning Space - Type 13 - (47.3 SQM) - Teaching Space: 1	Student Space (21)	
B0AA - R0132 - General Learning Space - Type 13 - (46.93 SQM) - Teaching Space: 1	Student Space (21)	
B0AA - R0133 - Movement - (12.31 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0137 - Movement - (28.1 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0141 - Student Canteen - (14.67 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0142 - Gymnasium - (263.26 SQM)	Student Space (122)	
B0AA - R1201 - Movement - (13.44 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1202 - Movement - (154.02 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1205 - General Learning Space - (47.21 SQM) - Teaching Space: 1	Student Space (21)	
B0AA - R1206 - General Learning Space - (48.71 SQM) - Teaching Space: 1	Student Space (22)	
B0AA - R1207 - Computer Room - (48.47 SQM)	Student Space (22)	
B0AA - R1208 - Main Area - (99.58 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1211 - Interview/Meeting - (12.03 SQM)	Office (3)	
B0AA - R1212 - Interview/Meeting - (12.2 SQM)	Office (3)	
B0AA - R1214 - General Learning Space - (49.98 SQM) - Teaching Space: 1	Student Space (23)	
B0AA - R1215 - General Learning Space - (51.23 SQM) - Teaching Space: 1	Student Space (23)	
B0AA - R1225 - General Learning Space - (48.03 SQM) - Teaching Space: 1	Student Space (22)	
B0AA - R1226 - General Learning Space - (48.37 SQM) - Teaching Space: 1	Student Space (22)	
B0AA - R2301 - Movement - (8 SQM)	Not Applicable	Circulation or storage space.
B0AA - R2302 - Movement - (147.39 SQM)	Not Applicable	Circulation or storage space.
B0AA - R2306 - General Learning Space - (46.35 SQM) - Teaching Space: 1	Student Space (21)	
B0AA - R2307 - General Learning Space - (49.33 SQM) - Teaching Space: 1	Student Space (22)	
B0AA - R2308 - General Learning Space - (51.47 SQM) - Teaching Space: 1	Student Space (23)	
B0AA - R2309 - General Learning Space - (46.44 SQM) - Teaching Space: 1	Student Space (21)	
B0AA - R2310 - General Learning Space - (52.34 SQM) - Teaching Space: 1	Student Space (24)	
B0AA - R2311 - General Learning Space - (46.72 SQM) - Teaching Space: 1	Student Space (21)	
B0AA - R2313 - General Learning Space - Type 10 - (72.11 SQM) - Teaching Space: 0.5	Student Space (33)	
B0AA - R2314 - Science Laboratory - (28.56 SQM)	Student Space (13)	
B0AA - R2325 - General Learning Space - Type 10 - (50.09 SQM) - Teaching Space: 0.5	Student Space (23)	
B0AA - R2326 - General Learning Space - (47.69 SQM) - Teaching Space: 1	Student Space (22)	
BOBB - R0106 - Movement - (25.71 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0108 - General Learning Space - (44.81 SQM) - Teaching Space: 1	Student Space (20)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOBB - R0109 - General Learning Space - (40.62 SQM) - Teaching Space: 1	 Student Space (18)	
BOBB - R1201 - Movement - (8.63 SQM)	Not Applicable	Circulation or storage space.
BOBB - R1202 - Movement - (48.59 SQM)	Not Applicable	Circulation or storage space.
BOBB - R1204 - Food Technology L.S. - (69.78 SQM) - Teaching Space: 1	 Student Space (32)	
BOBB - R1205 - Kitchen - Type 1 - (15.73 SQM)	 Student Space (7)	
BOBB - R1208 - Kitchen - Type 2 - (36.95 SQM)	 Student Space (17)	
BOBB - R1211 - Computer Room - (48.45 SQM)	 Student Space (22)	
BOBB - R1212 - Staff Study - (66.23 SQM)	 Office (16)	
BOBB - R1214 - Staff Lounge - (34.87 SQM)	 Office (8)	
BOBB - R1215 - Interview/Meeting - (7.9 SQM)	 Office (1)	
BOBB - R1216 - Staff Lounge - (40.1 SQM)	 Office (10)	
BOBB - R1217 - Staff Study - (59.03 SQM)	 Office (14)	
BOBB - R1218 - Movement - (14.59 SQM)	Not Applicable	Circulation or storage space.
BOBB - R2301 - Movement - (7.49 SQM)	Not Applicable	Circulation or storage space.
BOBB - R2302 - Movement - (67.01 SQM)	Not Applicable	Circulation or storage space.
BOBB - R2304 - General Learning Space - Type 12 - (48.37 SQM) - Teaching Space: 1	 Student Space (22)	
BOBB - R2305 - General Learning Space - Type 12 - (49.09 SQM) - Teaching Space: 1	 Student Space (22)	
BOBB - R2307 - Visual Arts Workshop - (36.98 SQM)	 Student Space (17)	
BOBB - R2308 - Computer Room - (46.59 SQM)	 Student Space (21)	
BOBB - R2309 - General Learning Space - (45.95 SQM) - Teaching Space: 1	 Student Space (21)	
BOBB - R2310 - Staff Study - (25.1 SQM)	 Office (6)	
BOBB - R2314 - Music Learning Space - (79.14 SQM) - Teaching Space: 1	 Student Space (36)	
BOBB - R2315 - Practice/Seminar - (7.8 SQM)	Not Applicable	Circulation or storage space.
BOBB - R2317 - Practice/Seminar - (7.79 SQM)	Not Applicable	Circulation or storage space.