


VENTILATION AUDIT REPORT

SCHOOL:	Cessnock Public School (1542)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Cessnock
LOCAL GOVERNMENT AREA:	Cessnock

1542 - Cessnock Public School
Site Plan (10928)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (120.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Raised Platform - (21.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Communal Space - (75.38 SQM)	● Student Space (34)	
B00A - R0008 - Deputy Principal - (17.67 SQM)	● Office (4)	
B00A - R0009 - Home Base - (47.29 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0010 - Home Base - (47.42 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0011 - Home Base - (47.33 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1002 - Staff Room Annexe - (9.34 SQM)	● Office (2)	
B00A - R1003 - Movement - (107.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Home Base - (49.19 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1005 - Home Base - (48.87 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1006 - Withdrawal Space - 1hb - (17.67 SQM)	● Student Space (8)	
B00A - R1007 - Home Base - (49.07 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1008 - Home Base - (49.02 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1009 - Home Base - (49.04 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0001 - Movement - (59.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (13.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Movement - (9.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Teachers Aide Special Ed - (9.36 SQM)	● Office (2)	
B00C - R0009 - Teachers Aide Special Ed - (10.03 SQM)	● Office (2)	
B00C - R0010 - Teachers Aide Special Ed - (5.2 SQM)	● Office (1)	
B00C - R0011 - Teachers Aide Special Ed - (8.38 SQM)	● Office (2)	
B00D - R0001 - Staff Room - (52.2 SQM)	● Office (13)	
B00D - R0002 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (42.34 SQM) - Teaching Space: 1	● Student Space (19)	
B00E - R0003 - Movement - (18.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (43.09 SQM) - Teaching Space: 1	● Student Space (19)	
B00E - R0005 - Home Base - (42.61 SQM) - Teaching Space: 1	● Student Space (19)	
B00E - R0006 - Communal Space - (91.48 SQM)	● Student Space (42)	
B00E - R0007 - Raised Platform - (8.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Staff Room - (21.12 SQM)	● Office (5)	
B00E - R0010 - Movement - (9.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Deputy Principal - (16.88 SQM)	● Office (4)	
B00E - R0012 - Home Base - (42.15 SQM) - Teaching Space: 1	● Student Space (19)	
B00E - R0013 - Home Base - (42.52 SQM) - Teaching Space: 1	● Student Space (19)	
B00E - R0014 - Home Base - (41.74 SQM) - Teaching Space: 1	● Student Space (19)	
B00F - R0001 - Practical Activities - 1hb - (5.36 SQM)	● Student Space (2)	
B00F - R0004 - Home Base - (87.95 SQM) - Teaching Space: 1	● Student Space (40)	
B00F - R0007 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Practical Activities - 1hb - (12.11 SQM)	● Student Space (5)	
B00G - R0001 - Movement - (11.24 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (112.46 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Reading Area - (225.35 SQM)	● Student Space (104)	
B00H - R0005 - Special Programs Room - (40.95 SQM)	● Student Space (18)	
B00I - R0001 - Movement - (12.48 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Movement - (41.51 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Canteen - (20.16 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Canteen - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Movement - (16.28 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0003 - Movement - (6.91 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Practical Activities - S - 1hb - (12.6 SQM)	● Student Space (5)	
B00K - R0005 - Home Base - S - (33.46 SQM) - Teaching Space: 1	● Student Space (15)	
B00K - R0006 - Movement - (37.01 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Practical Activities - M - 1hb - (12.81 SQM)	● Student Space (5)	
B00K - R0008 - Home Base - M - (33.32 SQM) - Teaching Space: 1	● Student Space (15)	
B00K - R0012 - Staff Kitchen - (11.64 SQM)	● Office (2)	
B00K - R0013 - Practical Activities - 1hb - (22.78 SQM)	● Student Space (10)	
B00K - R0014 - Home Base - (45.91 SQM) - Teaching Space: 1	● Student Space (21)	
B00K - R0015 - Home Base - (45.91 SQM) - Teaching Space: 1	● Student Space (21)	
B00M - R0001 - Entry Vestibule - (17.11 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Duplicating Workroom - (32.42 SQM)	● Office (8)	
B00M - R0003 - Principal - (16.79 SQM)	● Office (4)	
B00M - R0010 - Staff Room - (57.53 SQM)	● Office (14)	
B00M - R0011 - Staff Room Annexe - (26.65 SQM)	● Office (6)	
B00M - R0012 - Deputy Principal - (13.19 SQM)	● Office (3)	
B00M - R0013 - Deputy Principal - (13.04 SQM)	● Office (3)	
B00M - R0014 - Interview - (13.12 SQM)	● Office (3)	
B00M - R0016 - Sick Bay - (8.24 SQM)	● Student Space (3)	
B00M - R0017 - Clerical Office/Workroom - (17.86 SQM)	● Office (4)	
B00M - R0018 - Movement - (38.33 SQM)	Not Applicable	Circulation or storage space.
B00M - R0019 - Movement - (114.86 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Communal Space - (142.86 SQM)	● Student Space (66)	
B00N - R0003 - Movement - (5.49 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Raised Platform - (59.37 SQM)	Not Applicable	Circulation or storage space.
B00N - R0006 - Movement - (15.56 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Canteen - (27.3 SQM)	Not Applicable	Circulation or storage space.