

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Cessnock West Public School (1545)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Cessnock</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Cessnock</b>

1545 - Cessnock West Public School  
Site Plan (12237)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (23.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Home Base - (45.98 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0004 - Home Base - (46.1 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0005 - Movement - (16.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Sick Bay - (9.79 SQM)	● Student Space (4)	
B00A - R0007 - Clerical Office - (23.36 SQM)	● Office (5)	
B00A - R0008 - Duplicating Workroom - (12 SQM)	● Office (3)	
B00A - R0009 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Entry Vestibule - (16.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Principal - (19.05 SQM)	● Office (4)	
B00A - R0013 - Movement - (36.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (13.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Interview - (11.82 SQM)	● Office (2)	
B00A - R0018 - Movement - (9.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Home Base - (47.91 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0022 - Movement - (16.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Home Base - (45.55 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0024 - Home Base - (45.62 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0025 - Movement - (35.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Home Base - (45.61 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1001 - Movement - (17.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Home Base - (45.51 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1003 - Home Base - (50.05 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1004 - Withdrawal Space - 1hb - (12.88 SQM)	● Student Space (5)	
B00A - R1006 - Movement - (36.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Staff Room Annexe - (13.86 SQM)	● Office (3)	
B00A - R1009 - Home Base - (48.66 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1010 - Movement - (16.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Home Base - (45.86 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0001 - Movement - (21.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (21.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (13.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Staff Room - (21.94 SQM)	● Office (5)	
B00C - R0003 - Movement - (8.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Staff Room - (57.4 SQM)	● Office (14)	
B00C - R0007 - Canteen - (38.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Movement - (35.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (16.62 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (16.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Staff Room Annexe - (16.05 SQM)	● Office (4)	
B00E - R0003 - Movement - (17.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (53.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (58.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0009 - Raised Platform - (9.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Communal Space - (82.03 SQM)	● Student Space (38)	
B00E - R0011 - Home Base - (45.24 SQM) - Teaching Space: 1	● Student Space (20)	
B00E - R0012 - Home Base - (45.37 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R1002 - Withdrawal Space - 1hb - (13.77 SQM)	● Student Space (6)	
B00E - R1003 - Movement - (5.38 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1004 - Movement - (52.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R1005 - Withdrawal Space - 1hb - (9.69 SQM)	● Student Space (4)	
B00E - R1006 - Movement - (6.18 SQM)	Not Applicable	Circulation or storage space.
B00E - R1008 - Home Base - (61.78 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R1009 - Home Base - (46.85 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R1010 - Home Base - (47.75 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R0001 - Movement - (30.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (53.7 SQM)	● Student Space (24)	
B00F - R0003 - Home Base - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0020 - Movement - (25.62 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Movement - (100.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0024 - Movement - (29.84 SQM)	Not Applicable	Circulation or storage space.
B00G - R0025 - Movement - (17.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0026 - Reading Area - (221.17 SQM)	● Student Space (102)	
B00G - R0029 - Special Programs Room - (45.91 SQM)	● Student Space (21)	
B00G - R0031 - Movement - (27.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (53.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0002 - Movement - (30.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Home Base - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R0001 - Canteen - (41.66 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Communal Space - (199.86 SQM)	● Student Space (92)	
B00I - R0004 - Communal Space - (62.63 SQM)	● Student Space (29)	
B00I - R0019 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00I - R0020 - Movement - (5.47 SQM)	Not Applicable	Circulation or storage space.