

VENTILATION AUDIT REPORT

SCHOOL:	Charlestown Public School (1550)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Charlestown
LOCAL GOVERNMENT AREA:	Lake Macquarie

Siteplan

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.34 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0004 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Home Base - (66.87 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0009 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Home Base - (66.78 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0013 - Movement - (45.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Deputy Principal - (17.35 SQM)	● Office (4)	
B00A - R0016 - Interview - (12.47 SQM)	● Office (3)	
B00A - R0018 - Duplicating Workroom - (16.9 SQM)	● Office (4)	
B00A - R0022 - Principal - (19.47 SQM)	● Office (4)	
B00A - R0025 - Clerical Office - (18.04 SQM)	● Office (4)	
B00A - R0026 - Entry Vestibule - (13.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (6.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (9.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Staff Room - (66.93 SQM)	● Office (16)	
B00A - R0032 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Home Base - (66.86 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0036 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Home Base - (67.03 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0002 - Home Base - (67.02 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0006 - Home Base - (66.96 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0010 - Home Base - (67.03 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0012 - Movement - (14.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Special Programs Room - (66.87 SQM)	● Student Space (31)	
B00B - R0023 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Home Base - (66.88 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0031 - Reading Area - (151.61 SQM)	● Student Space (70)	
B00C - R0001 - Home Base - (57.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0004 - Movement - (16.57 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (25.51 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Canteen - (26.85 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Movement - (24.94 SQM)	Not Applicable	Circulation or storage space.
B00L - R0019 - Raised Platform - (49.6 SQM)	Not Applicable	Circulation or storage space.
B00L - R0020 - Communal Space - (137.73 SQM)	● Student Space (63)	
B00L - R0021 - Movement - (12.05 SQM)	Not Applicable	Circulation or storage space.
B00L - R0022 - Movement - (12.11 SQM)	Not Applicable	Circulation or storage space.
B00L - R0023 - Movement - (98.95 SQM)	Not Applicable	Circulation or storage space.