

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Chatham High School (8414)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Myall Lakes</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Mid-Coast</b>

8414 - Chatham High School  
Site Plan (12238)



1:1,616

Printed: 17-Apr-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Tiered Learning Area - (64.87 SQM)	Student Space (30)	
B00A - R0005 - Ancillary Staff - (22.39 SQM)	Office (5)	
B00A - R0006 - Principal Office - (19.06 SQM)	Office (4)	
B00A - R0010 - Staff Study - (13 SQM)	Office (3)	
B00A - R0012 - Deputy Principal Office - (13.06 SQM)	Office (3)	
B00A - R0013 - Administration - Clerical - (12.11 SQM)	Office (3)	
B00A - R0014 - Duplicating Workroom - (26.79 SQM)	Office (6)	
B00A - R0016 - Administration - Clerical - (42.55 SQM)	Office (10)	
B00A - R0017 - Movement - (125.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Clinic - Girls - (16.28 SQM)	Office (4)	
B00A - R0021 - Clinic - Boys - (16.28 SQM)	Office (4)	
B00A - R0022 - Deputy Principal Office - (16.27 SQM)	Office (4)	
B00A - R0023 - Interview/Office - Type 1 - (11.67 SQM)	Office (2)	
B00A - R0024 - Special Learning Space - (43.53 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0025 - Movement - (73.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Staff Study - (42.76 SQM)	Office (10)	
B00A - R1005 - General Learning Space - (38.58 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R1008 - Interview/Office - Type 1 - (13.39 SQM)	Office (3)	
B00A - R1009 - General Learning Space - (49.55 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1010 - General Learning Space - (49.55 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1011 - Movement - (172.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - General Learning Space - (49.55 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1017 - General Learning Space - (38.86 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1018 - General Learning Space - (49.41 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1019 - General Learning Space - (42.76 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R9001 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R9004 - Entry - (11.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Darkroom Space - (6.3 SQM)	Office (1)	
B00B - R0006 - Art Learning Space - (62.63 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0007 - Workshop - (61.39 SQM)	Student Space (28)	
B00B - R0008 - Art Learning Space - (62.83 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0010 - Art Learning Space - (62.73 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0011 - Movement - (17.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Staff Study - (22.45 SQM)	Office (5)	
B00B - R0016 - Art Learning Space - (62.77 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0017 - Movement - (128.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Computer Room - (33.47 SQM)	Student Space (15)	
B00B - R0021 - Dark Room - (9.79 SQM)	Office (2)	
B00B - R0023 - Dark Room - (13.44 SQM)	Office (3)	
B00B - R1007 - Music Learning Space - (61.85 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1008 - Practice/Seminar - (28.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R1009 - Movement - (109.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Music Learning Space - (109.26 SQM) - Teaching Space: 1	Student Space (50)	
B00C - R0001 - Audio Visual Workroom - (34.36 SQM)	Student Space (15)	
B00C - R0003 - Entry - (14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Seminar - (13.32 SQM)	Office (3)	
B00C - R0005 - Seminar - (13.36 SQM)	Office (3)	
B00C - R0006 - Main Area - (445.14 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0010 - Workroom - (44.85 SQM)	Office (11)	
B00D - R0005 - General Learning Space - (51.04 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0009 - General Learning Space - (45.42 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0010 - Laboratory L.S. - (90.11 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0011 - Preparation - (25.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Laboratory L.S. - (89.68 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0021 - Computer Learning Space - (64.65 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0024 - Staff Study - (12.55 SQM)	Office (3)	
B00D - R0025 - Staff Study - (45.13 SQM)	Office (11)	
B00D - R0026 - Laboratory L.S. - (89.9 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0027 - Preparation - (38.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0028 - Laboratory L.S. - (90.4 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0030 - Movement - (257.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - General Learning Space - (51.4 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1003 - General Learning Space - (50.38 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1006 - General Learning Space - (58.03 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1008 - General Learning Space - (51.47 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1009 - Staff Study - (77.42 SQM)	Office (19)	
B00D - R1010 - General Learning Space - (38.31 SQM) - Teaching Space: 1	Student Space (17)	
B00D - R1011 - General Learning Space - (45.54 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R1013 - General Learning Space - (51.54 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1020 - General Learning Space - (57.81 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1023 - Staff Study - (18.76 SQM)	Office (4)	
B00D - R1024 - Interview/Office - Type 1 - (12.33 SQM)	Office (3)	
B00D - R1025 - General Learning Space - (51.19 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1026 - General Learning Space - (57.82 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1027 - Movement - (260.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R1028 - General Learning Space - (63.94 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R1029 - Senior Seminar - (36.45 SQM)	Office (9)	
B00D - R1030 - General Learning Space - (52.11 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0002 - Materials Technology L.S. - (103.05 SQM) - Teaching Space: 1	Student Space (47)	
B00F - R0003 - Materials Technology L.S. - (82.21 SQM) - Teaching Space: 1	Student Space (38)	
B00F - R0008 - Movement - (128.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Staff Study - (24.14 SQM)	Office (6)	
B00F - R0010 - Design L.S. - (53.36 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0013 - Design L.S. - (59.61 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0014 - Interview/Office - Type 1 - (9.25 SQM)	Office (2)	
B00F - R0017 - Design L.S. - (52.25 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0020 - Materials Technology L.S. - (73 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0021 - Materials Technology L.S. - (66.75 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0022 - Welding Area - (12.62 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (365.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Student Canteen - (56.15 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Entry - (14.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Staff Study - (18.53 SQM)	Office (4)	
B00H - R0007 - Multi-Purpose Space - (475.21 SQM)	Student Space (220)	
B00H - R0013 - General Assistants - (13.82 SQM)	Office (3)	
B00H - R0016 - Entry - (12.85 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0018 - Stage - (106.48 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Special Learning Space - (59.15 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0002 - Movement - (182.76 SQM)	Not Applicable	Circulation or storage space.
B00I - R0011 - Special Learning Space - (62.3 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0012 - Kitchen - Type 1 - (59.06 SQM)	● Student Space (27)	
B00I - R0013 - Special Learning Space - (60.05 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0019 - Interview/Office - Type 1 - (16.02 SQM)	○ Office (4)	
B00I - R0020 - Staff Study - (21.69 SQM)	○ Office (5)	
B00I - R0023 - Special Learning Space - (52.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R0024 - Special Learning Space - (52.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R0001 - Performance Workspace - (94.21 SQM) - Teaching Space: 1	● Student Space (43)	
B00N - R0003 - General Assistants - (16.98 SQM)	○ Office (4)	
B00P - R0001 - Computer Learning Space - (91.7 SQM) - Teaching Space: 1	● Student Space (42)	
B00P - R0002 - Seminar - Type 2 - (18.72 SQM)	○ Office (4)	
B00Q - R0001 - General Learning Space - (60.24 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0002 - General Learning Space - (60.1 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0003 - Kitchen - Type 1 - (100.85 SQM)	● Student Space (46)	
B00Q - R0006 - Preparation - (27.94 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0008 - Movement - (24.24 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0012 - Seminar - Type 2 - (20.84 SQM)	○ Office (5)	
B00Q - R0014 - General Learning Space - Type 6 - (59.11 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0015 - General Learning Space - Type 7 - (59.89 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0016 - Kitchen - Type 2 - (109.1 SQM)	● Student Space (50)	
B00Q - R1001 - Preparation - (46.13 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1003 - General Learning Space - Type 3 - (61.93 SQM) - Teaching Space: 1	● Student Space (28)	
B00Q - R1004 - General Learning Space - Type 2 - (65.2 SQM) - Teaching Space: 1	● Student Space (30)	
B00Q - R1005 - Science Laboratory - (111.53 SQM)	● Student Space (51)	
B00Q - R1006 - Staff Study - (114.59 SQM)	○ Office (28)	
B00Q - R1007 - Seminar - (20.42 SQM)	○ Office (5)	
B00Q - R1008 - Movement - (9.53 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1009 - Movement - (12.49 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1015 - Staff Lounge - (130.84 SQM)	○ Office (32)	