

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Chatham Public School (4014)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Myall Lakes</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Mid-Coast</b>

4014 - Chatham Public School  
Site Plan (10227)



1:887

Printed: 27-Apr-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (30.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Principal - (21.34 SQM)	Office (5)	
B00A - R0003 - Entry Vestibule - (15.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office - (14.26 SQM)	Office (3)	
B00A - R0007 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Sick Bay - (8.98 SQM)	Student Space (4)	
B00A - R0013 - Duplicating Workroom - (21.16 SQM)	Office (5)	
B00A - R0014 - Staff Room Annexe - (13.01 SQM)	Office (3)	
B00A - R0015 - Movement - (13.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Interview - (9.84 SQM)	Office (2)	
B00A - R0017 - Staff Room Annexe - (13.01 SQM)	Office (3)	
B00A - R1001 - Withdrawal Space - 1hb - (25.24 SQM)	Student Space (11)	
B00A - R1002 - Reading Area - (154.01 SQM)	Student Space (71)	
B00B - R0003 - Special Programs Room - (133.55 SQM)	Student Space (61)	
B00C - R0003 - Movement - (9.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0006 - Practical Activities - 1hb - (18.92 SQM)	Student Space (8)	
B00C - R0007 - Home Base - (53.29 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0009 - Movement - (17.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Home Base - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0012 - Practical Activities - 1hb - (16.31 SQM)	Student Space (7)	
B00C - R0014 - Home Base - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0019 - Staff Kitchen - (10.25 SQM)	Office (2)	
B00C - R0022 - Staff Room - (42.49 SQM)	Office (10)	
B00D - R0003 - Practical Activities - 1hb - (30.98 SQM)	Student Space (14)	
B00D - R0004 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0005 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0001 - Movement - (7.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (66.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Canteen - (31.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (57.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (7.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (86.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Home Base - (57.57 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1004 - Practical Activities - 1hb - (14.64 SQM)	Student Space (6)	
B00E - R1006 - Home Base - (56.95 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1008 - Movement - (13.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R1011 - Home Base - (57.34 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0001 - Home Base - (56.7 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0003 - Practical Activities - 1hb - (19.05 SQM)	Student Space (8)	
B00F - R0005 - Home Base - (56.78 SQM) - Teaching Space: 1	Student Space (26)	
B0AA - R0001 - Communal Space - (145.44 SQM)	Student Space (67)	
B0AA - R0002 - Raised Platform - (59.72 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0016 - Movement - (6.36 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0018 - Movement - (13.01 SQM)	Not Applicable	Circulation or storage space.