

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Chatsworth Island Public School (1553)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Clarence</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Clarence Valley</b>

1553 - Chatsworth Island Public School  
Site Plan (12239)



1:596

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.44 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0002 - Home Base - (57.82 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0003 - Movement - (20.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Entry Vestibule - (11.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Clerical Office/Workroom - (11.09 SQM)	● Office (2)	
B00B - R0004 - Principal - (12.99 SQM)	● Office (3)	
B00B - R0006 - Home Base - (69.69 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R0010 - Withdrawal Space - 1hb - (22.6 SQM)	● Student Space (10)	
B00B - R0011 - Practical Activities - 1hb - (18.84 SQM)	● Student Space (8)	
B00C - R0003 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Staff Kitchen - (10.15 SQM)	● Office (2)	
B00C - R0005 - Withdrawal Space - 1hb - (10.58 SQM)	● Student Space (4)	
B00C - R0009 - Withdrawal Space - 1hb - (16.25 SQM)	● Student Space (7)	
B00C - R0010 - Staff Room - (18.63 SQM)	● Office (4)	
B00C - R0011 - Movement - (13.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Canteen - (13.2 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (22.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (22.01 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Reading Area - (91.78 SQM)	● Student Space (42)	