

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Cherrybrook Public School (4440)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Epping</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Hornsby</b>

4440 - Cherrybrook Public School  
Site Plan (12049)



1:1,465

Printed: 07-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Movement - (48.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Staff Room - (65.77 SQM)	Office (16)	
B00A - R0011 - Staff Room Annexe - (30.11 SQM)	Office (7)	
B00A - R0012 - Interview - (19.46 SQM)	Office (4)	
B00A - R0013 - Interview - (14.92 SQM)	Office (3)	
B00A - R1001 - Home Base - (66.71 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1002 - Home Base - (66.27 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1003 - Movement - (34.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Practical Activities - 1hb - (16.15 SQM)	Student Space (7)	
B00A - R1007 - Home Base - (66.15 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1008 - Home Base - (66.15 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0002 - Entry Vestibule - (16.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Clerical Office - (13.56 SQM)	Office (3)	
B00B - R0004 - Sick Bay - (8.1 SQM)	Student Space (3)	
B00B - R0006 - Duplicating Workroom - (32.67 SQM)	Office (8)	
B00B - R0009 - Deputy Principal - (12.89 SQM)	Office (3)	
B00B - R0011 - Principal - (17.19 SQM)	Office (4)	
B00B - R0012 - Deputy Principal - (12.86 SQM)	Office (3)	
B00B - R0013 - Movement - (21.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Canteen - (27.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Raised Platform - (43.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Communal Space - (197.23 SQM)	Student Space (91)	
B00D - R0001 - Special Programs Room - (43.59 SQM)	Student Space (20)	
B00E - R0003 - Reading Area - (233.74 SQM)	Student Space (108)	
B00E - R0004 - Home Base - (60.73 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0005 - Practical Activities - 1hb - (20.53 SQM)	Student Space (9)	
B00E - R0008 - Withdrawal Space - 1hb - (12.21 SQM)	Student Space (5)	
B00E - R0010 - Home Base - (60.57 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0011 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B00E - R0013 - Practical Activities - 1hb - (20.53 SQM)	Student Space (9)	
B00E - R0014 - Home Base - (60.73 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0015 - Withdrawal Space - 1hb - (12.19 SQM)	Student Space (5)	
B00E - R0019 - Home Base - (60.98 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0020 - Practical Activities - 1hb - (20.62 SQM)	Student Space (9)	
B00F - R0001 - Practical Activities - 1hb - (19.8 SQM)	Student Space (9)	
B00F - R0002 - Home Base - (61.47 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0003 - Withdrawal Space - 1hb - (12.31 SQM)	Student Space (5)	
B00F - R0007 - Practical Activities - 1hb - (19.8 SQM)	Student Space (9)	
B00F - R0008 - Home Base - (61.47 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0009 - Home Base - (67.36 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0010 - Practical Activities - 1hb - (23.17 SQM)	Student Space (10)	
B00G - R0001 - Home Base - (93.51 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R0002 - Home Base - (93.51 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R0015 - Home Base - (97.49 SQM) - Teaching Space: 1	Student Space (45)	
B00I - R0002 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00I - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00K - R0003 - Staff Kitchen - (7.94 SQM)	● Office (1)	
B00K - R0004 - Practical Activities - 1hb - (43.81 SQM)	● Student Space (20)	
B00K - R0005 - Practical Activities - 1hb - (51.87 SQM)	● Student Space (24)	
B00M - R0002 - Practical Activities - 1hb - (19.37 SQM)	● Student Space (8)	
B00M - R0004 - Home Base - (58.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	● Student Space (4)	
B00M - R0006 - Home Base - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0008 - Practical Activities - 1hb - (19.37 SQM)	● Student Space (8)	
B00N - R0002 - Practical Activities - 1hb - (19.37 SQM)	● Student Space (8)	
B00N - R0004 - Home Base - (58.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	● Student Space (4)	
B00N - R0006 - Home Base - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0008 - Practical Activities - 1hb - (19.37 SQM)	● Student Space (8)	
B00O - R0002 - Practical Activities - 1hb - (19.37 SQM)	● Student Space (8)	
B00O - R0004 - Home Base - (58.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00O - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	● Student Space (4)	
B00O - R0006 - Home Base - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00O - R0008 - Practical Activities - 1hb - (19.37 SQM)	● Student Space (8)	
OS 600 15817 - OS 600 15817 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 12292 - OS 601 12292 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12941 - OS 601 12941 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14049 - OS 601 14049 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14894 - OS 601 14894 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14895 - OS 601 14895 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14921 - OS 601 14921 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10717 - OS 602 10717 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11506 - OS 602 11506 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11759 - OS 602 11759 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15370 - OS 602 15370 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16147 - OS 602 16147 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19002 - OS 606 19002 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19003 - OS 606 19003 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19090 - OS 606 19090 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19580 - OS 606 19580 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19603 - OS 606 19603 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19611 - OS 606 19611 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19736 - OS 606 19736 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	