


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Cherrybrook Technology High School (8592)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Epping</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Hornsby</b>

8592 - Cherrybrook Technology High School  
Site Plan (10445)



1:1,918

Printed: 24-Jun-2021

## Ventilation Audit Key







Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Computer Learning Space - (60.32 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0008 - Computer Learning Space - (60.3 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0014 - General Learning Space - (57.91 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0015 - General Learning Space - (58.23 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0016 - General Learning Space - (57.96 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0018 - General Learning Space - (63.43 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0019 - General Learning Space - (63.34 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0021 - General Learning Space - (58.22 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0022 - General Learning Space - (57.9 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0023 - General Learning Space - (58.13 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0026 - General Learning Space - (66.32 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0028 - Seminar - Type 1 - (27.92 SQM)	Office (6)	
B00A - R0031 - Movement - (30.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Seminar - Type 1 - (27.92 SQM)	Office (6)	
B00A - R0037 - General Learning Space - (66.15 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0038 - Movement - (9.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Shared Learning Space - (71.99 SQM)	Student Space (33)	
B00A - R0040 - Movement - (14.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Movement - (14.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Computer Learning Space - (71.94 SQM) - Teaching Space: 1	Student Space (33)	
B00A - R0043 - Movement - (9.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R9001 - Public Entry - (17.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R9013 - Principal Office - (24.36 SQM)	Office (6)	
B00A - R9020 - Interview/Meeting - (16.95 SQM)	Office (4)	
B00A - R9021 - Interview/Meeting - (13.98 SQM)	Office (3)	
B00A - R9023 - Movement - (33.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R9026 - Clinic - (13.21 SQM)	Office (3)	
B00A - R9027 - Interview/Office - Type 1 - (13.2 SQM)	Office (3)	
B00A - R9028 - Interview/Office - Type 1 - (12.53 SQM)	Office (3)	
B00A - R9030 - Interview/Office - Type 1 - (13.28 SQM)	Office (3)	
B00A - R9031 - Interview/Office - Type 1 - (13.21 SQM)	Office (3)	
B00A - R9032 - Tea Room - (12.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R9046 - General Learning Space - (58.77 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R9048 - Administration - Clerical - (109.47 SQM)	Office (27)	
B00A - R9049 - Movement - (71.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R9050 - Administration - Executive - (12.69 SQM)	Office (3)	
B00A - R9051 - Interview/Office - Type 1 - (12.76 SQM)	Office (3)	
B00A - R9052 - Deputy Principal Office - (13.76 SQM)	Office (3)	
B00A - R9053 - Interview/Meeting - (34.11 SQM)	Office (8)	
B00A - R9055 - Staff Study - (109.18 SQM)	Office (27)	
B00A - R9056 - Tea Room - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R9058 - Ancillary Staff - (16.77 SQM)	Office (4)	
B00A - R9062 - Public Reception - (37.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R9064 - Deputy Principal Office - (14.12 SQM)	Office (3)	
B00A - R9065 - Deputy Principal Office - (17.65 SQM)	Office (4)	
B00A - R9068 - General Learning Space - (66.31 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R9069 - Administration - Executive - (10.06 SQM)	Office (2)	
B00A - R9070 - Seminar - Type 1 - (14.03 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R9071 - Deputy Principal Office - (8.55 SQM)	Office (2)	
B00A - R9073 - Student Reception - (20.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R9074 - Movement - (50.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (15.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (12.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (34.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - General Assistants - (14.64 SQM)	Office (3)	
B00B - R0021 - Tiered Learning Area - (36.38 SQM)	Student Space (16)	
B00B - R0026 - Practice/Seminar - (16.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Practice/Seminar - (7.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Staff Study - (37.76 SQM)	Office (9)	
B00B - R9001 - Movement - (20.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R9007 - Fitness Laboratory - (58.66 SQM)	Student Space (27)	
B00B - R9008 - Movement - (13.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R9016 - Movement - (86.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R9019 - Stage - (92.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R9023 - Movement - (11.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R9026 - Staff Kitchen - (17.47 SQM)	Office (4)	
B00B - R9033 - Movement - (11.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R9039 - Tiered Learning Area - (55.3 SQM)	Student Space (25)	
B00B - R9040 - Multi-Purpose Space - (633.94 SQM)	Student Space (294)	
B00C - R0008 - Performance Workshop - (131.9 SQM)	Student Space (61)	
B00C - R9001 - Performance Workshop - (135.78 SQM)	Student Space (62)	
B00D - R0002 - General Learning Space - (49.81 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0003 - Seminar - (24.61 SQM)	Office (6)	
B00D - R0004 - General Learning Space - (49.7 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0005 - General Learning Space - (49.37 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0008 - General Learning Space - (49.87 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0009 - Food/Research Space - (48.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Food Technology L.S. - (113.92 SQM) - Teaching Space: 1	Student Space (52)	
B00D - R0018 - Kitchen - Type 1 - (111.6 SQM)	Student Space (51)	
B00D - R0022 - Student Canteen - (58.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - General Learning Space - (49.58 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0026 - Seminar - Type 1 - (23.6 SQM)	Office (5)	
B00D - R0028 - General Learning Space - (49.45 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0029 - General Learning Space - (49.6 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0030 - General Learning Space - (48.98 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0031 - Seminar - Type 1 - (23.53 SQM)	Office (5)	
B00D - R0033 - General Learning Space - (49.7 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0036 - Computer Learning Space - (74.77 SQM) - Teaching Space: 1	Student Space (34)	
B00D - R0040 - Movement - (122.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0041 - Movement - (10.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0042 - Preparation - (24.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R9002 - Senior Study - (46.85 SQM)	Office (11)	
B00D - R9003 - Design/Technology L.S. - (60.83 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R9004 - Music Learning Space - (60.44 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R9006 - Practice/Seminar - (27.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R9007 - Music Learning Space - (75.78 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R9008 - Practice/Seminar - (13.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R9009 - Practice/Seminar - (14.02 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0001 - General Learning Space - (49.73 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0002 - General Learning Space - (49.48 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0003 - General Learning Space - (59.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0007 - General Learning Space - (49.62 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0015 - Study Space - (13.73 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - General Learning Space - (47.17 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0018 - General Learning Space - (49.48 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0019 - General Learning Space - (49.12 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0022 - General Learning Space - (49.23 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0023 - General Learning Space - (49.5 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0034 - Seminar - (20.83 SQM)	● Office (5)	
B00E - R0035 - Seminar - (20.62 SQM)	● Office (5)	
B00E - R0038 - Movement - (20.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0039 - Seminar/Study - (20.6 SQM)	● Office (5)	
B00E - R0040 - Seminar/Study - (20.57 SQM)	● Office (5)	
B00E - R0041 - Seminar/Study - (20.63 SQM)	● Office (5)	
B00E - R0042 - Seminar/Study - (29.12 SQM)	● Office (7)	
B00E - R0043 - Main Area - (439.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R9002 - Staff Kitchen - (17.42 SQM)	● Office (4)	
B00E - R9008 - Coffee Kiosk - (36.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R9009 - Commonroom - (76.86 SQM)	● Office (19)	
B00E - R9014 - Staff Study - (372.41 SQM)	● Office (93)	
B00F - R0002 - Design/Technology L.S. - (76.08 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0014 - Dark Room - (32.12 SQM)	● Office (8)	
B00F - R9009 - Computer Learning Space - (56.57 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R9019 - Design/Technology L.S. - (54.08 SQM) - Teaching Space: 1	● Student Space (25)	
B00G - R0009 - Multi Media Workshop - (69.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Laboratory L.S. - (89 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0022 - Laboratory L.S. - (89.48 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0023 - Laboratory L.S. - (89.46 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0024 - Laboratory L.S. - (89.07 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0025 - Laboratory L.S. - (89.81 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0034 - Movement - (13.71 SQM)	Not Applicable	Circulation or storage space.
B00G - R0035 - Preparation - Science - (72.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0036 - Movement - (14.93 SQM)	Not Applicable	Circulation or storage space.
B00G - R0041 - Movement - (87.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0042 - General Learning Space - (63.72 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R0043 - Science Laboratory - (93.48 SQM)	● Student Space (43)	
B00G - R0044 - Science Laboratory - (90.57 SQM)	● Student Space (42)	
B00G - R0045 - General Learning Space - (56.55 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0046 - Staff Lounge - (50.24 SQM)	● Office (12)	
B00G - R0048 - General Learning Space - (56.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0049 - Movement - (14.29 SQM)	Not Applicable	Circulation or storage space.
B00G - R0050 - General Learning Space - (67.1 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R9001 - Design L.S. - (94.64 SQM) - Teaching Space: 1	● Student Space (43)	
B00G - R9003 - Materials Workshop - Type 2 - (68.28 SQM)	● Student Space (31)	
B00G - R9005 - Materials Technology L.S. - (109.65 SQM) - Teaching Space: 1	● Student Space (50)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R9006 - Wood Technology Bay - (53.68 SQM)	Not Applicable	Circulation or storage space.
B00G - R9007 - Materials Technology L.S. - (109.73 SQM) - Teaching Space: 1	● Student Space (50)	
B00G - R9015 - Materials Workshop - Type 2 - (73.81 SQM)	● Student Space (34)	
B00H - R0005 - General Learning Space - (60.32 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0001 - Staff Lounge - (61.98 SQM)	○ Office (15)	
B00K - R0002 - Staff Study - (11.19 SQM)	○ Office (2)	
B00K - R0003 - Staff Kitchen - (19.47 SQM)	○ Office (4)	
B00K - R0004 - Staff Study - (62.88 SQM)	○ Office (15)	
B00K - R1001 - Staff Lounge - (64.5 SQM)	○ Office (16)	
B00K - R1002 - Staff Study - (11.4 SQM)	○ Office (2)	
B00K - R1003 - Staff Kitchen - (19.66 SQM)	○ Office (4)	
B00K - R1004 - Staff Study - (65.02 SQM)	○ Office (16)	
B0JJ - R0001 - General Learning Space - (60.56 SQM) - Teaching Space: 1	● Student Space (28)	
B0JJ - R0002 - General Learning Space - (61.75 SQM) - Teaching Space: 1	● Student Space (28)	
B0JJ - R0003 - General Learning Space - (58.88 SQM) - Teaching Space: 1	● Student Space (27)	
B0JJ - R0004 - General Learning Space - (60.54 SQM) - Teaching Space: 1	● Student Space (28)	
B0JJ - R0005 - Seminar - Type 1 - (12.93 SQM)	○ Office (3)	
B0JJ - R0006 - Seminar - Type 1 - (13.2 SQM)	○ Office (3)	
B0JJ - R0007 - Shared Learning Space - (113.05 SQM)	● Student Space (52)	
B0JJ - R0013 - General Learning Space - (61.98 SQM) - Teaching Space: 1	● Student Space (28)	
B0JJ - R0014 - General Learning Space - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B0JJ - R0015 - General Learning Space - (63.27 SQM) - Teaching Space: 1	● Student Space (29)	
B0JJ - R0016 - General Learning Space - (57.84 SQM) - Teaching Space: 1	● Student Space (26)	
B0JJ - R0017 - General Learning Space - (61.97 SQM) - Teaching Space: 1	● Student Space (28)	
B0JJ - R0018 - General Learning Space - (59.41 SQM) - Teaching Space: 1	● Student Space (27)	
B0JJ - R0019 - General Learning Space - (59.71 SQM) - Teaching Space: 1	● Student Space (27)	
B0JJ - R0020 - General Learning Space - (65.49 SQM) - Teaching Space: 1	● Student Space (30)	
B0JJ - R0021 - Practical Activities - (13.2 SQM)	● Student Space (6)	
B0JJ - R1001 - General Learning Space - (60.05 SQM) - Teaching Space: 1	● Student Space (27)	
B0JJ - R1002 - General Learning Space - (62.92 SQM) - Teaching Space: 1	● Student Space (29)	
B0JJ - R1006 - Visual Arts Workshop - (73.64 SQM)	● Student Space (34)	
B0JJ - R1007 - Visual Arts Workshop - (72.71 SQM)	● Student Space (33)	
B0JJ - R1008 - Visual Arts Workshop - (72.71 SQM)	● Student Space (33)	
B0JJ - R1014 - General Learning Space - (62.77 SQM) - Teaching Space: 1	● Student Space (29)	
B0JJ - R1015 - General Learning Space - (60.9 SQM) - Teaching Space: 1	● Student Space (28)	
B0JJ - R1016 - Seminar - Type 1 - (11.49 SQM)	○ Office (2)	
B0JJ - R1017 - Practical Activity Area - (11.54 SQM)	● Student Space (5)	
B0JJ - R1018 - Multi Media Workshop - (100.14 SQM)	Not Applicable	Circulation or storage space.
B0JJ - R1020 - Multi Media Studio - (10.71 SQM)	Not Applicable	Circulation or storage space.
B0JJ - R1022 - General Learning Space - (62.94 SQM) - Teaching Space: 1	● Student Space (29)	
B0JJ - R1023 - General Learning Space - (61.75 SQM) - Teaching Space: 1	● Student Space (28)	
B0JJ - R1024 - General Learning Space - (64.89 SQM) - Teaching Space: 1	● Student Space (30)	
NS 110 14006 - NS 110 14006 - Learning Unit - Single Secondary/Secure - (57 SQM)	● Student Space (26)	
NS 110 15240 - NS 110 15240 - Learning Unit - Single Secondary/Secure - (57 SQM)	● Student Space (26)	
NS 111 14825 - NS 111 14825 - Learning Unit - Double Secondary/Secure - (114 SQM)	● Student Space (52)	
NS 200 10892 - NS 200 10892 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
NS 210 13181 - NS 210 13181 - Home Science/Preparation Area/Laundry - (95 SQM)	 Office (23)	
NS 210 16259 - NS 210 16259 - Home Science/Preparation Area/Laundry - (95 SQM)	 Office (23)	
NS 220 13192 - NS 220 13192 - Science Learning/Preparation Space - (95 SQM)	Not Applicable	Circulation or storage space.
NS 220 13193 - NS 220 13193 - Science Learning/Preparation Space - (95 SQM)	Not Applicable	Circulation or storage space.
NS 270 13187 - NS 270 13187 - Metal Technics/Heat Area/Storage - (95 SQM)	 Student Space (44)	
OS 600 13406 - OS 600 13406 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 14882 - OS 600 14882 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 15889 - OS 600 15889 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 720 10592 - OS 720 10592 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 13064 - OS 720 13064 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 13125 - OS 720 13125 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 15412 - OS 720 15412 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 760 10952 - OS 760 10952 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.