

VENTILATION AUDIT REPORT

SCHOOL:	Chertsey Public School (4398)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Terrigal
LOCAL GOVERNMENT AREA:	Central Coast

4398 - Chertsey Public School
Site Plan (11564)



1:927

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (81.15 SQM) - Teaching Space: 1	● Student Space (37)	
B00A - R0002 - Home Base - (53.76 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0003 - Movement - (5.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Interview - (12.93 SQM)	● Office (3)	
B00A - R0007 - Clerical Office - (12.5 SQM)	● Office (3)	
B00A - R0008 - Duplicating Workroom - (26.22 SQM)	● Office (6)	
B00A - R0011 - Principal - (19.79 SQM)	● Office (4)	
B00A - R0014 - Deputy Principal - (14.09 SQM)	● Office (3)	
B00A - R0015 - Movement - (27.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Staff Room - (58.02 SQM)	● Office (14)	
B00B - R0001 - Movement - (25.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (15.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (25.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (87.37 SQM) - Teaching Space: 1	● Student Space (40)	
B00B - R0009 - Home Base - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0001 - Movement - (25.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (15.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Movement - (25.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Home Base - (87.6 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0009 - Home Base - (58.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0001 - Movement - (11.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (5.6 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Raised Platform - (44.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (6.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (44.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Communal Space - (158.65 SQM)	● Student Space (73)	
B00D - R0014 - Movement - (58.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Movement - (10.85 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (58.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0004 - Home Base - (59.64 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0006 - Interview - (8.75 SQM)	● Office (2)	
B00G - R0008 - Home Base - (59.51 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0013 - Home Base - (59.72 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0014 - Movement - (40.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R9010 - Canteen - (32.36 SQM)	Not Applicable	Circulation or storage space.
B00G - R9011 - Movement - (74.27 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (15.13 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Movement - (10.22 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Movement - (8.34 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Reading Area - (167.17 SQM)	● Student Space (77)	
B00J - R0009 - Movement - (55.64 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - Home Base - (60.45 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R1002 - Home Base - (60.6 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R1003 - Practical Activities - 1hb - (19.91 SQM)	● Student Space (9)	
B00J - R1004 - Practical Activities - 1hb - (19.68 SQM)	● Student Space (9)	
B00J - R1005 - Withdrawal Space - 2hb - (11.62 SQM)	● Student Space (5)	
B00J - R1008 - Special Programs Room - (39.97 SQM)	● Student Space (18)	
B00J - R1010 - Movement - (51.63 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Practical Activities - 1hb - (17.36 SQM)	● Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0002 - Withdrawal Space - 1hb - (9.1 SQM)	● Student Space (4)	
B00L - R0004 - Home Base - (58.05 SQM) - Teaching Space: 1	● Student Space (26)	
B00L - R0006 - Practical Activities - 1hb - (15.69 SQM)	● Student Space (7)	
B00L - R0007 - Withdrawal Space - 2hb - (11.54 SQM)	● Student Space (5)	
B00L - R0008 - Home Base - (60.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0011 - Practical Activities - 1hb - (14.87 SQM)	● Student Space (6)	
B00L - R0014 - Home Base - (60.3 SQM) - Teaching Space: 1	● Student Space (27)	