

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Chester Hill North Public School (3981)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Bankstown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canterbury-Bankstown</b>

3981 - Chester Hill North Public School  
Site Plan (12240)



1:1,274

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Movement - (12.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Canteen - (28.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (50.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (52.19 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0010 - Home Base - (51.98 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0011 - Home Base - (52.05 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0017 - Home Base - (52.2 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0019 - Staff Study - (10.76 SQM)	● Office (2)	
B00B - R0020 - Staff Study - (8.07 SQM)	● Office (2)	
B00B - R0025 - Staff Study - (18.68 SQM)	● Office (4)	
B00B - R0028 - Home Base - (64.97 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0029 - Home Base - (64.97 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0030 - Movement - (7.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Communal Space - (123.26 SQM)	● Student Space (57)	
B00B - R0036 - Stage - (32.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0039 - Movement - (25.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0040 - Movement - (91.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Movement - (43.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0042 - Movement - (18.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Home Base - (51.98 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1007 - Special Programs Room - (51.91 SQM)	● Student Space (24)	
B00B - R1008 - Special Programs Room - (52.13 SQM)	● Student Space (24)	
B00B - R1014 - Home Base - (51.77 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1019 - Home Base - (51.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1025 - Home Base - (52.27 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1027 - Movement - (158.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R1031 - Clerical Office/Workroom - (25.49 SQM)	● Office (6)	
B00B - R1032 - Reading Area - (153.53 SQM)	● Student Space (71)	
B00B - R1038 - Special Programs Room - (8.81 SQM)	● Student Space (4)	
B00C - R0002 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (5.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Home Base - (56.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0010 - Home Base - (56.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0015 - Home Base - (57.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0024 - Practical Activities/Movement - 2hb - (15.95 SQM)	● Student Space (7)	
B00D - R0004 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Seminar/Study - (56.85 SQM)	● Office (14)	
B00E - R0004 - Home Base - (55.92 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0005 - Home Base - (57.19 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0009 - Deputy Principal - (16.82 SQM)	● Office (4)	
B00E - R0010 - Clerical Office - (17.03 SQM)	● Office (4)	
B00E - R0012 - Entry Vestibule - (15.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Deputy Principal - (10.69 SQM)	● Office (2)	
B00E - R0015 - Sick Bay - (8.54 SQM)	● Student Space (3)	
B00E - R0016 - Duplicating Workroom - (21.36 SQM)	● Office (5)	
B00E - R0018 - Principal - (15.32 SQM)	● Office (3)	
B00E - R0023 - Movement - (9.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Home Base - (56.33 SQM) - Teaching Space: 1	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1004 - Home Base - (56.4 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1009 - Home Base - (57.19 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1010 - Home Base - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1015 - Movement - (92.57 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Movement - (7.84 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (9.26 SQM)	Not Applicable	Circulation or storage space.
B00F - R0025 - Home Base - Pre - (64.81 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0026 - Home Base - Pre - (64.54 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R0027 - Staff Room - (64.72 SQM)	● Office (16)	
B00F - R0028 - Home Base - Pre - (63.96 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R0003 - Movement - (8.29 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Staff Room - (64.26 SQM)	● Office (16)	
B00G - R0007 - Staff Room - (69.78 SQM)	● Office (17)	
B00G - R0009 - Seminar/Study - (11.4 SQM)	● Office (2)	
B00G - R0011 - Movement - (15.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Staff Room - (20.69 SQM)	● Office (5)	
B00G - R0022 - Staff Room - (17.19 SQM)	● Office (4)	
B00G - R0032 - Clerical Office - (14.96 SQM)	● Office (3)	
B00G - R0033 - Seminar/Study - (89.55 SQM)	● Office (22)	
B00G - R0035 - Clerical Office - (12.19 SQM)	● Office (3)	
B00G - R0036 - Interview/Office - Type 3 - (29.43 SQM)	● Office (7)	
B00G - R0037 - Clerical Office - (13.56 SQM)	● Office (3)	
B00G - R0038 - Clerical Office - (23.93 SQM)	● Office (5)	
B00I - R0002 - Communal Space - (204.99 SQM)	● Student Space (95)	
B00I - R0006 - Staff Kitchen - (6.06 SQM)	● Office (1)	
B00I - R0011 - Movement - (13.57 SQM)	Not Applicable	Circulation or storage space.
B00I - R0012 - Raised Platform - (60.48 SQM)	Not Applicable	Circulation or storage space.
B00I - R0013 - Movement - (12.84 SQM)	Not Applicable	Circulation or storage space.
B00I - R0014 - Movement - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (6.24 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Special Programs Room - (33.17 SQM)	● Student Space (15)	
B00L - R0006 - Special Programs Room - (42.73 SQM)	● Student Space (19)	