

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Chifley College Dunheved Campus (8488)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Londonderry</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Penrith</b>

8488 - Chifley College Dunheved Campus  
Site Plan (10342)



1:1,664

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Study - (25.82 SQM)	Office (6)	
B00A - R0002 - Performance Workspace - (82.18 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R0007 - Leading Teacher - (16.2 SQM)	Office (4)	
B00A - R0008 - Leading Teacher - (20.25 SQM)	Office (5)	
B00A - R0010 - Administration - Clerical - (33.35 SQM)	Office (8)	
B00A - R0011 - Deputy Principal Office - (19.62 SQM)	Office (4)	
B00A - R0012 - Principal Office - (23.09 SQM)	Office (5)	
B00A - R0017 - Interview/Office - Type 1 - (9.73 SQM)	Office (2)	
B00A - R0018 - Administration - Clerical - (9.33 SQM)	Office (2)	
B00A - R0019 - Clinic - Boys - (14.08 SQM)	Office (3)	
B00A - R0021 - Staff Study - (76.75 SQM)	Office (19)	
B00A - R0024 - Movement - (30.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (77.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (56.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (53.59 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1002 - General Learning Space - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1003 - Staff Study - (22.2 SQM)	Office (5)	
B00A - R1006 - General Learning Space - (59.86 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1007 - General Learning Space - (60.01 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1008 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - General Learning Space - (40.31 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1011 - Staff Study - (40.86 SQM)	Office (10)	
B00A - R1014 - Computer Learning Space - (40.65 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1015 - Movement - (56.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Movement - (45.09 SQM)	Not Applicable	Circulation or storage space.
B00B - M1001 - Main Area - (128.46 SQM)	Not Applicable	Circulation or storage space.
B00B - M1002 - Seminar - (24.07 SQM)	Office (6)	
B00B - M1003 - Seminar - (23.88 SQM)	Office (5)	
B00B - M1004 - Audio Visual Workroom - (21.91 SQM)	Student Space (10)	
B00B - R0001 - Laboratory L.S. - (91.54 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0002 - Preparation - (49.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Laboratory L.S. - (91.54 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0004 - Laboratory L.S. - (91.35 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0005 - Preparation - (49.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Laboratory L.S. - (91.34 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0009 - Movement - (58.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (69.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Seminar - (12.96 SQM)	Office (3)	
B00B - R1002 - Seminar - (14.55 SQM)	Office (3)	
B00B - R1006 - Seminar - (13.73 SQM)	Office (3)	
B00B - R1007 - Seminar - (14.75 SQM)	Office (3)	
B00B - R1008 - Seminar - (12.82 SQM)	Office (3)	
B00B - R1011 - Entry - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - Workroom - (12.92 SQM)	Office (3)	
B00B - R1016 - Audio Visual Workroom - (35.09 SQM)	Student Space (16)	
B00B - R1018 - Movement - (82.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R1020 - Main Area - (370.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Food Technology L.S. - (82.21 SQM) - Teaching Space: 1	Student Space (38)	
B00C - R0004 - Food Technology L.S. - (82.12 SQM) - Teaching Space: 1	Student Space (38)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0007 - Staff Study - (20.9 SQM)	Office (5)	
B00C - R0008 - Staff Study - (65.58 SQM)	Office (16)	
B00C - R0016 - Movement - (74.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (32.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Food/Research Space - (22.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Staff Study - (61.31 SQM)	Office (15)	
B00C - R1007 - Music Learning Space - (65.12 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1009 - Music Learning Space - (65.84 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1011 - Art Learning Space - (65.53 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1012 - Art Learning Space - (69.06 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R1016 - Movement - (14.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R1018 - Art Learning Space - (85.52 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R1019 - Movement - (58.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R1021 - Darkroom Space - (28.85 SQM)	Office (7)	
B00D - R0004 - Student Canteen - (60.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Movement - (74.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Multi-Purpose Space - (309.02 SQM)	Student Space (143)	
B00D - R0014 - Movement - (71.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (24.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R1007 - Movement - (66.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R1008 - Movement - (42.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - General Learning Space - (67.04 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R0015 - Movement - (80.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Gymnasium - (131.99 SQM)	Student Space (61)	
B00E - R0021 - Welding/Hot Metals Area - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Materials Technology L.S. - (115.78 SQM) - Teaching Space: 1	Student Space (53)	
B00E - R0024 - Movement - (29.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Wood Technology Bay - (82.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Wood Technology Bay - (82.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R1006 - Design L.S. - (52.88 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1007 - Staff Study - (25.83 SQM)	Office (6)	
B00E - R1008 - Computer Learning Space - (51.78 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1012 - Movement - (52.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R1013 - Movement - (66.59 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Laboratory L.S. - (90.47 SQM) - Teaching Space: 1	Student Space (41)	
B00F - R0002 - Preparation - (48.58 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Laboratory L.S. - (90.47 SQM) - Teaching Space: 1	Student Space (41)	
B00F - R0007 - Movement - (68.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Laboratory L.S. - (90.54 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R1002 - Preparation - (48.62 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Laboratory L.S. - (90.55 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R1006 - General Assistants - (10.9 SQM)	Office (2)	
B00F - R1008 - Movement - (64.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Duplicating Workroom - (32.34 SQM)	Office (8)	
B00G - R0006 - Staff Study - (10.61 SQM)	Office (2)	
B00G - R0008 - Staff Study - (23.52 SQM)	Office (5)	
B00G - R0009 - Staff Study - (27.39 SQM)	Office (6)	
B00G - R0012 - General Learning Space - (52.35 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0013 - General Learning Space - (52.36 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0014 - Staff Study - (24.66 SQM)	Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0015 - General Learning Space - (53.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0018 - General Learning Space - (53.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0019 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0023 - Movement - (77.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R0024 - Movement - (61.09 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Movement - (13.06 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Staff Study - (39.73 SQM)	● Office (9)	
B00G - R1005 - General Learning Space - (54.7 SQM) - Teaching Space: 1	● Student Space (25)	
B00G - R1006 - General Learning Space - (54.55 SQM) - Teaching Space: 1	● Student Space (25)	
B00G - R1007 - Movement - (18.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R1008 - General Learning Space - (54.18 SQM) - Teaching Space: 1	● Student Space (25)	
B00G - R1009 - General Learning Space - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1010 - Interview/Office - Type 1 - (18.37 SQM)	● Office (4)	
B00G - R1011 - General Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1012 - General Learning Space - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1014 - General Learning Space - (53.02 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1015 - Movement - (27.66 SQM)	Not Applicable	Circulation or storage space.
B00G - R1018 - Movement - (67.52 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Interview/Office - Type 1 - (10.77 SQM)	● Office (2)	
B00H - R0008 - Staff Study - (49.32 SQM)	● Office (12)	
B00H - R0010 - General Learning Space - (52.57 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0011 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0012 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0013 - General Learning Space - (37.61 SQM) - Teaching Space: 1	● Student Space (17)	
B00H - R0014 - General Learning Space - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0015 - Computer Learning Space - (53.09 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0016 - Movement - (88.08 SQM)	Not Applicable	Circulation or storage space.
B00H - R0019 - Movement - (56.01 SQM)	Not Applicable	Circulation or storage space.
B00H - R1001 - General Learning Space - (53.25 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R1002 - General Learning Space - (54.34 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R1003 - Movement - (18.8 SQM)	Not Applicable	Circulation or storage space.
B00H - R1004 - Staff Study - (18.27 SQM)	● Office (4)	
B00H - R1005 - General Learning Space - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R1006 - General Learning Space - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R1008 - General Learning Space - (53.03 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R1009 - Staff Study - (40.96 SQM)	● Office (10)	
B00H - R1013 - General Learning Space - (54.86 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R1014 - General Learning Space - (54.77 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R1015 - Movement - (26.59 SQM)	Not Applicable	Circulation or storage space.
B00H - R1018 - Movement - (50.2 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Gymnasium - (463.53 SQM)	● Student Space (215)	
B00J - R0002 - Movement - (11.22 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Movement - (11.19 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Movement - (15.94 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Computer Room - (92.01 SQM)	● Student Space (42)	
B00O - R0002 - Seminar - (19.09 SQM)	● Office (4)	