

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Chifley College Mount DrUITt Campus (8459)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Mount DrUITt</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blacktown</b>

8459 - Chifley College Mount DrUITt Campus  
Site Plan (12942)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Laboratory L.S. - (81.59 SQM) - Teaching Space: 1	● Student Space (37)	
B00A - R0003 - Preparation - (29.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Laboratory L.S. - (88.92 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R0009 - Staff Study - (24.6 SQM)	● Office (6)	
B00A - R0013 - General Learning Space - (57.62 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0014 - Deputy Principal Office - (23.37 SQM)	● Office (5)	
B00A - R0015 - Administration - Clerical - (7.81 SQM)	● Office (1)	
B00A - R0016 - Administration - Clerical - (12.64 SQM)	● Office (3)	
B00A - R0019 - Principal Office - (18.81 SQM)	● Office (4)	
B00A - R0020 - Pupil Entry - (8.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Administration - Clerical - (12 SQM)	● Office (3)	
B00A - R0027 - Commonroom - (30.97 SQM)	● Office (7)	
B00A - R0028 - Staff Study - (11.32 SQM)	● Office (2)	
B00A - R0029 - Staff Study - (12.04 SQM)	● Office (3)	
B00A - R0030 - Staff Study - (37.83 SQM)	● Office (9)	
B00A - R0031 - Movement - (361.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Administration - Clerical - (32.63 SQM)	● Office (8)	
B00A - R0036 - Entry - (33.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Commonroom - (137.07 SQM)	● Office (34)	
B00A - R1002 - General Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1003 - General Learning Space - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1007 - General Learning Space - (51.21 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1010 - Computer Learning Space - (71.46 SQM) - Teaching Space: 1	● Student Space (33)	
B00A - R1013 - General Learning Space - (65.28 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1014 - General Learning Space - (52.22 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1017 - General Learning Space - (57.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1018 - Leading Teacher - (12.72 SQM)	● Office (3)	
B00A - R1020 - General Learning Space - (51.35 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1023 - Movement - (171.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Design L.S. - (49.92 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0007 - Staff Study - (31.53 SQM)	● Office (7)	
B00B - R0008 - Staff Study - (25.75 SQM)	● Office (6)	
B00B - R0009 - Food Technology L.S. - (78.7 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0010 - Food/Research Space - (12.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Food/Research Space - (12.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Food Technology L.S. - (76.62 SQM) - Teaching Space: 1	● Student Space (35)	
B00B - R0019 - Music Learning Space - (51 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0027 - Movement - (174.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Food Technology L.S. - (84.27 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R0029 - Preparation - Materials - (25.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Materials Workshop - Type 2 - (32.05 SQM)	● Student Space (14)	
B00B - R0033 - Metal Technology L.S. - (103.03 SQM) - Teaching Space: 1	● Student Space (47)	
B00B - R0034 - Welding/Hot Metals Area - (7.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Materials Technology L.S. - (57.66 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1009 - Music Learning Space - (51 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1012 - Art Learning Space - (57.66 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1015 - Art Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1016 - Art Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1019 - Darkroom Space - (12.33 SQM)	Office (3)	
B00B - R1020 - Staff Study - (31.34 SQM)	Office (7)	
B00B - R1025 - Movement - (179.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R1026 - Darkroom Space - (28.95 SQM)	Office (7)	
B00B - R1027 - Art Learning Space - (33.63 SQM) - Teaching Space: 1	Student Space (15)	
B00B - R1028 - General Learning Space - (57.73 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1030 - Materials Workshop - Type 2 - (106.71 SQM)	Student Space (49)	
B00B - R1031 - Materials Workshop - Type 2 - (6.92 SQM)	Student Space (3)	
B00C - R0010 - General Assistants - (18.16 SQM)	Office (4)	
B00C - R0014 - Seminar - (15.43 SQM)	Office (3)	
B00C - R0015 - Seminar - (16.68 SQM)	Office (4)	
B00C - R0016 - Special Learning Space - (40.75 SQM) - Teaching Space: 1	Student Space (18)	
B00C - R0017 - Seminar - (9.57 SQM)	Office (2)	
B00C - R0018 - Seminar - (14.1 SQM)	Office (3)	
B00C - R0019 - Seminar - (25.84 SQM)	Office (6)	
B00C - R0020 - Ancillary Staff - (12.42 SQM)	Office (3)	
B00C - R0021 - Deputy Principal Office - (19.53 SQM)	Office (4)	
B00C - R0022 - Staff Study - (25.92 SQM)	Office (6)	
B00C - R0023 - Special Learning Space - (58.28 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0024 - General Learning Space - (49.26 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0030 - Movement - (150.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0032 - Entry - (16.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0033 - Clinic - Boys - (20.35 SQM)	Office (5)	
B00C - R0038 - Seminar - (24.97 SQM)	Office (6)	
B00C - R0039 - Senior Study - (26.88 SQM)	Office (6)	
B00C - R0040 - Main Area - (370.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (57.68 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1002 - Staff Study - (25.75 SQM)	Office (6)	
B00C - R1003 - General Learning Space - (52.22 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1004 - General Learning Space - (52.22 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1005 - General Learning Space - (57.68 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1006 - Leading Teacher - (12.9 SQM)	Office (3)	
B00C - R1008 - General Learning Space - (51.7 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1020 - General Learning Space - (51.72 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1024 - Movement - (179.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R1025 - Performance Workspace - (132.88 SQM) - Teaching Space: 1	Student Space (61)	
B00C - R1026 - Performance Workspace - (85.28 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0003 - Laboratory L.S. - (92.74 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R0004 - Preparation - (19.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - General Learning Space - (51.21 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0012 - Interview/Office - Type 1 - (12.57 SQM)	Office (3)	
B00D - R0013 - General Learning Space - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0014 - Laboratory L.S. - (91.26 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0015 - Preparation - (29.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Laboratory L.S. - (83.8 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R0022 - General Learning Space - (50.99 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0024 - Movement - (178.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - Staff Study - (39.21 SQM)	Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1001 - General Learning Space - (57.86 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1003 - General Learning Space - (50 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1006 - Computer Learning Space - (57.43 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1008 - Staff Study - (30.73 SQM)	● Office (7)	
B00D - R1010 - General Learning Space - (52.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1011 - General Learning Space - (52.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1012 - General Learning Space - (57.41 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1013 - Interview/Office - Type 1 - (12.6 SQM)	● Office (3)	
B00D - R1015 - General Learning Space - (51.21 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1018 - General Learning Space - (57.51 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1021 - Staff Study - (25.38 SQM)	● Office (6)	
B00D - R1023 - Interview/Office - Type 1 - (12.6 SQM)	● Office (3)	
B00D - R1024 - Interview/Office - Type 1 - (25.67 SQM)	● Office (6)	
B00D - R1025 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1026 - Movement - (161.63 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (338.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (10.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Student Canteen - (57.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (10.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Movement - (12.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R1012 - Movement - (12.2 SQM)	Not Applicable	Circulation or storage space.
B00E - R1015 - Gymnasium - (119.28 SQM)	● Student Space (55)	
B00F - R0001 - Student Canteen - (16.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (22.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Multi-Purpose Space - (425.56 SQM)	● Student Space (197)	
B00F - R0008 - Stage - (125.61 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Computer Learning Space - (92.01 SQM) - Teaching Space: 1	● Student Space (42)	
B00I - R0003 - Seminar - Type 2 - (18.76 SQM)	● Office (4)	
B00J - R0001 - Gymnasium - (1470.94 SQM)	● Student Space (682)	
B00J - R0006 - Movement - (24.36 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Performance Workspace - (46.52 SQM) - Teaching Space: 1	● Student Space (21)	
B00J - R0011 - Performance Workspace - (108.29 SQM) - Teaching Space: 1	● Student Space (50)	