

VENTILATION AUDIT REPORT

SCHOOL:	Chifley Public School (4299)
AMU REGION:	Sydney
STATE ELECTORATE:	Maroubra
LOCAL GOVERNMENT AREA:	Randwick

4299 - Chifley Public School
Site Plan (12822)



1:1,919

Printed: 17-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Duplicating Workroom - (18.97 SQM)	Office (4)	
B00A - R0007 - Principal - (23.09 SQM)	Office (5)	
B00A - R0010 - Staff Room - (34.47 SQM)	Office (8)	
B00A - R0013 - Entry Vestibule - (32.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (57.02 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0004 - Movement - (6.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Staff Room - (56.87 SQM)	Office (14)	
B00C - R0001 - Home Base - (57.42 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0006 - Home Base - (57.5 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0001 - Home Base - (57.58 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0004 - Movement - (5.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (57.59 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0001 - Dental Clinic - (19.75 SQM)	Office (4)	
B00E - R0004 - Dental Clinic - (13.16 SQM)	Office (3)	
B00E - R0007 - Clerical Office - (9.6 SQM)	Office (2)	
B00E - R0009 - Staff Room - (8.33 SQM)	Office (2)	
B00E - R0010 - Dental Clinic - (5.2 SQM)	Office (1)	
B00G - R0008 - Canteen - (16.1 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Practical Activities - 1hb - (18.93 SQM)	Student Space (8)	
B00H - R0005 - Home Base - (38.02 SQM) - Teaching Space: 1	Student Space (17)	
B00H - R0006 - Home Base - (63.44 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0007 - Practical Activities - 1hb - (21.07 SQM)	Student Space (9)	
B00J - R0008 - Home Base - (54.31 SQM) - Teaching Space: 1	Student Space (25)	
B00J - R0010 - Special Programs Room - (14.92 SQM)	Student Space (6)	
B00K - R0001 - Home Base - (57.58 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R0004 - Movement - (15.95 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Special Programs Room - (21.36 SQM)	Student Space (9)	
B00K - R0008 - Staff Room Annexe - (18.12 SQM)	Office (4)	
B00K - R0009 - Movement - (7.09 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Reading Area - (92.26 SQM)	Student Space (42)	
B00L - R0003 - Movement - (6.06 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Movement - (16.05 SQM)	Not Applicable	Circulation or storage space.
B00M - R0005 - Communal Space - (56.78 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R0006 - Communal Space - (42.57 SQM) - Teaching Space: 1	Student Space (19)	
B00M - R0007 - Raised Platform - (13.77 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Communal Space - (147.23 SQM)	Student Space (68)	
B00O - R0002 - Raised Platform - (58.96 SQM)	Not Applicable	Circulation or storage space.
B00O - R0017 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00O - R0018 - Movement - (11.08 SQM)	Not Applicable	Circulation or storage space.
B00O - R0019 - Movement - (12.22 SQM)	Not Applicable	Circulation or storage space.
OS 534 15584 - OS 534 15584 - Library/Group Study/Office/A V Store - (152 SQM)	Student Space (70)	
OS 602 15991 - OS 602 15991 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 750 13843 - OS 750 13843 - Learning Unit - ESL - (38 SQM)	Student Space (17)	
OS 750 17704 - OS 750 17704 - Learning Unit - ESL - (38 SQM)	Student Space (17)	