

VENTILATION AUDIT REPORT

SCHOOL:	Chillingham Public School (1558)
AMU REGION:	North Coast
STATE ELECTORATE:	Lismore
LOCAL GOVERNMENT AREA:	Tweed

1558 - Chillingham Public School
Site Plan (11955)














1:622

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (6.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Staff Room - (14.09 SQM)	 Office (3)	
B00A - R0004 - Home Base - (53.47 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0001 - Practical Activities - 1hb - (16.52 SQM)	 Student Space (7)	
B00B - R0002 - Home Base - (43.86 SQM) - Teaching Space: 1	 Student Space (20)	
B00D - R0002 - Home Base - (45.86 SQM) - Teaching Space: 1	 Student Space (21)	
B00D - R9001 - Reading Area - (53.87 SQM)	 Student Space (24)	
B00D - R9002 - Movement - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Special Programs Room - (8.16 SQM)	 Student Space (3)	
B00E - R0005 - Movement - (10.18 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Staff Kitchen - (12.81 SQM)	 Office (3)	
B00E - R0010 - Principal - (15.97 SQM)	 Office (3)	
B00E - R0012 - Clerical Office - (15.56 SQM)	 Office (3)	
B00E - R0013 - Movement - (27.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Canteen - (14.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (20.3 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Home Base - (60.03 SQM) - Teaching Space: 1	 Student Space (27)	