

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Chipping Norton Public School (1560)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Holsworthy</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Liverpool</b>

1560 - Chipping Norton Public School  
Site Plan (10932)












1:1,092

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (53.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0002 - Home Base - (53.37 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0004 - Staff Room Annexe - (9.34 SQM)	● Office (2)	
B00A - R0007 - Movement - (34.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Special Programs Room - (44.02 SQM)	● Student Space (20)	
B00B - R0003 - Special Programs Room - (43.95 SQM)	● Student Space (20)	
B00B - R0004 - Movement - (28.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (16.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (66.97 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0002 - Home Base - (53.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0006 - Movement - (38.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Special Programs Room - (46.76 SQM)	● Student Space (21)	
B00D - R0002 - Movement - (12.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Home Base - (85.98 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R0007 - Home Base - (85.66 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R0012 - Movement - (60.45 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Staff Room - (48.63 SQM)	● Office (12)	
B00F - R0015 - Staff Room Annexe - (18.02 SQM)	● Office (4)	
B00I - R0015 - Sick Bay - (9.03 SQM)	● Student Space (4)	
B00I - R0018 - Clerical Office - (16.27 SQM)	● Office (4)	
B00I - R0019 - Principal - (12.53 SQM)	● Office (3)	
B00I - R0023 - Entry Vestibule - (8.88 SQM)	Not Applicable	Circulation or storage space.
B00I - R0024 - Movement - (26.94 SQM)	Not Applicable	Circulation or storage space.
B00I - R0025 - Deputy Principal - (12.53 SQM)	● Office (3)	
B00I - R0026 - Movement - (27.14 SQM)	Not Applicable	Circulation or storage space.
B00I - R0027 - Interview - (12.82 SQM)	● Office (3)	
B00I - R0028 - Interview/Office - Type 3 - (15.44 SQM)	● Office (3)	
B00I - R0029 - Duplicating Workroom - (17.96 SQM)	● Office (4)	
B00J - R0001 - Movement - (34.03 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Duplicating Workroom - (12.04 SQM)	● Office (3)	
B00J - R0003 - Staff Kitchen - (11.3 SQM)	● Office (2)	
B00J - R0006 - Movement - (8.47 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Interview - (24.63 SQM)	● Office (6)	
B00J - R0010 - Movement - (11.36 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Communal Space - (144.87 SQM)	● Student Space (67)	
B00M - R0002 - Raised Platform - (64.38 SQM)	Not Applicable	Circulation or storage space.
B00M - R0016 - Movement - (5.72 SQM)	Not Applicable	Circulation or storage space.
B00M - R0018 - Movement - (11.95 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0003 - Practical Activities - 1hb - (19.24 SQM)	● Student Space (8)	
BOB1 - R0004 - Home Base - (60 SQM) - Teaching Space: 1	● Student Space (27)	
BOB1 - R0005 - Withdrawal Space - 2hb - (12.07 SQM)	● Student Space (5)	
BOB1 - R0006 - Home Base - (60.77 SQM) - Teaching Space: 1	● Student Space (28)	
BOB1 - R0007 - Practical Activities - 1hb - (19.27 SQM)	● Student Space (8)	
BOB1 - R0009 - Movement - (43.47 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0001 - Practical Activities - 1hb - (19.15 SQM)	● Student Space (8)	
BOC1 - R0004 - Home Base - (60.11 SQM) - Teaching Space: 1	● Student Space (27)	
BOC1 - R0005 - Withdrawal Space - 2hb - (12.04 SQM)	● Student Space (5)	
BOC1 - R0006 - Home Base - (60.74 SQM) - Teaching Space: 1	● Student Space (28)	
BOC1 - R0007 - Practical Activities - 1hb - (19.17 SQM)	● Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOC1 - R0010 - Practical Activities - 1hb - (19.15 SQM)	 Student Space (8)	
BOC1 - R0011 - Home Base - (60.59 SQM) - Teaching Space: 1	 Student Space (28)	
BOC1 - R0012 - Withdrawal Space - 2hb - (12.07 SQM)	 Student Space (5)	
BOC1 - R0013 - Home Base - (60.24 SQM) - Teaching Space: 1	 Student Space (27)	
BOC1 - R0014 - Practical Activities - 1hb - (19.27 SQM)	 Student Space (8)	
BOC1 - R0017 - Movement - (92.55 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R0001 - Reading Area - (169.84 SQM)	 Student Space (78)	
B0D1 - R0012 - Movement - (60.78 SQM)	Not Applicable	Circulation or storage space.
OS 602 14939 - OS 602 14939 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 17725 - OS 602 17725 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 750 10353 - OS 750 10353 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	
OS 801 12059 - OS 801 12059 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.