


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Chittaway Bay Public School (4542)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wyong</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

4542 - Chittaway Bay Public School  
Site Plan (10933)























1:1,305

Printed: 05-Dec-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Practical Activities - 1hb - (37.68 SQM)	● Student Space (17)	
B00A - R0004 - Home Base - (59.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0005 - Movement - (15.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Withdrawal Space - 1hb - (8.91 SQM)	● Student Space (4)	
B00A - R0007 - Home Base - (61.91 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0010 - Home Base - (61.62 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0012 - Withdrawal Space - 1hb - (12.05 SQM)	● Student Space (5)	
B00A - R0013 - Home Base - (59.99 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0018 - Practical Activities - 1hb - (36.61 SQM)	● Student Space (16)	
B00B - R0003 - Home Base - (59.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0004 - Movement - (15.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Withdrawal Space - 1hb - (8.91 SQM)	● Student Space (4)	
B00B - R0006 - Home Base - (61.91 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0009 - Practical Activities - 1hb - (37.68 SQM)	● Student Space (17)	
B00B - R0011 - Practical Activities - 1hb - (37.68 SQM)	● Student Space (17)	
B00B - R0013 - Home Base - (61.62 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0014 - Withdrawal Space - 1hb - (12.05 SQM)	● Student Space (5)	
B00B - R0016 - Home Base - (59.99 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0001 - Home Base - (59.84 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0003 - Withdrawal Space - 1hb - (11.91 SQM)	● Student Space (5)	
B00C - R0005 - Home Base - (61.54 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0007 - Practical Activities - 1hb - (37.65 SQM)	● Student Space (17)	
B00D - R0004 - Canteen - (27.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Raised Platform - (29.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (14.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Communal Space - (146.6 SQM)	● Student Space (68)	
B00F - R0001 - Staff Room Annexe - (18.79 SQM)	● Office (4)	
B00F - R0004 - Interview - (12.01 SQM)	● Office (3)	
B00F - R0005 - Entry Vestibule - (9.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Clerical Office - (11.89 SQM)	● Office (2)	
B00F - R0008 - Sick Bay - (8.11 SQM)	● Student Space (3)	
B00F - R0010 - Deputy Principal - (11.92 SQM)	● Office (2)	
B00F - R0012 - Staff Room Annexe - (12.18 SQM)	● Office (3)	
B00F - R0016 - Principal - (15.77 SQM)	● Office (3)	
B00F - R0017 - Duplicating Workroom - (21.13 SQM)	● Office (5)	
B00F - R0019 - Staff Room - (48.76 SQM)	● Office (12)	
B00F - R0021 - Movement - (46.74 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Duplicating Workroom - (21.55 SQM)	● Office (5)	
B00F - R0024 - Movement - (29.34 SQM)	Not Applicable	Circulation or storage space.
B00F - R0025 - Entry Vestibule - (17.96 SQM)	Not Applicable	Circulation or storage space.
B00F - R0026 - Movement - (9.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Reading Area - (176.06 SQM)	● Student Space (81)	
B00I - R0001 - Movement - (38.48 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Practical Activities - 1hb - (19.39 SQM)	● Student Space (8)	
B00I - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00I - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0001 - Home Base - (59.7 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0002 - Home Base - (59.93 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0003 - Practical Activities - 1hb - (18.86 SQM)	 Student Space (8)	
B00J - R0004 - Practical Activities - 1hb - (18.93 SQM)	 Student Space (8)	
B00J - R0005 - Withdrawal Space - 2hb - (11.61 SQM)	 Student Space (5)	
B00K - R0001 - Home Base - (59.72 SQM) - Teaching Space: 1	 Student Space (27)	
B00K - R0002 - Home Base - (59.93 SQM) - Teaching Space: 1	 Student Space (27)	
B00K - R0003 - Practical Activities - 1hb - (19.16 SQM)	 Student Space (8)	
B00K - R0004 - Practical Activities - 1hb - (19.02 SQM)	 Student Space (8)	
B00K - R0005 - Withdrawal Space - 2hb - (11.68 SQM)	 Student Space (5)	
B00K - R0013 - Practical Activities - 1hb - (20.3 SQM)	 Student Space (9)	
B00K - R0014 - Withdrawal Space - 1hb - (9.27 SQM)	 Student Space (4)	
B00K - R0015 - Home Base - (57.7 SQM) - Teaching Space: 1	 Student Space (26)	
B00M - R0001 - Practical Activities - 1hb - (14.55 SQM)	 Student Space (6)	
B00M - R0004 - Home Base - (58.88 SQM) - Teaching Space: 1	 Student Space (27)	
B00M - R0005 - Withdrawal Space - 2hb - (11.57 SQM)	 Student Space (5)	
B00M - R0006 - Home Base - (60.4 SQM) - Teaching Space: 1	 Student Space (28)	
B00M - R0008 - Special Programs Room - Type 1 - (37.1 SQM)	 Student Space (17)	
B00M - R0009 - Practical Activities - 1hb - (14.84 SQM)	 Student Space (6)	
B00M - R0017 - Special Programs Room - (46.2 SQM)	 Student Space (21)	