

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Chullora Public School (3808)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Lakemba</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canterbury-Bankstown</b>

3808 - Chullora Public School  
Site Plan (10232)



1:972

Printed: 24-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0011 - Movement - (11.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Home Base - (33.1 SQM)	● Student Space (15)	
B00A - R0014 - Staff Room - (13.49 SQM)	○ Office (3)	
B00B - R0001 - Home Base - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0002 - Home Base - (53.09 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0004 - Movement - (54.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (47.08 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0002 - Home Base - (47.08 SQM)	● Student Space (21)	
B00C - R0008 - Home Base - (47.09 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0009 - Home Base - (47.09 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0010 - Movement - (68.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (47.08 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0003 - Home Base - (47.09 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0006 - Movement - (31.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Principal - (17.49 SQM)	○ Office (4)	
B00E - R0020 - Staff Room - (70.88 SQM)	○ Office (17)	
B00E - R0021 - General Assistants - (21.93 SQM)	○ Office (5)	
B00E - R0023 - Sick Bay - (9.14 SQM)	● Student Space (4)	
B00E - R0026 - Clerical Office - (24.12 SQM)	○ Office (6)	
B00E - R0027 - Clerical Office - (12.8 SQM)	○ Office (3)	
B00E - R0028 - Interview - (9.45 SQM)	○ Office (2)	
B00E - R0029 - Clerical Office - (7.7 SQM)	○ Office (1)	
B00E - R0030 - Movement - (17.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Special Programs Room - (53.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0003 - Home Base - (53.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0005 - Movement - (26.66 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (53.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0002 - Home Base - (53.39 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0007 - Home Base - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0008 - Home Base - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0009 - Movement - (64.51 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Withdrawal Space - 2hb - (25.06 SQM)	● Student Space (11)	
B00H - R0001 - Home Base - (67.69 SQM) - Teaching Space: 1	● Student Space (31)	
B00H - R0004 - Movement - (7.81 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Home Base - (67.77 SQM) - Teaching Space: 1	● Student Space (31)	
B00J - R0004 - Staff Room Annexe - (14.9 SQM)	○ Office (3)	
B00J - R0007 - Movement - (10.7 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - Home Base - (66.72 SQM) - Teaching Space: 1	● Student Space (30)	
B00J - R0009 - Home Base - (66.44 SQM) - Teaching Space: 1	● Student Space (30)	
B00J - R0012 - Interview - (19.26 SQM)	○ Office (4)	
B00J - R0015 - Movement - (9.81 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Reading Area - (132.89 SQM)	● Student Space (61)	
B00L - R0001 - Movement - (12.01 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Canteen - (25.86 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Movement - (34.23 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Movement - (56.71 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Communal Space - (143.58 SQM)	● Student Space (66)	
B00P - R0002 - Raised Platform - (60.58 SQM)	Not Applicable	Circulation or storage space.
B00P - R0016 - Movement - (7.4 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0017 - Movement - (13.8 SQM)	Not Applicable	Circulation or storage space.
OS 602 13494 - OS 602 13494 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19503 - OS 602 19503 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 751 11192 - OS 751 11192 - Learning Unit - ESL - (76 SQM)	● Student Space (35)	