


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Clarence Town Public School (1564)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Upper Hunter</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Dungog</b>

1564 - Clarence Town Public School  
Site Plan (12243)



1:736

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (27.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office/Workroom - (14.11 SQM)	Office (3)	
B00A - R0013 - Interview - (13.27 SQM)	Office (3)	
B00A - R0015 - Principal - (16.24 SQM)	Office (4)	
B00A - R0016 - Duplicating Workroom - (15.56 SQM)	Office (3)	
B00A - R0017 - Clerical Office - (13.08 SQM)	Office (3)	
B00A - R0018 - Movement - (8.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Entry Vestibule - (32.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Sick Bay - (6.44 SQM)	Student Space (2)	
B00A - R0021 - Movement - (5.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Staff Room - (40.22 SQM)	Office (10)	
B00A - R0028 - Staff Room Annexe - (12.39 SQM)	Office (3)	
B00B - R0006 - Movement - (27.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Practical Activities - 1hb - (10.61 SQM)	Student Space (4)	
B00B - R0011 - Withdrawal Space - 1hb - (9.22 SQM)	Student Space (4)	
B00B - R0012 - Home Base - (60.8 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0015 - Reading Area - (96.68 SQM)	Student Space (44)	
B00F - R0002 - Practical Activities - 1hb - (18.89 SQM)	Student Space (8)	
B00F - R0003 - Home Base - (60.26 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0005 - Withdrawal Space - 2hb - (11.51 SQM)	Student Space (5)	
B00F - R0006 - Practical Activities - 1hb - (18.9 SQM)	Student Space (8)	
B00F - R0007 - Home Base - (60.27 SQM) - Teaching Space: 1	Student Space (27)	
BOC1 - R0003 - Canteen - (13.62 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0007 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0011 - Movement - (8.48 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0012 - Raised Platform - (61.1 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0013 - Movement - (27.44 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0021 - Communal Space - (144.04 SQM)	Student Space (66)	
BOD1 - R0002 - Practical Activities - 1hb - (20.25 SQM)	Student Space (9)	
BOD1 - R0003 - Home Base - (59.71 SQM) - Teaching Space: 1	Student Space (27)	
BOD1 - R0004 - Withdrawal Space - 2hb - (11.46 SQM)	Student Space (5)	
BOD1 - R0005 - Home Base - (60.41 SQM) - Teaching Space: 1	Student Space (28)	
BOD1 - R0006 - Practical Activities - 1hb - (20.25 SQM)	Student Space (9)	
BOD1 - R0008 - Movement - (65.73 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0010 - Movement - (17.43 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R0001 - Special Programs Room - (33.05 SQM)	Student Space (15)	
BOE1 - R0008 - Practical Activities - 1hb - (18.56 SQM)	Student Space (8)	
BOE1 - R0009 - Home Base - (60.18 SQM) - Teaching Space: 1	Student Space (27)	
BOE1 - R0010 - Withdrawal Space - 2hb - (11.31 SQM)	Student Space (5)	
BOE1 - R0011 - Home Base - (59.72 SQM) - Teaching Space: 1	Student Space (27)	
BOE1 - R0012 - Practical Activities - 1hb - (18.53 SQM)	Student Space (8)	
BOE1 - R0015 - Practical Activities - 1hb - (18.93 SQM)	Student Space (8)	
BOE1 - R0016 - Home Base - (60.21 SQM) - Teaching Space: 1	Student Space (27)	
BOE1 - R0017 - Withdrawal Space - 2hb - (11.54 SQM)	Student Space (5)	
BOE1 - R0018 - Home Base - (60.2 SQM) - Teaching Space: 1	Student Space (27)	
BOE1 - R0019 - Practical Activities - 1hb - (18.96 SQM)	Student Space (8)	
BOE1 - R0022 - Movement - (140.01 SQM)	Not Applicable	Circulation or storage space.