

VENTILATION AUDIT REPORT

SCHOOL:	Clarke Road School (5655)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Hornsby
LOCAL GOVERNMENT AREA:	Hornsby

5655 - Clarke Road School
Site Plan (10234)








1:594

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0001 - Hydrotherapy - Pool - (172.27 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Entry Vestibule - (19.85 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Interview - (15.44 SQM)	Office (3)	
B00L - R0003 - Interview/Office - Type 3 - (19.27 SQM)	Office (4)	
B00L - R0004 - Principal - (15.4 SQM)	Office (3)	
B00L - R0005 - Movement - (46.89 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Clerical/Printing - (55.77 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Sick Bay - (7.27 SQM)	Student Space (3)	
B00L - R0014 - Staff Room Annexe - (27.31 SQM)	Office (6)	
B00L - R0015 - Staff Room - (52.19 SQM)	Office (13)	
B00L - R0020 - Reading Area - (88.21 SQM)	Student Space (40)	
B00L - R0021 - Movement - (28.37 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Canteen - (30.3 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Special Programs Room - (24.75 SQM)	Student Space (11)	
B00M - R0006 - Communal Space - (113.93 SQM)	Student Space (52)	
B00N - R0001 - Withdrawal Space - 1hb - (10.35 SQM)	Student Space (4)	
B00N - R0005 - Breakout Area - (7.6 SQM)	Not Applicable	Circulation or storage space.
B00N - R0006 - Home Base - (58.65 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0007 - Practical Activities - (19.65 SQM)	Student Space (9)	
B00N - R0011 - Breakout Area - (10.26 SQM)	Not Applicable	Circulation or storage space.
B00N - R0012 - Home Base - (58.39 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0013 - Practical Activities - (19.56 SQM)	Student Space (9)	
B00N - R0014 - Withdrawal Space - 1hb - (9.5 SQM)	Student Space (4)	
B00N - R0015 - Withdrawal Space - 1hb - (9.47 SQM)	Student Space (4)	
B00N - R0019 - Breakout Area - (10.3 SQM)	Not Applicable	Circulation or storage space.
B00N - R0020 - Home Base - (58.39 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0021 - Practical Activities - (19.5 SQM)	Student Space (9)	
B00N - R0025 - Breakout Area - (10.65 SQM)	Not Applicable	Circulation or storage space.
B00N - R0026 - Home Base - (58.61 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0027 - Practical Activities - (19.5 SQM)	Student Space (9)	
B00N - R0028 - Withdrawal Space - 1hb - (9.5 SQM)	Student Space (4)	
B00N - R0029 - Withdrawal Space - 1hb - (9.56 SQM)	Student Space (4)	
B00N - R0033 - Breakout Area - (10.65 SQM)	Not Applicable	Circulation or storage space.
B00N - R0034 - Home Base - (58.57 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0035 - Practical Activities - (19.5 SQM)	Student Space (9)	
B00N - R0040 - Breakout Area - (8.36 SQM)	Not Applicable	Circulation or storage space.
B00N - R0041 - Home Base - (58.61 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0042 - Practical Activities - (19.5 SQM)	Student Space (9)	
B00N - R0043 - Withdrawal Space - 1hb - (10.37 SQM)	Student Space (4)	
B00O - R0004 - Withdrawal Space - 1hb - (10.43 SQM)	Student Space (4)	
B00O - R0005 - Practical Activities - (19.43 SQM)	Student Space (9)	
B00O - R0006 - Home Base - (58.63 SQM) - Teaching Space: 1	Student Space (27)	
B00O - R0007 - Breakout Area - (8.44 SQM)	Not Applicable	Circulation or storage space.
B00O - R0012 - Home Base - (58.45 SQM) - Teaching Space: 1	Student Space (27)	
B00O - R0013 - Practical Activities - (19.5 SQM)	Student Space (9)	
B00O - R0017 - Withdrawal Space - 1hb - (9.12 SQM)	Student Space (4)	
B00O - R0018 - Withdrawal Space - 1hb - (9.79 SQM)	Student Space (4)	
B00O - R0019 - Breakout Area - (10.69 SQM)	Not Applicable	Circulation or storage space.
B00O - R0020 - Breakout Area - (10.71 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B000 - R0021 - Home Base - (58.4 SQM) - Teaching Space: 1	 Student Space (27)	
B000 - R0022 - Practical Activities - (19.25 SQM)	 Student Space (8)	
B000 - R0026 - Home Base - (58.58 SQM) - Teaching Space: 1	 Student Space (27)	
B000 - R0027 - Practical Activities - (19.25 SQM)	 Student Space (8)	
B000 - R0029 - Withdrawal Space - 1hb - (10.04 SQM)	 Student Space (4)	
B000 - R0030 - Breakout Area - (7.65 SQM)	Not Applicable	Circulation or storage space.