


VENTILATION AUDIT REPORT

SCHOOL:	Claymore Public School (4510)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Campbelltown
LOCAL GOVERNMENT AREA:	Campbelltown



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Withdrawal Space - 1hb - (27.34 SQM)	● Student Space (12)	
B00A - R0001 - Movement - (16.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Home Base - (58.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0003 - Withdrawal Space - 1hb - (14.22 SQM)	● Student Space (6)	
B00A - R0004 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (58.62 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0008 - Movement - (14.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (6.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Staff Kitchen - (6.84 SQM)	● Office (1)	
B00A - R0012 - Practical Activities - 1hb - (43.81 SQM)	● Student Space (20)	
B00A - R0013 - Staff Room Annexe - (14.37 SQM)	● Office (3)	
B00A - R0015 - Home Base - (58.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0016 - Movement - (6.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Withdrawal Space - 1hb - (14.22 SQM)	● Student Space (6)	
B00A - R0018 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Home Base - (58.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0025 - Practical Activities - 1hb - (29.27 SQM)	● Student Space (13)	
B00A - R0026 - Movement - (5.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Movement - (16.37 SQM)	Not Applicable	Circulation or storage space.
B00B - M0001 - Withdrawal Space - 1hb - (27.34 SQM)	● Student Space (12)	
B00B - R0001 - Movement - (16.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0003 - Withdrawal Space - 1hb - (14.18 SQM)	● Student Space (6)	
B00B - R0004 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0008 - Movement - (13.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (6.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Staff Kitchen - (6.86 SQM)	● Office (1)	
B00B - R0012 - Practical Activities - 1hb - (43.82 SQM)	● Student Space (20)	
B00B - R0013 - Staff Room Annexe - (14.41 SQM)	● Office (3)	
B00B - R0015 - Home Base - (58.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0016 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Withdrawal Space - 1hb - (14.25 SQM)	● Student Space (6)	
B00B - R0018 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Home Base - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0023 - Staff Kitchen - (6.96 SQM)	● Office (1)	
B00B - R0025 - Practical Activities - 1hb - (29.27 SQM)	● Student Space (13)	
B00B - R0026 - Movement - (5.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Movement - (16.37 SQM)	Not Applicable	Circulation or storage space.
B00C - M0001 - Withdrawal Space - 1hb - (27.37 SQM)	● Student Space (12)	
B00C - R0001 - Movement - (16.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (58.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0003 - Withdrawal Space - 1hb - (14.14 SQM)	● Student Space (6)	
B00C - R0004 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0008 - Movement - (13.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (6.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Staff Kitchen - (6.86 SQM)	● Office (1)	
B00C - R0012 - Practical Activities - 1hb - (43.82 SQM)	● Student Space (20)	
B00C - R0013 - Staff Room Annexe - (14.37 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0015 - Home Base - (58.61 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0016 - Movement - (6.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Withdrawal Space - 1hb - (14.22 SQM)	● Student Space (6)	
B00C - R0018 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Home Base - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0025 - Practical Activities - 1hb - (29.31 SQM)	● Student Space (13)	
B00C - R0026 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R0029 - Movement - (16.37 SQM)	Not Applicable	Circulation or storage space.
B00D - M0001 - Withdrawal Space - 1hb - (27.36 SQM)	● Student Space (12)	
B00D - R0001 - Movement - (16.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (58.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0003 - Withdrawal Space - 1hb - (14.18 SQM)	● Student Space (6)	
B00D - R0004 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (58.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0008 - Movement - (14.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (6.13 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Staff Kitchen - (6.84 SQM)	● Office (1)	
B00D - R0012 - Practical Activities - 1hb - (43.9 SQM)	● Student Space (20)	
B00D - R0013 - Staff Room Annexe - (14.36 SQM)	● Office (3)	
B00D - R0015 - Home Base - (58.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0016 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Withdrawal Space - 1hb - (14.14 SQM)	● Student Space (6)	
B00D - R0018 - Movement - (6.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Home Base - M - (58.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0023 - Staff Kitchen - (6.82 SQM)	● Office (1)	
B00D - R0025 - Practical Activities - 1hb - (29.16 SQM)	● Student Space (13)	
B00D - R0026 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - Movement - (16.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0035 - Home Base - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0036 - Movement - (15.84 SQM)	Not Applicable	Circulation or storage space.
B00E - M0001 - Withdrawal Space - 1hb - (27.34 SQM)	● Student Space (12)	
B00E - R0001 - Movement - (16.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (58.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0003 - Withdrawal Space - 1hb - (14.22 SQM)	● Student Space (6)	
B00E - R0004 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Home Base - (58.63 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0008 - Movement - (13.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (6.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Staff Kitchen - (6.88 SQM)	● Office (1)	
B00E - R0012 - Practical Activities - 1hb - (43.82 SQM)	● Student Space (20)	
B00E - R0013 - Staff Room Annexe - (14.37 SQM)	● Office (3)	
B00E - R0015 - Home Base - (58.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0016 - Movement - (6.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Withdrawal Space - 1hb - (14.22 SQM)	● Student Space (6)	
B00E - R0018 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Home Base - (58.69 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0025 - Practical Activities - 1hb - (29.19 SQM)	● Student Space (13)	
B00E - R0026 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0029 - Movement - (16.37 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (15.81 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0002 - Movement - (71.51 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Movement - (95.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Movement - (23.24 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Movement - (133.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (23.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (107.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (99.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Movement - (54.66 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (47.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (14.39 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Special Programs Room - (41.55 SQM)	● Student Space (19)	
B00H - R0001 - Movement - (59.23 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Staff Room - (6.63 SQM)	● Office (1)	
B00H - R0003 - Staff Room Annexe - (7.52 SQM)	● Office (1)	
B00H - R0004 - Movement - (20.55 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (9.83 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Entry Vestibule - (50.5 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Principal - (21.68 SQM)	● Office (5)	
B00H - R0015 - Sick Bay - (12.23 SQM)	● Student Space (5)	
B00H - R0016 - Staff Room Annexe - (12.27 SQM)	● Office (3)	
B00H - R0017 - Staff Room Annexe - (12.27 SQM)	● Office (3)	
B00H - R0018 - Movement - (18.31 SQM)	Not Applicable	Circulation or storage space.
B00H - R0020 - Duplicating Workroom - (30.72 SQM)	● Office (7)	
B00H - R0021 - Clerical Office - (15.26 SQM)	● Office (3)	
B00H - R0024 - Entry Vestibule - (9.58 SQM)	Not Applicable	Circulation or storage space.
B00H - R0025 - Interview - (11.65 SQM)	● Office (2)	
B00H - R0026 - Movement - (29.97 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Special Programs Room - (42.45 SQM)	● Student Space (19)	
B00K - R0005 - Reading Area - (183.06 SQM)	● Student Space (84)	
B00K - R0008 - Reading Area - (62.44 SQM)	● Student Space (28)	
B00K - R0009 - Movement - (61.37 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Movement - (28.4 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Canteen - (45.01 SQM)	Not Applicable	Circulation or storage space.
B00L - R0012 - Movement - (10.22 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Movement - (20.05 SQM)	Not Applicable	Circulation or storage space.
B00L - R0014 - Movement - (12.68 SQM)	Not Applicable	Circulation or storage space.
B00L - R0015 - Movement - (13.22 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Communal Space - (22.81 SQM)	● Student Space (10)	
B00L - R0019 - Movement - (14.09 SQM)	Not Applicable	Circulation or storage space.
B00L - R0020 - Raised Platform - (41.55 SQM)	Not Applicable	Circulation or storage space.
B00L - R0021 - Communal Space - (181.8 SQM)	● Student Space (84)	
B00M - R0001 - Movement - (14.27 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Special Programs Room - (42.26 SQM)	● Student Space (19)	
B00N - R0002 - Entry Vestibule - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Home Base - Pre - (68.97 SQM) - Teaching Space: 1	● Student Space (31)	
B00N - R0006 - Practical Activities - Pre - (46.31 SQM)	● Student Space (21)	
B00N - R0015 - Movement - (69.35 SQM)	Not Applicable	Circulation or storage space.