

VENTILATION AUDIT REPORT

SCHOOL:	Clovelly Public School (1573)
AMU REGION:	Sydney
STATE ELECTORATE:	Coogee
LOCAL GOVERNMENT AREA:	Waverley

1573 - Clovelly Public School
Site Plan (11644)



1:635

Printed: 16-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0002 - Home Base - (48.18 SQM) - Teaching Space: 1	Student Space (22)	
B001 - R0003 - Home Base - (48.65 SQM) - Teaching Space: 1	Student Space (22)	
B001 - R0004 - Home Base - (49.07 SQM) - Teaching Space: 1	Student Space (22)	
B001 - R0005 - Movement - (81.2 SQM)	Not Applicable	Circulation or storage space.
B001 - R1001 - Home Base - (50.8 SQM) - Teaching Space: 1	Student Space (23)	
B001 - R1002 - Home Base - (50.93 SQM) - Teaching Space: 1	Student Space (23)	
B001 - R1003 - Home Base - (52.27 SQM) - Teaching Space: 1	Student Space (24)	
B001 - R1004 - Movement - (61.09 SQM)	Not Applicable	Circulation or storage space.
B001 - R1005 - Staff Room Annexe - (9.09 SQM)	Office (2)	
B001 - R1006 - Movement - (14.8 SQM)	Not Applicable	Circulation or storage space.
B001 - R9003 - Canteen - (7.5 SQM)	Not Applicable	Circulation or storage space.
B001 - R9005 - Canteen - (19.22 SQM)	Not Applicable	Circulation or storage space.
B001 - R9011 - Movement - (6.95 SQM)	Not Applicable	Circulation or storage space.
B002 - R0001 - Staff Room - (53.27 SQM)	Office (13)	
B002 - R0002 - Staff Room Annexe - (31.95 SQM)	Office (7)	
B002 - R0003 - Interview - (17.41 SQM)	Office (4)	
B002 - R0004 - Principal - (17.45 SQM)	Office (4)	
B002 - R0005 - Movement - (74.79 SQM)	Not Applicable	Circulation or storage space.
B002 - R0006 - Home Base - (49.25 SQM) - Teaching Space: 1	Student Space (22)	
B002 - R0007 - Home Base - (48.78 SQM) - Teaching Space: 1	Student Space (22)	
B002 - R0008 - Home Base - (52.88 SQM) - Teaching Space: 1	Student Space (24)	
B002 - R0009 - Home Base - (49.34 SQM) - Teaching Space: 1	Student Space (22)	
B002 - R0010 - Movement - (10.13 SQM)	Not Applicable	Circulation or storage space.
B002 - R0016 - Sick Bay - (12.27 SQM)	Student Space (5)	
B002 - R9006 - Home Base - (47.64 SQM) - Teaching Space: 1	Student Space (22)	
B002 - R9007 - Home Base - (42.44 SQM) - Teaching Space: 1	Student Space (19)	
B003 - R0002 - Home Base - (52.22 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R0003 - Home Base - (47.87 SQM) - Teaching Space: 1	Student Space (22)	
B003 - R0004 - Home Base - (47.82 SQM) - Teaching Space: 1	Student Space (22)	
B003 - R0005 - Home Base - (61.88 SQM) - Teaching Space: 1	Student Space (28)	
B003 - R0007 - Movement - (16.56 SQM)	Not Applicable	Circulation or storage space.
B003 - R0012 - Practical Activities - 1hb - (13.76 SQM)	Student Space (6)	
B003 - R0013 - Practical Activities - 1hb - (100.84 SQM)	Student Space (46)	
B003 - R0014 - Movement - (20.09 SQM)	Not Applicable	Circulation or storage space.
B003 - R0015 - Movement - (19.69 SQM)	Not Applicable	Circulation or storage space.
B003 - R0016 - Staff Room Annexe - (12.42 SQM)	Office (3)	
B003 - R0019 - Movement - (18.25 SQM)	Not Applicable	Circulation or storage space.
B003 - R1001 - Home Base - (52.78 SQM) - Teaching Space: 1	Student Space (24)	
B003 - R1002 - Home Base - (48.87 SQM) - Teaching Space: 1	Student Space (22)	
B003 - R1003 - Home Base - (49.52 SQM) - Teaching Space: 1	Student Space (22)	
B003 - R1004 - Home Base - (63.61 SQM) - Teaching Space: 1	Student Space (29)	
B003 - R1005 - Movement - (19.95 SQM)	Not Applicable	Circulation or storage space.
B003 - R1008 - Home Base - (94.79 SQM) - Teaching Space: 1	Student Space (43)	
B003 - R1010 - Staff Room Annexe - (12.5 SQM)	Office (3)	
B003 - R1011 - Movement - (19.9 SQM)	Not Applicable	Circulation or storage space.
B004 - R0001 - Movement - (5.75 SQM)	Not Applicable	Circulation or storage space.
B004 - R0003 - Staff Kitchen - (8.02 SQM)	Office (2)	
B004 - R0004 - Communal Space - (232.48 SQM)	Student Space (107)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B004 - R0005 - Raised Platform - (37.48 SQM)	Not Applicable	Circulation or storage space.
B008 - R0003 - Movement - (52.77 SQM)	Not Applicable	Circulation or storage space.
B008 - R0004 - Practical Activities/Movement - 1hb - (12.33 SQM)	● Student Space (5)	
B008 - R0005 - Home Base - (60.21 SQM) - Teaching Space: 1	● Student Space (27)	
B008 - R0006 - Withdrawal Space - 2hb - (11.84 SQM)	● Student Space (5)	
B008 - R0009 - Home Base - (59.37 SQM) - Teaching Space: 1	● Student Space (27)	
B008 - R0010 - Practical Activities/Movement - 1hb - (12.15 SQM)	● Student Space (5)	
B008 - R0011 - Movement - (7.05 SQM)	Not Applicable	Circulation or storage space.
B009 - R0008 - Reading Area - (231.21 SQM)	● Student Space (107)	
B009 - R1001 - Home Base - (59.18 SQM) - Teaching Space: 1	● Student Space (27)	
B009 - R1002 - Practical Activities/Movement - 1hb - (18.55 SQM)	● Student Space (8)	
B009 - R1003 - Withdrawal Space - 1hb - (9 SQM)	● Student Space (4)	
B009 - R1005 - Home Base - (60.88 SQM) - Teaching Space: 1	● Student Space (28)	
B009 - R1007 - Practical Activities/Movement - 1hb - (18.79 SQM)	● Student Space (8)	
B009 - R1008 - Withdrawal Space - 2hb - (11.51 SQM)	● Student Space (5)	
B009 - R1009 - Home Base - (60.88 SQM) - Teaching Space: 1	● Student Space (28)	
B009 - R1011 - Practical Activities/Movement - 1hb - (18.79 SQM)	● Student Space (8)	
OS 510 15165 - OS 510 15165 - Staff Common Room - (114 SQM)	● Office (28)	
OS 602 13687 - OS 602 13687 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	