




# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Clunes Public School (1574)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lismore</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lismore</b>

1574 - Clunes Public School  
Site Plan (12246)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Withdrawal Space - 1hb - (6.39 SQM)	● Student Space (2)	
B00A - R0002 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0003 - Practical Activities - 1hb - (21.98 SQM)	● Student Space (10)	
B00A - R0006 - Movement - (100.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Staff Room - (33.43 SQM)	● Office (8)	
B00A - R0008 - Staff Room Annexe - (12.12 SQM)	● Office (3)	
B00A - R0009 - Movement - (34.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Deputy Principal - (15.23 SQM)	● Office (3)	
B00A - R0014 - Interview - (13.31 SQM)	● Office (3)	
B00A - R0015 - Principal - (17.01 SQM)	● Office (4)	
B00A - R0017 - Sick Bay - (10.1 SQM)	● Student Space (4)	
B00A - R0018 - Duplicating Workroom - (22.34 SQM)	● Office (5)	
B00A - R0019 - Clerical Office - (17.46 SQM)	● Office (4)	
B00A - R0020 - Entry Vestibule - (9.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (70.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Practical Activities - 1hb - (16.19 SQM)	● Student Space (7)	
B00B - R0007 - Home Base - (59.38 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0008 - Withdrawal Space - 1hb - (11.15 SQM)	● Student Space (5)	
B00B - R0009 - Home Base - (59.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0012 - Practical Activities - 1hb - (16.54 SQM)	● Student Space (7)	
B00C - R0003 - Movement - (32.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Practical Activities - 1hb - (18.32 SQM)	● Student Space (8)	
B00C - R0006 - Home Base - (58.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0007 - Withdrawal Space - 1hb - (11.01 SQM)	● Student Space (5)	
B00C - R0008 - Home Base - (58.53 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0009 - Practical Activities - 1hb - (18.35 SQM)	● Student Space (8)	
B00D - R0005 - Special Programs Room - (38.29 SQM)	● Student Space (17)	
B00D - R0012 - Movement - (53.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Withdrawal Space - 1hb - (11.04 SQM)	● Student Space (5)	
B00D - R0017 - Home Base - (59.61 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0018 - Practical Activities - 1hb - (17.27 SQM)	● Student Space (8)	
B00D - R0020 - Movement - (35.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Movement - (103.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Special Programs Room - (18.76 SQM)	● Student Space (8)	
B00D - R0025 - Reading Area - (129.17 SQM)	● Student Space (59)	
B00E - R0003 - Canteen - (16.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (164.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Raised Platform - (48.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Communal Space - (136.81 SQM)	● Student Space (63)	
B00F - R0004 - Movement - (37.17 SQM)	Not Applicable	Circulation or storage space.