


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Coal Point Public School (4022)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lake Macquarie</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

4022 - Coal Point Public School  
Site Plan (10239)



1:884

Printed: 13-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (45.49 SQM)	Office (11)	
B00A - R0002 - Staff Room Annexe - (19.62 SQM)	Office (4)	
B00A - R0007 - Principal - (16.24 SQM)	Office (4)	
B00A - R0008 - Duplicating Workroom - (19.53 SQM)	Office (4)	
B00A - R0009 - Entry Vestibule - (24.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (16.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Clerical Office - (17.66 SQM)	Office (4)	
B00A - R0012 - Movement - (34.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Sick Bay - (8.64 SQM)	Student Space (4)	
B00A - R0015 - Interview - (13.11 SQM)	Office (3)	
B00A - R0016 - Deputy Principal - (13.19 SQM)	Office (3)	
B00A - R0017 - Staff Room Annexe - (13.15 SQM)	Office (3)	
B00B - R0001 - Movement - (141.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Reading Area - (158.6 SQM)	Student Space (73)	
B00B - R0007 - Special Programs Room - (43.85 SQM)	Student Space (20)	
B00C - R0003 - Practical Activities - 1hb - (27.12 SQM)	Student Space (12)	
B00C - R0004 - Home Base - (53.29 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0005 - Home Base - (53.37 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0006 - Movement - (59.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0010 - Home Base - (53.22 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0012 - Staff Room Annexe - (5.5 SQM)	Office (1)	
B00D - R0001 - Movement - (52.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (53.51 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0009 - Home Base - (53.37 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0001 - Movement - (10.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Canteen - (33.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Practical Activities - 1hb - (19.9 SQM)	Student Space (9)	
B00F - R0002 - Home Base - (60.73 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0004 - Movement - (33.45 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Home Base - (53.37 SQM) - Teaching Space: 1	Student Space (24)	
B00K - R0004 - Movement - (52.16 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Communal Space - (143.24 SQM)	Student Space (66)	
B00L - R0014 - Movement - (5.56 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (14.99 SQM)	Not Applicable	Circulation or storage space.
B00L - R0017 - Raised Platform - (59.93 SQM)	Not Applicable	Circulation or storage space.
OS 602 15813 - OS 602 15813 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 19514 - OS 602 19514 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 18187 - OS 603 18187 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 606 15355 - OS 606 15355 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	