

VENTILATION AUDIT REPORT

SCHOOL:	Cobar High School (8356)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Cobar



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Laboratory L.S. - (90.84 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0002 - Staff Study - (26.75 SQM)	Office (6)	
B00A - R0006 - Preparation - (30.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Laboratory L.S. - (92.3 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0011 - Design L.S. - (51.83 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0017 - Materials Technology L.S. - (76.9 SQM) - Teaching Space: 1	Student Space (35)	
B00A - R0022 - Staff Study - (26.86 SQM)	Office (6)	
B00A - R0029 - General Learning Space - (65.7 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0039 - Food Technology L.S. - (97.03 SQM) - Teaching Space: 1	Student Space (45)	
B00A - R0041 - Materials Technology L.S. - (103.07 SQM) - Teaching Space: 1	Student Space (47)	
B00A - R0046 - Materials Technology L.S. - (48.45 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0048 - Preparation - Materials - (15.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0005 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0006 - Staff Study - (25.7 SQM)	Office (6)	
B00B - R0007 - Computer Learning Space - (52.2 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0008 - General Learning Space - (53.51 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0009 - Stage - (23.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0002 - Commonroom - (61.61 SQM)	Office (15)	
B00C - R0005 - Staff Study - (15.41 SQM)	Office (3)	
B00C - R0007 - Practice/Seminar - (52.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Music Learning Space - (79.06 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0009 - Staff Study - (31.68 SQM)	Office (7)	
B00D - R0003 - Art Learning Space - (77.39 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0007 - Darkroom Space - (5.76 SQM)	Office (1)	
B00D - R0012 - Darkroom Space - (12.23 SQM)	Office (3)	
B00D - R0014 - Movement - (38.44 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Movement - (74.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (310.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Student Canteen - (36.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (12.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - General Assistants - (10.87 SQM)	Office (2)	
B00E - R0012 - Movement - (9.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Staff Study - (24.78 SQM)	Office (6)	
B00E - R0022 - Staff Study - (24.82 SQM)	Office (6)	
B00E - R0023 - Administration - Clerical - (32.46 SQM)	Office (8)	
B00E - R0024 - Administration - Clerical - (18.97 SQM)	Office (4)	
B00F - R0001 - Duplicating Workroom - (6.65 SQM)	Office (1)	
B00F - R0004 - Principal Office - (19.65 SQM)	Office (4)	
B00F - R0005 - Administration - Clerical - (19.17 SQM)	Office (4)	
B00F - R0006 - Staff Study - (12.74 SQM)	Office (3)	
B00F - R0007 - Movement - (41.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Duplicating Workroom - (22.93 SQM)	Office (5)	
B00F - R0014 - Interview/Office - Type 1 - (12.89 SQM)	Office (3)	
B00F - R0016 - Interview/Office - Type 1 - (5.8 SQM)	Office (1)	
B00F - R0017 - Deputy Principal Office - (14.04 SQM)	Office (3)	
B00F - R0018 - Movement - (16.95 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0001 - General Learning Space - (53.28 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0002 - Preparation - (17.49 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Laboratory L.S. - (92.19 SQM) - Teaching Space: 1	● Student Space (42)	
B00G - R0006 - Movement - (53.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - General Learning Space - (53.28 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0010 - General Learning Space - (52.7 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0011 - Computer Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0001 - Seminar - (26.08 SQM)	● Office (6)	
B00H - R0002 - Main Area - (174.63 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Workroom - (17.68 SQM)	● Office (4)	
B00H - R0006 - Audio Visual Workroom - (18.45 SQM)	● Student Space (8)	
B00J - R0001 - Movement - (7.84 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Movement - (7.94 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Multi-Purpose Space - (632.95 SQM)	● Student Space (293)	
B00J - R0009 - Stage - (47.47 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Student Canteen - (12.16 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Movement - (99.18 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Performance Workspace - (161.99 SQM) - Teaching Space: 1	● Student Space (75)	
B00J - R0014 - Movement - (5.9 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Movement - (5.9 SQM)	Not Applicable	Circulation or storage space.