

VENTILATION AUDIT REPORT

SCHOOL:	Cobbitty Public School (1580)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Camden
LOCAL GOVERNMENT AREA:	Camden

1580 - Cobbitty Public School
Site Plan (12249)







1:621

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (12.97 SQM)	Office (3)	
B00A - R0002 - Duplicating Workroom - (10.59 SQM)	Office (2)	
B00A - R0003 - Interview - (11.08 SQM)	Office (2)	
B00A - R0005 - Sick Bay - (8.03 SQM)	Student Space (3)	
B00A - R0010 - Movement - (8.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Principal - (15.14 SQM)	Office (3)	
B00A - R0013 - Interview - (10.82 SQM)	Office (2)	
B00A - R0014 - Entry Vestibule - (9.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Staff Room - (34.56 SQM)	Office (8)	
B00B - R0005 - Movement - (10.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Reading Area - (89.53 SQM)	Student Space (41)	
B00B - R0010 - Seminar/Study - (19.7 SQM)	Office (4)	
B00B - R0013 - Special Programs Room - (32.1 SQM)	Student Space (14)	
B00C - R0002 - Practical Activities - 1hb - (27.6 SQM)	Student Space (12)	
B00C - R0004 - Withdrawal Space - 1hb - (5.85 SQM)	Student Space (2)	
B00C - R0005 - Home Base - (50.19 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0007 - Practical Activities - 1hb - (27.88 SQM)	Student Space (12)	
B00C - R0008 - Home Base - (49.77 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0009 - Withdrawal Space - 1hb - (5.9 SQM)	Student Space (2)	
B00D - R0003 - Practical Activities - 1hb - (27.91 SQM)	Student Space (12)	
B00D - R0005 - Withdrawal Space - 1hb - (5.92 SQM)	Student Space (2)	
B00D - R0006 - Home Base - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0008 - Practical Activities - 1hb - (27.62 SQM)	Student Space (12)	
B00D - R0009 - Home Base - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0010 - Withdrawal Space - 1hb - (5.92 SQM)	Student Space (2)	
B00E - R0002 - Home Base - (59.25 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0003 - Practical Activities - 1hb - (19.03 SQM)	Student Space (8)	
B00E - R0004 - Withdrawal Space - 1hb - (10.5 SQM)	Student Space (4)	
B00F - R0001 - Withdrawal Space - 1hb - (5.73 SQM)	Student Space (2)	
B00F - R0002 - Home Base - (49.92 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0005 - Practical Activities - 1hb - (25.98 SQM)	Student Space (12)	
B00F - R0007 - Practical Activities - 1hb - (26.82 SQM)	Student Space (12)	
B00F - R0008 - Home Base - (49.92 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0010 - Withdrawal Space - 1hb - (5.75 SQM)	Student Space (2)	
B00G - R0001 - Movement - (5.76 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (13.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Canteen - (32.45 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Movement - (13.14 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Communal Space - (142.24 SQM)	Student Space (65)	
B00G - R0023 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
B00G - R0025 - Raised Platform - (48.1 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Practical Activities/Movement - 1hb - (19.14 SQM)	Student Space (8)	
B00K - R0004 - Home Base - (61.31 SQM) - Teaching Space: 1	Student Space (28)	
B00K - R0005 - Withdrawal Space - 2hb - (11.78 SQM)	Student Space (5)	
B00K - R0006 - Home Base - (61.09 SQM) - Teaching Space: 1	Student Space (28)	
B00K - R0008 - Practical Activities/Movement - 1hb - (18.65 SQM)	Student Space (8)	
OS 602 10207 - OS 602 10207 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 14311 - OS 602 14311 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15825 - OS 602 15825 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 19107 - OS 606 19107 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19675 - OS 606 19675 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	