


VENTILATION AUDIT REPORT

SCHOOL:	Coffs Harbour Learning Centre (5763)
AMU REGION:	North Coast
STATE ELECTORATE:	Coffs Harbour
LOCAL GOVERNMENT AREA:	Coffs Harbour

5763 - Coffs Harbour Learning Centre
Site Plan (13273)

















1:624

Printed: 30-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (23.09 SQM)	 Office (5)	
B00A - R0002 - Staff Room Annexe - (13.84 SQM)	 Office (3)	
B00A - R0007 - Sick Bay - (6.63 SQM)	 Student Space (3)	
B00A - R0008 - Principal - (12.93 SQM)	 Office (3)	
B00A - R0009 - Staff Room Annexe - (17.55 SQM)	 Office (4)	
B00A - R0010 - Interview - (12.82 SQM)	 Office (3)	
B00A - R0011 - Movement - (20.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Entry Vestibule - (11.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (58.39 SQM) - Teaching Space: 1	 Student Space (27)	
B00B - R0006 - Home Base - (58.32 SQM) - Teaching Space: 1	 Student Space (27)	
B00C - R0001 - Home Base - (56.85 SQM)	 Student Space (26)	
B00C - R0006 - Home Base - (60.4 SQM) - Teaching Space: 1	 Student Space (28)	
B00D - R0001 - Communal Space - (60.92 SQM)	 Student Space (28)	
B00F - R0001 - Gymnasium - (67.34 SQM)	 Student Space (31)	
B00F - R0002 - Practical Activities - (26.24 SQM)	 Student Space (12)	
B00F - R0003 - Practical Activities - (26.17 SQM)	 Student Space (12)	
B00F - R0004 - Movement - (16.15 SQM)	Not Applicable	Circulation or storage space.