

VENTILATION AUDIT REPORT

| | |
|-------------------------------|--|
| SCHOOL: | Coleambally Central School (4348) |
| AMU REGION: | Southern NSW |
| STATE ELECTORATE: | Murray |
| LOCAL GOVERNMENT AREA: | Murrumbidgee |

4348 - Coleambally Central School
Site Plan (10240)



1:1,713

Printed: 21-Mar-2020

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00A - R0001 - Movement - (44.06 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0003 - Staff Room Annexe - (12.15 SQM) | Office (3) | |
| B00A - R0004 - Staff Room Annexe - (12.11 SQM) | Office (3) | |
| B00A - R0005 - Entry Vestibule - (20.01 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0006 - Movement - (30.36 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0010 - Sick Bay - (17.64 SQM) | Student Space (8) | |
| B00A - R0012 - Principal - (17.07 SQM) | Office (4) | |
| B00A - R0013 - Staff Room Annexe - (12.14 SQM) | Office (3) | |
| B00A - R0014 - Movement - (28.8 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0016 - Duplicating Workroom - (19.95 SQM) | Office (4) | |
| B00A - R0017 - Clerical Office - (17.61 SQM) | Office (4) | |
| B00B - R0001 - Home Base - (56.2 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00B - R0002 - Movement - (82.58 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0006 - Home Base - (85.69 SQM) - Teaching Space: 1 | Student Space (39) | |
| B00B - R0007 - Home Base - (85.69 SQM) - Teaching Space: 1 | Student Space (39) | |
| B00B - R0011 - Home Base - (56.84 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00B - R0015 - Movement - (6.85 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0001 - Movement - (68.04 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0002 - General Learning Space - (57.05 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00C - R0003 - Staff Room Annexe - (27.82 SQM) | Office (6) | |
| B00C - R0004 - Food/Research Space - (24.38 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0005 - Food Technology L.S. - (89.39 SQM) - Teaching Space: 1 | Student Space (41) | |
| B00C - R0007 - Design L.S. - (60.98 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00C - R0008 - Movement - (9.86 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0001 - Movement - (34.18 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0002 - Staff Room - (59.38 SQM) | Office (14) | |
| B00D - R0004 - Staff Room Annexe - (19.07 SQM) | Office (4) | |
| B00D - R0007 - Staff Room Annexe - (16.01 SQM) | Office (4) | |
| B00D - R0008 - Staff Room Annexe - (11.68 SQM) | Office (2) | |
| B00D - R0010 - Movement - (18.96 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0004 - Seminar/Study - (11.38 SQM) | Office (2) | |
| B00E - R0005 - Seminar/Study - (11.2 SQM) | Office (2) | |
| B00E - R0006 - Reading Area - (104.14 SQM) | Student Space (48) | |
| B00E - R0011 - Special Programs Room - (42.43 SQM) | Student Space (19) | |
| B00E - R0012 - Movement - (8.89 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0013 - Reading Area - (143.42 SQM) | Student Space (66) | |
| B00E - R0015 - Movement - (56.87 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0001 - Movement - (219.28 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0011 - Canteen - (41.83 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0018 - Movement - (18.86 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0021 - Staff Room Annexe - (5.95 SQM) | Office (1) | |
| B00F - R0024 - Communal Space - (217.54 SQM) | Student Space (100) | |
| B00F - R0027 - Raised Platform - (61.78 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0001 - Staff Room Annexe - (19.89 SQM) | Office (4) | |
| B00G - R0002 - Materials Technology L.S. - (112.7 SQM) - Teaching Space: 1 | Student Space (52) | |
| B00G - R0008 - Welding Area - (5.24 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0009 - Materials Technology L.S. - (81.26 SQM) - Teaching Space: 1 | Student Space (37) | |
| B00G - R0010 - Withdrawal Space - 1hb - (36.43 SQM) | Student Space (16) | |
| B00G - R0015 - Materials Technology L.S. - (105.78 SQM) - Teaching Space: 1 | Student Space (49) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00G - R0016 - Movement - (59.78 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0005 - Staff Room Annexe - (36.09 SQM) | Office (9) | |
| B00H - R0006 - General Learning Space - (63.09 SQM) - Teaching Space: 1 | Student Space (29) | |
| B00H - R0007 - Practice/Seminar - (26.35 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0009 - Movement - (83.19 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0012 - Laboratory L.S. - (78.67 SQM) - Teaching Space: 1 | Student Space (36) | |
| B00H - R0013 - Preparation - (47.11 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0014 - Laboratory L.S. - (79.11 SQM) - Teaching Space: 1 | Student Space (36) | |
| B00I - R0003 - Movement - (5.61 SQM) | Not Applicable | Circulation or storage space. |
| B00J - R0004 - Movement - (5.66 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0001 - Home Base - (56.17 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00K - R0002 - Movement - (68.82 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0003 - Special Programs Room - (56.66 SQM) | Student Space (26) | |
| B00K - R0007 - Movement - (8.26 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0008 - Home Base - (56.88 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00K - R0009 - Home Base - (56.8 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00K - R0014 - Movement - (9.08 SQM) | Not Applicable | Circulation or storage space. |
| B00L - R0001 - Seminar/Study - (21.95 SQM) | Office (5) | |
| B00M - R0001 - Staff Room Annexe - (22.28 SQM) | Office (5) | |
| B00M - R0002 - General Learning Space - (53.58 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00M - R0003 - General Learning Space - (53.65 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00M - R0006 - General Learning Space - (53.73 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00M - R0007 - Art Learning Space - (53.51 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00M - R0013 - Special Programs Room - (25.6 SQM) | Student Space (11) | |