

VENTILATION AUDIT REPORT

SCHOOL:	Collaroy Plateau Public School (3970)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Wakehurst
LOCAL GOVERNMENT AREA:	Northern Beaches

3970 - Collaroy Plateau Public School
Site Plan (10938)



1:934

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0018 - Movement - (12.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (11.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Special Programs Room - (48.71 SQM)	● Student Space (22)	
B00A - R0022 - Reading Area - (139.66 SQM)	● Student Space (64)	
B00B - R0006 - Home Base - (56.78 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0007 - Home Base - (56.77 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0011 - Movement - (47.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Communal Space - (172.78 SQM)	● Student Space (80)	
B00B - R0013 - Canteen - (18.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Home Base - (56.8 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0020 - Movement - (9.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (13.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Interview - (20.54 SQM)	● Office (5)	
B00B - R0028 - Home Base - (56.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R9001 - Movement - (11 SQM)	Not Applicable	Circulation or storage space.
B00B - R9002 - Interview - (21.11 SQM)	● Office (5)	
B00B - R9003 - Practical Activities - 1hb - (88.44 SQM)	● Student Space (41)	
B00C - R0001 - Home Base - (65.46 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R0002 - Movement - (5.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Home Base - (65.28 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R0009 - Movement - (11.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Movement - (8.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Home Base - (65.46 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0001 - Home Base - (53.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0004 - Movement - (6.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Home Base - (92.97 SQM) - Teaching Space: 1	● Student Space (43)	
B00D - R0008 - Movement - (9.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Movement - (46.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Practical Activities - 1hb - (12.66 SQM)	● Student Space (5)	
B00E - R0001 - Duplicating Workroom - (6.23 SQM)	● Office (1)	
B00E - R0002 - Deputy Principal - (9.47 SQM)	● Office (2)	
B00E - R0004 - Staff Room - (22.16 SQM)	● Office (5)	
B00E - R0005 - Home Base - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0006 - Home Base - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0008 - Home Base - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0009 - Home Base - (52.49 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0013 - Movement - (97.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Home Base - (53.54 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0003 - Home Base - (53.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0004 - Movement - (24.98 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (16.38 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Entry Vestibule - (24.96 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Clerical Office - (19.97 SQM)	● Office (4)	
B00H - R0004 - Principal - (16.8 SQM)	● Office (4)	
B00H - R0005 - Deputy Principal - (13.12 SQM)	● Office (3)	
B00H - R0006 - Staff Room Annexe - (13.23 SQM)	● Office (3)	
B00H - R0007 - Movement - (43.11 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Staff Room - (42.35 SQM)	● Office (10)	
B00H - R0010 - Staff Room Annexe - (23.07 SQM)	● Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0015 - Interview - (13.2 SQM)	Office (3)	
B00H - R0016 - Sick Bay - (8.62 SQM)	Student Space (3)	
B00H - R0020 - Duplicating Workroom - (17.66 SQM)	Office (4)	
B00M - R0001 - Communal Space - (203.41 SQM)	Student Space (94)	
B00M - R0002 - Canteen - (42.1 SQM)	Not Applicable	Circulation or storage space.
B00M - R0021 - Movement - (12.84 SQM)	Not Applicable	Circulation or storage space.
B00M - R0023 - Raised Platform - (61.77 SQM)	Not Applicable	Circulation or storage space.
B00M - R0024 - Movement - (5.56 SQM)	Not Applicable	Circulation or storage space.
OS 601 10124 - OS 601 10124 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 16204 - OS 601 16204 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 11060 - OS 602 11060 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11237 - OS 602 11237 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12942 - OS 602 12942 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13236 - OS 602 13236 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13366 - OS 602 13366 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15299 - OS 602 15299 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 16796 - OS 602 16796 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 12895 - OS 603 12895 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 603 13585 - OS 603 13585 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	