

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Colo Vale Public School (1085)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Wollondilly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wingecarribee</b>

1085 - Colo Vale Public School  
Site Plan (10275)






1:1,072

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Home Base - (61.42 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0006 - Staff Room Annexe - (9.95 SQM)	Office (2)	
B00A - R0011 - Home Base - (59.75 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0029 - Principal - (13.11 SQM)	Office (3)	
B00A - R0034 - Home Base - (59.3 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0036 - Home Base - (61.11 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0045 - Interview - (11.51 SQM)	Office (2)	
B00A - R0046 - Practical Activities - 2hb - (38.06 SQM)	Student Space (17)	
B00A - R0047 - Movement - (66.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Staff Kitchen - (9.02 SQM)	Office (2)	
B00A - R0049 - Staff Room - (54.6 SQM)	Office (13)	
B00A - R0050 - Staff Room Annexe - (16.93 SQM)	Office (4)	
B00A - R0051 - Practical Activities - 2hb - (37.8 SQM)	Student Space (17)	
B00A - R0052 - Interview - (11.57 SQM)	Office (2)	
B00A - R0053 - Deputy Principal - (12.36 SQM)	Office (3)	
B00A - R0054 - Duplicating Workroom - (25.59 SQM)	Office (6)	
B00A - R0055 - Clerical Office - (26.62 SQM)	Office (6)	
B00A - R0056 - Entry Vestibule - (23.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Principal - (18.79 SQM)	Office (4)	
B00A - R0059 - Sick Bay - (11.35 SQM)	Student Space (5)	
B00A - R0060 - Interview - (14.73 SQM)	Office (3)	
B00C - R0003 - Canteen - (26.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Communal Space - (142.75 SQM)	Student Space (66)	
B00C - R0010 - Movement - (6.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Raised Platform - (47.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (10.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Reading Area - (154.01 SQM)	Student Space (71)	
B00D - R0012 - Special Programs Room - (34.39 SQM)	Student Space (15)	
B00E - R0004 - Practical Activities - 1hb - (18.82 SQM)	Student Space (8)	
B00E - R0006 - Home Base - (60.22 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0007 - Withdrawal Space - 2hb - (11.6 SQM)	Student Space (5)	
B00E - R0008 - Home Base - (59.67 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0011 - Practical Activities - 1hb - (19.14 SQM)	Student Space (8)	
B00F - R0002 - Practical Activities - 1hb - (18.99 SQM)	Student Space (8)	
B00F - R0004 - Home Base - (60.84 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0005 - Withdrawal Space - 2hb - (11.58 SQM)	Student Space (5)	
B00F - R0006 - Home Base - (60.26 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0008 - Practical Activities - 1hb - (18.88 SQM)	Student Space (8)	
B00F - R0009 - Practical Activities - 1hb - (18.89 SQM)	Student Space (8)	
B00F - R0011 - Home Base - (59.55 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0013 - Withdrawal Space - 2hb - (11.53 SQM)	Student Space (5)	
B00F - R0014 - Home Base - (59.83 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0016 - Practical Activities - 1hb - (18.71 SQM)	Student Space (8)	
B00G - R0002 - Special Programs Room - (43.29 SQM)	Student Space (20)	
B00G - R0005 - Practical Activities/Movement - 1hb - (20.05 SQM)	Student Space (9)	
B00G - R0006 - Home Base - (67.18 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R0007 - Withdrawal Space - 2hb - (11.74 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0008 - Practical Activities/Movement - 1hb - (19.83 SQM)	 Student Space (9)	
B00G - R0009 - Home Base - (60.22 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0012 - Special Programs Room - (43.3 SQM)	 Student Space (20)	