

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Colyton Public School (1596)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Mount Druitt</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blacktown</b>

1596 - Colyton Public School  
Site Plan (10319)



1:1,294






Printed: 06-Apr-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Duplicating Workroom - (23.97 SQM)	Office (5)	
B00A - R0002 - Movement - (12.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Sick Bay - (10.97 SQM)	Student Space (5)	
B00A - R0009 - Movement - (32.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Staff Room - (79.28 SQM)	Office (19)	
B00A - R0011 - Interview - (13.73 SQM)	Office (3)	
B00A - R0012 - Movement - (12.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Clerical Office/Workroom - (12.21 SQM)	Office (3)	
B00A - R0014 - Principal - (25.36 SQM)	Office (6)	
B00A - R0015 - Deputy Principal - (12.99 SQM)	Office (3)	
B00A - R0018 - Clerical Office - (13.91 SQM)	Office (3)	
B00A - R0019 - Movement - (39.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (18.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (12.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Seminar/Study - (17.58 SQM)	Office (4)	
B00A - R1011 - Reading Area - (258.03 SQM)	Student Space (119)	
B00A - R1014 - Movement - (11.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Movement - (43.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (38.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Home Base - (56.72 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0005 - Home Base - (82.59 SQM) - Teaching Space: 1	Student Space (38)	
B00C - R0001 - Home Base - (53.13 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0004 - Movement - (6.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Movement - (9.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0009 - Home Base - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0012 - Movement - (12.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (8.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Withdrawal Space - 1hb - (8.19 SQM)	Student Space (3)	
B00C - R0018 - Home Base - (53.12 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0001 - Movement - (179.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Practical Activities - 1hb - (15.01 SQM)	Student Space (6)	
B00D - R0007 - Home Base - (59.28 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0008 - Withdrawal Space - 1hb - (14.17 SQM)	Student Space (6)	
B00D - R0009 - Home Base - (58.7 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0010 - Practical Activities - 1hb - (22.1 SQM)	Student Space (10)	
B00D - R0011 - Home Base - (58.61 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0012 - Withdrawal Space - 1hb - (14.12 SQM)	Student Space (6)	
B00D - R0013 - Home Base - (60.14 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0014 - Practical Activities - 1hb - (28.61 SQM)	Student Space (13)	
B00D - R0015 - Home Base - (58.26 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0016 - Withdrawal Space - 1hb - (14.16 SQM)	Student Space (6)	
B00D - R0017 - Home Base - (59.36 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0018 - Practical Activities - 1hb - (15.13 SQM)	Student Space (7)	
B00D - R0020 - Movement - (82.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Movement - (46.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0002 - Practical Activities - 1hb - (5.25 SQM)	Student Space (2)	
B00E - R0005 - Movement - (6.87 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0006 - Movement - (9.36 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (51.36 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0009 - Practical Activities - 1hb - (5.9 SQM)	● Student Space (2)	
B00F - R0001 - Movement - (34.81 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Home Base - (52.48 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0003 - Home Base - (52.41 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0001 - Movement - (109.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Movement - (24.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Movement - (10.16 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Home Base - (56.9 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0022 - Practical Activities - 1hb - (6.84 SQM)	● Student Space (3)	
B00G - R0024 - Computer Room - (70.96 SQM)	● Student Space (32)	
B00H - R0001 - Movement - (12.97 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Special Programs Room - (46.58 SQM)	● Student Space (21)	
B00I - R0001 - Staff Room Annexe - (37.93 SQM)	○ Office (9)	
B00I - R0002 - Interview - (17.61 SQM)	○ Office (4)	
B00I - R0006 - Movement - (7.94 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Staff Kitchen - (11.45 SQM)	○ Office (2)	
B00I - R0010 - Movement - (22.53 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (54.39 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Home Base - (84.02 SQM) - Teaching Space: 1	● Student Space (38)	
B00K - R0003 - Practical Activities - 1hb - (28.1 SQM)	● Student Space (13)	
B00L - R0001 - Movement - (37.42 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Home Base - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R0003 - Special Programs Room - (53.44 SQM)	● Student Space (24)	
B00M - R0001 - Movement - (47.4 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Home Base - (53.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00M - R0003 - Home Base - (66.76 SQM) - Teaching Space: 1	● Student Space (30)	
B00M - R0005 - Withdrawal Space - 2hb - (10.96 SQM)	● Student Space (5)	
B00P - R0001 - Movement - (12.23 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - Movement - (13.45 SQM)	Not Applicable	Circulation or storage space.
B00P - R0003 - Raised Platform - (61.52 SQM)	Not Applicable	Circulation or storage space.
B00P - R0004 - Communal Space - (207.88 SQM)	● Student Space (96)	
B00P - R0017 - Canteen - (43.52 SQM)	Not Applicable	Circulation or storage space.
B00P - R0023 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Practical Activities - 1hb - (18.94 SQM)	● Student Space (8)	
B00S - R0003 - Withdrawal Space - 2hb - (11.65 SQM)	● Student Space (5)	
B00S - R0004 - Practical Activities - 1hb - (19.04 SQM)	● Student Space (8)	
B00S - R0006 - Home Base - (60.6 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R0007 - Home Base - (60.64 SQM) - Teaching Space: 1	● Student Space (28)	
OS 602 12496 - OS 602 12496 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12681 - OS 602 12681 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13747 - OS 602 13747 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14392 - OS 602 14392 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14509 - OS 602 14509 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15766 - OS 602 15766 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19824 - OS 602 19824 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 14795 - OS 603 14795 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 16793 - OS 603 16793 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 606 19039 - OS 606 19039 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19149 - OS 606 19149 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19155 - OS 606 19155 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 750 17700 - OS 750 17700 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	
OS 750 19559 - OS 750 19559 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	