

VENTILATION AUDIT REPORT

| | |
|-------------------------------|--------------------------------------|
| SCHOOL: | Comboyne Public School (1601) |
| AMU REGION: | North Coast |
| STATE ELECTORATE: | Oxley |
| LOCAL GOVERNMENT AREA: | Port Macquarie-Hastings |

1601 - Comboyne Public School
Site Plan (10323)













1:1,155

Printed: 20-Mar-2020

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|--|-------------------------------|
| B00A - R0002 - Home Base - (53.73 SQM) - Teaching Space: 1 |  Student Space (24) | |
| B00A - R0003 - Principal - (10.82 SQM) |  Office (2) | |
| B00A - R0004 - Clerical Office - (10.86 SQM) |  Office (2) | |
| B00A - R0006 - Movement - (8.91 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0007 - Sick Bay - (5.88 SQM) |  Student Space (2) | |
| B00A - R0009 - Staff Room - (21.41 SQM) |  Office (5) | |
| B00A - R0011 - Home Base - (41.87 SQM) - Teaching Space: 1 |  Student Space (19) | |
| B00A - R0012 - Practical Activities - 1hb - (5.4 SQM) |  Student Space (2) | |
| B00A - R0013 - Reading Area - (47.75 SQM) |  Student Space (22) | |
| B00A - R0018 - Canteen - (28.89 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0019 - Practical Activities - (30.68 SQM) |  Student Space (14) | |
| B00B - R0001 - Movement - (41.6 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0001 - Special Programs Room - (16.82 SQM) |  Student Space (7) | |